

TTS PRO REPORT

Basic Electrical Equipment Test Report

Source	PADFX tester export
Description	Electrical equipment testing report
Generated	03/06/2026

Total	152	Passed	138	Failed	0
-------	-----	--------	-----	--------	---

PRO REPORT - TEST REGISTER

RESULTS SUMMARY						
Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
AT2011	RCD CAL ROOM	CAL Room	18/09/2025	18/09/2026	Pass	RCD: t Δ N, (+): 40.3 ms; t Δ N, (-): 29.7 ms; Uc: 0.3 V
TTS00099	C6 IEC Lead	CAL Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00101	Seaward lead	CAL Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00164	Fig 8 Lead	CAL Room	17/09/2025	17/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS8003	Red IEC Lead	CAL Room	26/08/2025	26/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
001003	KETTLE	Kitchen	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.88 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00065	Microwave	Kitchen	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; Leakage: Idiff TRMS: 0.18 mA; P: 340 W
TTS00067	Sandwich toastie	Kitchen	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.18 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00070	RCD KITCHEN	Kitchen	18/09/2025	18/09/2026	Pass	RCD: t Δ N, (+): 7.5 ms; t Δ N, (-): 17.2 ms; Uc: 0.1 V
TTS00178	Fridge	Kitchen	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS1008	Coffee Machine	Kitchen	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Touch leakage: Itou TRMS: 0.002 mA; Itou AC: 0.002 mA; Itou DC: 0.001 mA; P: 1630 W
LPM102	RCD	LPM	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; RCD: t Δ N, (+): 22.5 ms; t Δ N, (-): 23.7 ms; Polarity: Result: Pass
TTS00313	IEC LEAD C6	LPM	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.81 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00314	LAPTOP SUPPLY	LPM	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Touch leakage: Itou TRMS: 0.056 mA; Itou AC: 0.056 mA; Itou DC: 0.001 mA; P: 0.16 W
TTS00202	IEC Lead	Reception	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00203	Dell PC	Reception	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00204	Power board	Reception	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; R iso EE: Riso:...
TTS0220	HP Printer	Reception	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS2020	IEC Lead	Reception	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00008	Knife	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00015	Solder Station	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; Leakage: Idiff TRMS: 0.27 mA; P: 147.5 W
TTS00109	Fume Extractor	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00125	Fig 8 Lead	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass
TTS00217	Power Supply	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00236	Heat Gun	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00306A	IEC LEAD	Repairs	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.04 Ohm; R iso EE: Riso: 180.5 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00307	IEC LEAD	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00309	Light	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.35 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00311	SOLDER IRON	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.32 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00311	IEC Cable	Repairs	26/08/2025	26/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS0077	Glue Gun	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS01003	POWER BOARD	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; Continuity: R: 0.00 Ohm; Continuity: R: 0.00 Ohm; Polarity: Result...
001001	TOASTER	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
001002	SANDWICH TOASTER	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
RCD003	RCD SHOWROOM	Show Room	18/09/2025	18/09/2026	Pass	RCD: t IΔN, (+): 5.9 ms; t IΔN, (-): 15.6 ms; Uc: 0.8 V
TTS00110	Lead figure 8	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00123	IEC Lead	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00143	Seaward Lead	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.11 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00145	IEC Lead	Show Room	26/08/2025	26/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00146	Printer Charger	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.17 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00150	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.04 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00152	Battery Charger	Show Room	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00167	Battery Charger	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00179	Iso Tx	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS00218	Power Supply	Show Room	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00219	RCD	Show Room	19/05/2026	19/05/2027	Pass	RCD: t IΔN, (+): 7.5 ms; t IΔN, (-): 17.5 ms; Uc: 1.0 V
TTS00220	C6 IEC Lead	Show Room	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00221	Kyoritsu Lead	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00228	Power Board	Show Room	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.00 Ohm; Continuity: R: 0.00 Ohm; Continuity: R: 0...
TTS00229	Power Supply	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 527 V
TTS00230	Television	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00235	Phone Charger	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00244	IEC Lead	Show Room	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00247	Charger	Show Room	17/09/2025	17/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: 74.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00250	IEC Lead LH	Show Room	18/09/2025	18/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00251	IEC Lead RH	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00267	Power Board	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0...
TTS00268	Power Board	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; R iso EE: Riso:...
TTS00269	Phone Charger	Show Room	18/09/2025	18/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00272	USB CHARGER	Show Room	21/05/2026	21/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 527 V
TTS00274	Charger	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00307	Toaster	Show Room	26/08/2025	26/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.12 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00308	IRON	Show Room	21/05/2026	21/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.15 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS00320	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.05 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00321	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00322	KYORITSU LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.11 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS0088	IEC Lead	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS10001	SANDER	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 527 V
TTS10006	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS10007	POWER BOARD	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; R iso EE: Riso:...
TTS10008	METREL XC LEAD	Show Room	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.16 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS2011	Instaltest Lead	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS8015	RCD Portable	Show Room	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Leakage: Idiff TRMS: 0.05 mA; P: 1.71 W; RCD: t ΔN, (+): 15.3 ms;...
TTS00171	C6 IEC Lead	Showroom	17/09/2025	17/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
AT2010-PH1	3 Phase RCD	WAREHOUSE	18/09/2025	18/09/2026	Pass	RCD: t ΔN, (+): 26.6 ms; t ΔN, (-): 36.6 ms; Uc: 0.5 V
RCD001	RCD PRINTERS	WAREHOUSE	18/09/2025	18/09/2026	Pass	RCD: t ΔN, (+): 45.6 ms; t ΔN, (-): 36.6 ms; Uc: 0.1 V
TTS00047	IEC lead	WAREHOUSE	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00100	Zebra PSU	WAREHOUSE	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00248	IEC Lead	WAREHOUSE	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00265	Printer PSU	WAREHOUSE	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00278	Mini PC PSU	WAREHOUSE	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS170	Laminator	WAREHOUSE	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
0002	Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
001005	LABEL PRINTER	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.11 Ohm
001006	COMPUTER	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.12 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
001007	WALL FAN	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
001008	POWER SUPPLY	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
AT2000	Battery Charger	Warehouse	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
AT2002	SEW Lead	Warehouse	18/09/2025	18/03/2026	Pass	RCD: t ΔN, (+): 9.1 ms; t ΔN, (-): 19.1 ms; Uc: 0.2 V
AT2009	IEC Lead	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00010	Extension lead	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00033	IEC lead	Warehouse	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00048	IEC Lead	Warehouse	21/05/2026	21/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00053	Label Printer	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00054	Monitor	Warehouse	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00059	Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00115	Phone Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00131	Laminator	Warehouse	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00132	Phone Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00133	IEC Lead	Warehouse	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00134	Fig 8 Lead	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00151	Power Supply	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00156	Power Board	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0...
TTS00157	IEC Lead	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00161	Phone Charger	Warehouse	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00172	Power Supply	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: 173.0 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00174	Label Winder	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00183	Printer	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.16 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00237	Charger	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00238	Kyoritsu lead	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00256	C6 IEC Lead	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00257	Power Supply	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00258	Power Board	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0...
TTS00262	IEC Lead	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00263	Monitor	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS0027	Power Board	Warehouse	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.03 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.02 Ohm; R iso EE: Riso:...
TTS00275	Monitor PSU	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00276	MRL	Warehouse	02/09/2025	02/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00277	IEC Lead	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00291	Charger	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00296	RCD Portable	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Leakage: Idiff TRMS: 0.03 mA; P: 1.69 W; RCD: t IΔN, (+): 1.2 ms; t IΔN, (-): 18.4 ms; Pola...
TTS00306	Power Board	Warehouse	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0...
TTS00306A0002	FIG 8	Warehouse	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass
TTS00310	Power Supply	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00312	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.09 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00313	Power Supply	Warehouse	26/08/2025	26/02/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00315	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00316	POWER SUPPLY	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00317	BATTERY CHARGER	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00318	KYORITSU LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00319	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00323	KYORITSU LEAD	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.06 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS0084	Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS01004	TSC Psu	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS10003	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS10004	IEC LEAD	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS1306	IEC Lead	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS260301	FIG 8	Warehouse	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass
AT2005	TOASTER	CAL ROOM	19/07/2022	19/07/2023	Recorded	No test rows
AT2010-PH3	3 Phase RCD	CAL Room	20/07/2023	19/07/2024	Recorded	No test rows
TTS00072	IEC Lead	CAL Room	29/01/2025	29/01/2026	Recorded	No test rows
TTS00199	Cal Box Lead	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00232	IEC lead	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00233	DMM 6500	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00253	IEC Lead RH	CAL Room	29/01/2025	29/01/2026	Recorded	No test rows
TTS00253	Kyoritsu Lead	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00254	Cal Box	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00255	RCD Portable	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00305	IEC Lead	CAL Room	29/01/2025	31/07/2025	Recorded	No test rows
TTS0284	TTS0284	CAL Room	05/02/2025	05/08/2025	Recorded	No test rows
TTS0285	Extension lead	CAL Room	05/02/2025	07/08/2025	Recorded	No test rows
TTS00205	Instaltest Lead	Warehouse	04/02/2025	06/08/2025	Recorded	No test rows