

Customer No.:		Inspect. rec. No.:		Order No.:	
---------------	--	--------------------	--	------------	--

PRO ELECTRICAL EQUIPMENT TEST REPORT

GENERAL DATA

Customer address:			Contractor:		
Description:			Electrical equipment testing report		
Type of equipment:	☐ EV cable ☐ Medical ☐ Portable appliance ☐ Machine ☐ Welding ☐ Switchgear ☐ Other ☐ CE Marketing		Reason for the test:	☐ In service ☐ Repair ☐ Periodic test ☐ Other	
Test in accordance with:	AS/NZS 3760	Start of testing:	18/09/2025	End of testing:	04/02/2025
Measuring instruments used:	Model:	MI 3340	Serial No.:	24460062	
Customer contact details:			Test engineer contact details:		

INSPECTION AND TEST RESULTS

Statement	Date of next inspection:
All electrical equipment was tested in accordance with the listed regulations and technical standards. Equipment that passed was marked appropriately and can be declared safe according to accepted technical rules. Inspection and test results are summarized in the attached pages with a recommended re-test date.	18/09/2026
Method of labelling	☐ Pass/Fail tags ☐ Barcoded tags ☐ RFID tags
Results:	No faults found
Notes:	

SIGNATURE AND STAMP

Client:	Operator:
☐ Report is fully accepted. Client is informed about inspection and test results. ☐ Client is informed about status of faulty equipment.	☐ Electrical equipment was tested according to valid regulations and technical standards. ☐ Faulty equipment and measures are appropriately noted.
Location: Date: Signature:	Location: Date: Signature:

PRO REPORT - TEST REGISTER

RESULTS SUMMARY						
Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
AT2011	RCD CAL ROOM	CAL Room	18/09/2025	18/09/2026	Pass	RCD: t Δ N, (+): 40.3 ms; t Δ N, (-): 29.7 ms; Uc: 0.3 V
TTS00099	C6 IEC Lead	CAL Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00101	Seaward lead	CAL Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00164	Fig 8 Lead	CAL Room	17/09/2025	17/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS8003	Red IEC Lead	CAL Room	26/08/2025	26/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
001003	KETTLE	Kitchen	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.88 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00065	Microwave	Kitchen	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; Leakage: Idiff TRMS: 0.18 mA; P: 340 W
TTS00067	Sandwich toastie	Kitchen	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.18 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00070	RCD KITCHEN	Kitchen	18/09/2025	18/09/2026	Pass	RCD: t Δ N, (+): 7.5 ms; t Δ N, (-): 17.2 ms; Uc: 0.1 V
TTS00178	Fridge	Kitchen	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS1008	Coffee Machine	Kitchen	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Touch leakage: Itou TRMS: 0.002 mA; Itou AC: 0.002 mA; Itou DC: 0.001 mA; P: 1630 W
LPM102	RCD	LPM	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; RCD: t Δ N, (+): 22.5 ms; t Δ N, (-): 23.7 ms; Polarity: Result: Pass
TTS00313	IEC LEAD C6	LPM	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.81 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00314	LAPTOP SUPPLY	LPM	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Touch leakage: Itou TRMS: 0.056 mA; Itou AC: 0.056 mA; Itou DC: 0.001 mA; P: 0.16 W
TTS00202	IEC Lead	Reception	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00203	Dell PC	Reception	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00204	Power board	Reception	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; R iso EE: Riso:...
TTS0220	HP Printer	Reception	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS2020	IEC Lead	Reception	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00008	Knife	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00015	Solder Station	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; Leakage: Idiff TRMS: 0.27 mA; P: 147.5 W
TTS00109	Fume Extractor	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00125	Fig 8 Lead	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass
TTS00217	Power Supply	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00236	Heat Gun	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00306A	IEC LEAD	Repairs	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.04 Ohm; R iso EE: Riso: 180.5 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00307	IEC LEAD	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00309	Light	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.35 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00311	SOLDER IRON	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.32 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00311	IEC Cable	Repairs	26/08/2025	26/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS0077	Glue Gun	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS01003	POWER BOARD	Repairs	18/09/2025	18/03/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; Continuity: R: 0.00 Ohm; Continuity: R: 0.00 Ohm; Polarity: Result...
001001	TOASTER	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
001002	SANDWICH TOASTER	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
RCD003	RCD SHOWROOM	Show Room	18/09/2025	18/09/2026	Pass	RCD: t IΔN, (+): 5.9 ms; t IΔN, (-): 15.6 ms; Uc: 0.8 V
TTS00110	Lead figure 8	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00123	IEC Lead	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00143	Seaward Lead	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.11 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00145	IEC Lead	Show Room	26/08/2025	26/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00146	Printer Charger	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.17 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00150	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.04 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00152	Battery Charger	Show Room	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00167	Battery Charger	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00179	Iso Tx	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS00218	Power Supply	Show Room	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00219	RCD	Show Room	19/05/2026	19/05/2027	Pass	RCD: t IΔN, (+): 7.5 ms; t IΔN, (-): 17.5 ms; Uc: 1.0 V
TTS00220	C6 IEC Lead	Show Room	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00221	Kyoritsu Lead	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.13 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00228	Power Board	Show Room	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.00 Ohm; Continuity: R: 0.00 Ohm; Continuity: R: 0...
TTS00229	Power Supply	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 527 V
TTS00230	Television	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00235	Phone Charger	Show Room	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00244	IEC Lead	Show Room	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00247	Charger	Show Room	17/09/2025	17/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: 74.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00250	IEC Lead LH	Show Room	18/09/2025	18/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00251	IEC Lead RH	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00267	Power Board	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0...
TTS00268	Power Board	Show Room	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; R iso EE: Riso:...
TTS00269	Phone Charger	Show Room	18/09/2025	18/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00272	USB CHARGER	Show Room	21/05/2026	21/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 527 V
TTS00274	Charger	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00307	Toaster	Show Room	26/08/2025	26/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.12 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00308	IRON	Show Room	21/05/2026	21/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.15 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS00320	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.05 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00321	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00322	KYORITSU LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.11 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS0088	IEC Lead	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS10001	SANDER	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 527 V
TTS10006	IEC LEAD	Show Room	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS10007	POWER BOARD	Show Room	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; R iso EE: Riso:...
TTS10008	METREL XC LEAD	Show Room	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.16 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS2011	Instaltest Lead	Show Room	28/08/2025	28/08/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS8015	RCD Portable	Show Room	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.01 Ohm; Leakage: Idiff TRMS: 0.05 mA; P: 1.71 W; RCD: t ΔN, (+): 15.3 ms;...
TTS00171	C6 IEC Lead	Showroom	17/09/2025	17/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
AT2010-PH1	3 Phase RCD	WAREHOUSE	18/09/2025	18/09/2026	Pass	RCD: t ΔN, (+): 26.6 ms; t ΔN, (-): 36.6 ms; Uc: 0.5 V
RCD001	RCD PRINTERS	WAREHOUSE	18/09/2025	18/09/2026	Pass	RCD: t ΔN, (+): 45.6 ms; t ΔN, (-): 36.6 ms; Uc: 0.1 V
TTS00047	IEC lead	WAREHOUSE	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00100	Zebra PSU	WAREHOUSE	19/05/2026	19/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00248	IEC Lead	WAREHOUSE	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00265	Printer PSU	WAREHOUSE	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00278	Mini PC PSU	WAREHOUSE	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS170	Laminator	WAREHOUSE	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
0002	Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
001005	LABEL PRINTER	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.11 Ohm
001006	COMPUTER	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.12 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
001007	WALL FAN	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
001008	POWER SUPPLY	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
AT2000	Battery Charger	Warehouse	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
AT2002	SEW Lead	Warehouse	18/09/2025	18/03/2026	Pass	RCD: t ΔN, (+): 9.1 ms; t ΔN, (-): 19.1 ms; Uc: 0.2 V
AT2009	IEC Lead	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00010	Extension lead	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00033	IEC lead	Warehouse	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00048	IEC Lead	Warehouse	21/05/2026	21/05/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00053	Label Printer	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00054	Monitor	Warehouse	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.14 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00059	Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00115	Phone Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00131	Laminator	Warehouse	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00132	Phone Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00133	IEC Lead	Warehouse	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.00 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00134	Fig 8 Lead	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00151	Power Supply	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00156	Power Board	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0...
TTS00157	IEC Lead	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00161	Phone Charger	Warehouse	18/05/2026	18/05/2027	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00172	Power Supply	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: 173.0 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00174	Label Winder	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00183	Printer	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.16 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00237	Charger	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00238	Kyoritsu lead	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.08 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00256	C6 IEC Lead	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00257	Power Supply	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00258	Power Board	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0...
TTS00262	IEC Lead	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00263	Monitor	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.10 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 527 V
TTS0027	Power Board	Warehouse	21/05/2026	21/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; Continuity: R: 0.03 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0.02 Ohm; R iso EE: Riso:...
TTS00275	Monitor PSU	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00276	MRL	Warehouse	02/09/2025	02/03/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00277	IEC Lead	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00291	Charger	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00296	RCD Portable	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; Leakage: Idiff TRMS: 0.03 mA; P: 1.69 W; RCD: t ΔN, (+): 1.2 ms; t ΔN, (-): 18.4 ms; Pola...
TTS00306	Power Board	Warehouse	28/08/2025	28/02/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.02 Ohm; Continuity: R: 0.01 Ohm; Continuity: R: 0...
TTS00306A0002	FIG 8	Warehouse	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass
TTS00310	Power Supply	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00312	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.09 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V
TTS00313	Power Supply	Warehouse	26/08/2025	26/02/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00315	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.03 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00316	POWER SUPPLY	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00317	BATTERY CHARGER	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00318	KYORITSU LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS00319	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS00323	KYORITSU LEAD	Warehouse	19/05/2026	19/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.06 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS0084	Charger	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS01004	TSC Psu	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; R iso EE: Riso: >199.9 MOhm; R236: >199.9 MOhm; Um: 526 V
TTS10003	IEC LEAD	Warehouse	18/05/2026	18/11/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.01 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS10004	IEC LEAD	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS1306	IEC Lead	Warehouse	12/03/2026	12/09/2026	Pass	Visual: Visual inspection: Pass; Continuity: R: 0.02 Ohm; R iso EE: Riso: >199.9 MOhm; Um: 526 V; Polarity: Result: Pass
TTS260301	FIG 8	Warehouse	12/03/2026	12/03/2027	Pass	Visual: Visual inspection: Pass
AT2005	TOASTER	CAL ROOM	19/07/2022	19/07/2023	Recorded	No test rows
AT2010-PH3	3 Phase RCD	CAL Room	20/07/2023	19/07/2024	Recorded	No test rows
TTS00072	IEC Lead	CAL Room	29/01/2025	29/01/2026	Recorded	No test rows
TTS00199	Cal Box Lead	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00232	IEC lead	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00233	DMM 6500	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00253	IEC Lead RH	CAL Room	29/01/2025	29/01/2026	Recorded	No test rows
TTS00253	Kyoritsu Lead	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00254	Cal Box	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00255	RCD Portable	CAL Room	19/07/2022	19/07/2023	Recorded	No test rows
TTS00305	IEC Lead	CAL Room	29/01/2025	31/07/2025	Recorded	No test rows
TTS0284	TTS0284	CAL Room	05/02/2025	05/08/2025	Recorded	No test rows
TTS0285	Extension lead	CAL Room	05/02/2025	07/08/2025	Recorded	No test rows
TTS00205	Instaltest Lead	Warehouse	04/02/2025	06/08/2025	Recorded	No test rows