Service Summary Report

Elpaso County Buildings- Colorado Springs - COLORADO SPRINGS, USA - 325 S CASCADE AVE

El Paso County September 2026 Service Report

Last 30 Days (08/15/2026 - 09/14/2026)

NALCO Water
An Ecolab Company

Program Tracker

Last Updated By: Erica Prushinski, 09/14/2026

See attached report for September 2026. Please review the following action items:

Cooling Towers and Chilled Loops

1. Main CUP Tower
    1. The conductivity and TRASAR dosage were low. Recommended to turn up pump to get the chemical dosage back in range which will fix everything else. (Want between 100-150)
    2. All other readings were acceptable.
2. CUP chilled loop.
    1. The nitrite level was acceptable.
    2. The other readings were acceptable.
3. TSB Cooling Tower
    1. Conductivity was low but trasar was high dosage. No concerns at this time.
    2. All other readings were acceptable.
4. Regional Cooling Tower
    1. TRASAR dosage was right in range.
    2. All other readings were acceptable.
        1. Will look if the Aquatrol is comparable to our chemicals to see if you can just use of the chemical to throw it away.
5. Regional Chilled Loop
    1. All readings acceptable.

CUP Boilers

1. All boilers are off.

Sent quotes for sampling of chilled loop.

E Data - Boilers

Data Set

Asset | Mapping Location	Hardness	Neutralized Conductivity	NexGuard	O Alkalinity	pH	Sulfite	Conductivity
Boiler 2 | Blowdown	-	-	-	-	-	-	-
Feedwater/Condensate | Outlet	-	-	-	-	-	-	-
Softener | Treated Water	-	-	-	-	-	-	-

E Data - Cooling

Data Set

09/09/2026 09:00
Erica Prushinski

Asset | Mapping Location	pH	Conductivity	TRASAR Dose	Calcium	M Alkalinity	Free Chlorine	Nitrite
Cooling Tower_CUP | Blowdown	7.80 No Limits	999.00 µS/cm 800.00 Min	50.00 ppm No Limits	288.00 ppm as $CaCO_3$ No Limits	280.00 ppm as $CaCO_3$ 401.00 Max	0.00 ppm as I_2 No Limits	-
Chilled Loop Regional | Primary Test Point	10.00 No Limits	2547.00 µS/cm No Limits	-	-	-	-	720.00 ppm No Limits
Cooling Tower_TSB | Blowdown	8.60 No Limits	717.00 µS/cm No Limits	235.00 ppm 175.00 Max	180.00 ppm as $CaCO_3$ No Limits	180.00 ppm as $CaCO_3$ No Limits	0.11 ppm as I_2 No Limits	-
Chilled Loop_CUP | Primary Test Point	9.40 No Limits	1417.00 µS/cm No Limits	-	-	-	-	560.00 ppm No Limits

Asset | Mapping Location	pH	Conductivity	TRASAR Dose	Calcium	M Alkalinity	Free Chlorine	Nitrite
Regional Cooling Tower | Blowdown	8.00 No Limits	71133.00 µS/cm No Limits	141.00 ppm 175.00 Max	352.00 ppm as $CaCO_3$ No Limits	350.00 ppm as $CaCO_3$ No Limits	0.82 ppm as I_2 No Limits	-

Actions & Recommendations (Showing all Open items)

Sites With Actions	Total Actions	Total Savings	Total Actions by Impact
1	1	$0	0 Safety, 0 High, 0 Medium, 1 Low

Asset	Impact	Recommendation Date	Responsible Person	Action Created By	Savings	Most Recent Action Date
Chilled Loop Regional	Low	11/30/2022	Paul Hoffman	Brian Epps	-	-
Problem:Observed chilled loop water dark colored.						
Recommended Action:Options to improve water: empty loop of dirty water then add fresh make up water plus Nitrite inhibitor. Add filtration (filter feeder, side stream, etc).						
Most Recent Action Taken: -						

System Performance by Parameter: Cooling Tower_Regional


Regional Cooling Tower



Parameter Name	% Performance	Status	Source	Lower Limit	Upper Limit	Latest Value	Last Reading Date Time	Last Reading Status
TRASAR Dose	100.0%		E	--	175	141 ppm	09/09/2026 09:00:00	

System Performance by Parameter: Cooling Tower TSB

Cooling Tower_TSB




Parameter Name	% Performance	Status	Source	Lower Limit	Upper Limit	Latest Value	Last Reading Date Time	Last Reading Status
TRASAR Dose	0.0%		E	--	175	235 ppm	09/09/2026 09:00:00	

System Performance by Parameter: Cooling Tower CUP

Cooling

Tower_CUP



Parameter Name	% Performance	Status	Source	Lower Limit	Upper Limit	Latest Value	Last Reading Date Time	Last Reading Status
Conductivity	0.0%		E	800	--	999 µS/cm	09/09/2026 09:00:00	
M Alkalinity	100.0%		E	--	401	280 ppm as $CaCO_3$	09/09/2026 09:00:00	

Inventory

No data available

Erica.Prushinski@ecolab.com | 09/14/2026 22:13:00

Service Summary Dashboard

Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Nalco and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Nalco's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.