RFP 27-07 Fire Sprinkler System and Portable Extinguisher Services
Addendum #1 - Inquiries and Responses
Posted on October 21, 2026

Inquiry #1
The RFP states “Any costs associated with submitting these reports shall be the responsibility of the awarded Contractor.” This is only listed under the scope of work for fire extinguisher inspections. Does that mean we can pass along the cost of report submittals for sprinkler inspections, but not fire extinguishers? Or will all report fees be the responsibility of the vendor?

Response #1
BVSD will cover the costs of reports that are issued to AHJ’s via Brycer or alternate online services, however, awarded Contractors should include an itemized cost to cover Brycer / Compliance Engine reporting Fees **upfront** in the original inspection quote or deficiency repair quote. Fees should not be added later when the invoice is submitted. This is to help streamline payment processing for when purchase orders are issued for specific dollar amounts.

In addition to Part 3 – Portable Fire Extinguisher Annual Testing and Maintenance in RFP 27-07, the request for compliance reporting fees to be included was also identified for sprinkler inspections as outlined below:

Part 1 - Annual Fire Sprinkler System Inspections
Scope of Services

- Most fire jurisdictions within Boulder Valley School District require fire sprinkler inspection reports to be submitted by the Contractor to The Compliance Engine.
- **Any associated costs involved with submitting these reports shall be the responsibility of the awarded Contractor and included in the submitted proposal.**

Inquiry #2
Will the district be participating in any purchasing cooperatives such as OMNIA for this RFP? Or will the district be ok with a vendor tying their pricing to a purchasing cooperative?

Response #2
The District will consider the use of OMNIA or other Cooperative agreements. The District is aware that cooperative pricing represents a ceiling and that pricing is negotiable.

Inquiry #3
Is there a previous report or additional information available regarding the manufacturer, make, model, devices, or coverage for the Suppression Systems?

Response #3

Of the two District Clean Agent suppression systems in IT Server rooms, one is a Fike HFC-125 system with (2) smoke detectors and (1) pull station. The other Clean Agent system is an older Halon system.

Inquiry #4
Is there a previous report or additional information available regarding the manufacturer, make, model, or GPM for the Fire Pump?

Response #4
The recently installed electric fire pump is rated for 1000GPM @ 90 PSI. It's a Peerless Model # 6AEF16C.

Inquiry #5
Under the fire extinguisher service, items are listed as 5 lb, 10 lb, ABC, and K Class. Could you clarify if the K Class extinguishers are 6L? Also, is line three intended to be 20 lb ABC, assuming the 5 lb and 10 lb references are also standard ABC extinguishers?

Response #5
Yes, K Class extinguishers are 6L.
Please provide pricing for 5 lb standard ABC and 10 lb. standard ABC only.

Inquiry #6
Could you clarify if the K Class extinguishers are 6L?

Response #6
Yes, K Class extinguishers are 6L.

Inquiry #7
Is line three intended to be 20 lb ABC, assuming the 5 lb and 10 lb references are also standard ABC extinguishers?

Response #7
Please provide pricing for 5 lb standard ABC and 10 lb. standard ABC only

Inquiry #8
Should we anticipate any sprinkler head testing for service work, as it does not appear to be included in the current scope of service?

Response #8
Visual inspections of all sprinkler heads should be included in the scope of Part 1. The awarded Contractor should be prepared to provide recommendations for aging heads, code changes, and manufacturers' recalls on heads. The findings should be included in the inspection report. Based on these recommendations, BVSD will proceed with sprinkler head testing or head replacements on an "As Needed" basis.

Inquiry #9
Is the fire pump Electric or Diesel?

Response #9

It is an Electric Fire Pump. The recently installed electric fire pump is rated for 1000GPM @ 90 PSI. It’s a Peerless Model # 6AEF16C.