Adams County Finance Department
Purchasing Division
4430 South Adams County Parkway
Brighton, Colorado 80601

ADDENDA NUMBER 2
COVER SHEET

Today's Date:	November 13th, 2026
IFB Issue Date:	October 9th, 2026
IFB Number:	IFB-JL-2026.766
IFB Title:	Street Light Repair and Replacement at the Colorado Air and Space Port
Mandatory Pre-Bid Meeting:	Wednesday October 21st, 2026, at 10:00am MT Colorado Air & Space Port 5200 Front Range Parkway, Watkins, CO 80137
IFB Questions Due:	Tuesday October 27th, 2026, 5:00 P.M., MT
Original Bid Due Date:	Thursday November 12th, 2026, 3:00 pm MT
New Bid Due Date:	**Wednesday December 2nd, 2026, 3:00 P.M.**
Proposal will be received at:	https://www.bidnetdirect.com/colorado/adams-county
For additional information please contact:	Joe Lachermeier, Contract Specialist III 720-523-6052 jlachermeier@adcogov.org

The County shall issue a written addendum if substantial changes which impact the technical submission of Bids are required. A copy of such addenda will be available at the Bidnet System website. In the event of conflict with the original Solicitation documents, addenda shall supersede to the extent specified. Subsequent addenda shall supersede prior addenda only to the extent specified.

IFB-JL-2026.766 ADDENDUM TWO

The purpose of this Addendum is to answer questions submitted to Adams County from vendors specific to this project.

This addendum shall be a part of the Contract Documents for the above project and is hereby made effective on the date shown above. All other terms and conditions of the Contract Documents not addressed in the addendum shall remain unchanged.

The bidders shall acknowledge receipt of this addendum on the request for bid submission check list provided in the Bid Proposal. Failure to do so may subject the Bidder To disqualification.

(1)Question: Will an Engineering stamp be required for the Electrical and Base for the Street lights?

Response: Just for the two new ones.

(2)Question: Is there a height restriction due to location of the air strip?

Response: Yes, 35'

(3)Question: What is the height of the existing luminaire Poles?

Response: 35'

(4)Question: Is there a Street light standard for luminaires required on this project?

Response: Just making sure both the street and parking lots have good light coverage

(5)Question: Do we need to follow CDOT standards for LED Luminaires or does Adams County have a spec?

Response: No

(6)Question: Will lighting Arrestors be required?

Response: No, just ground from the lightening rod into the ground

(7)Question: If lighting arrestors are required, Is there a Adams co spec or CDOT spec that we must follow?

Response: No, just ground from the lightening rod into the ground

(8)Question: Do we need to replace all lighting arrestors for the poles that are getting new Luminaires?

Response: Just the ones that are missing.

(9)Question: Will any type of field testing and inspections be required for the welding on the existing steel Poles.

Response: In-house inspections only.

(10)Question: *Will there be painting of the existing poles added to the scope?*

Response: Yes

(11)Question: If painting is added, is sanding and treating the pole required, or just paint over the old

Response: Painting only.

(12)Question: Also, what color and type/spec of paint is required?

Response: Dark brown or black.

(13)Question: For Phase #2, how many new poles and bases are now being required?

Response: 2

(14)Question: What is the size of caisson required for the new poles.

Response: 24”

(15)Question: What are the heights required for the new poles.

Response: to match existing poles

(16)Question: Please confirm if photometric studies are required for the parking lot only or the roadway as well.

Response: No.

(17)Question: Do all light poles require new 10” lightning air terminals?
Can the poles be utilized as the downlead?

Response: No. There is only one missing. The new pole will need them.

(18)Question: Are there any existing civil drawings for the roadway and parking lot?

Response: No

(19)Question: Please provide a list of the specific drawings, calculations, and studies that must be prepared, signed, and sealed by a licensed engineer.

Response: Just for the new poles and caissons

(20)Question: Please confirm the need for (4) four new caisson foundations for the parking lot lighting.

Response: Just 2

(21)Question: Is material required to be BABA compliant with COC's and CTR's?

Response: No

End of Addenda No 2