Questions & Answers - 1

Solicitation	044-26 - Alarm Monitoring Services for Douglas County Facilities
Buying Organization	Douglas County Government

No	Question/Answer	Question Date
Q1	**Question: Labor Rates** "On Exhibit A (Pages 13–18), please clarify the scope of work covered under the monthly fee for install/Service for Burg' and install/Service for Panic'. Is this intended to be an all-inclusive maintenance agreement covering all repairs, parts, and labor, or will service and repairs be billed under the T&M rates on Page 19? Furthermore, what specific installation scope is expected within a recurring monthly rate?" **Answer:** Pages 13-18 of the solicitation document should only cover monitoring. Page 19 of the soliciation document covers everything else.	11/05/2026
Q2	**Question: Subcrontractors** "Page 7, Item 8 and Page 9, Item 20 state that subcontractors are strictly prohibited; however, Exhibit A (Page 19, Item 6) requests a Subcontractor Cost, Mark-Up %'. Please clarify under what circumstances subcontractors are permitted (e.g., proprietary system servicing), or confirm if subcontractors are entirely prohibited across all monitoring, maintenance, and installation services." **Answer:** The restriction on subcontractors was included in error. Subcontractors may be used when the nature of the work justifies their involvement and the County approves both the subcontractor and the proposed scope of work in writing and in advance. All subcontractor technicians must complete the required background check and authorization process before performing work on site and must display their County badge at all times while working on County property. Unauthorized technicians will not be permitted on site.	11/05/2026
Q3	**Question: Inspections** "Please confirm that the annual inspection of all systems' required on Page 9, Item 21 applies exclusively to electronic Fire Alarm, Burglar, and Panic systems, and that Fire Sprinkler, Backflow, and Portable Fire Extinguisher inspections are excluded from this contract scope." **Answer:** That is correct - the annual inspection of systems referred to on Page 9, Item 21 pertains only to inspection/testing of Burglar/Panic systems.	11/05/2026
Q4	**Question: Fire Points** "Regarding the equipment schedules on Pages 13–18, please define Fire Points'. Does this count represent addressable initiating devices only (smoke detectors, heat detectors, pull stations, duct detectors, waterflow switches), or does it also include notification appliances (horns/strobes), control modules, relays, and auxiliary power supplies?" **Answer:** The count represents smoke detectors, heat detectors, pull stations, duct detectors and waterflow switches.	11/05/2026
Q5	**Question: Security/Panic points** Regarding Pages 13–18, please define Security/Panic points'. Does this count refer strictly to active protection zones and initiating devices (panic buttons, door contacts, motion detectors), or does it include hardware peripherals such as keypads, power supplies, and zone expanders?" **Answer:** The count represents panic buttons, door contacts and motion detectors.	11/05/2026

No	Question/Answer	Question Date
Q6	**Question: Testing Reports** To ensure accurate pricing for the annual inspections required in Item 21, will the County provide copies of the most recent annual fire inspection and testing reports for all facilities listed in Exhibit A? **Answer:** Annual inspections are only for burg/panic systems.	11/05/2026
Q7	**Question: Annual inspection due dates** What are the current annual inspection due dates for each facility in Exhibit A, and does the County allow the contractor to group and inspect geographically adjacent sites concurrently? **Answer:** Inspections normally start in February and can be grouped with other sites in the area.	11/05/2026
Q8	**Question: Proprietary fire alarm panels** Exhibit A includes proprietary fire alarm panels such as Simplex 4010 and Edwards (EST) Quickstar/10 Series. Because Page 7, Item 11 requires bidders to be authorized Resideo/Honeywell dealers, Page 9, Item 19 requires factory-authorized technicians for repairs, and Page 7, Item 8 prohibits subcontractors, what is the County's required procedure when software programming, proprietary parts, or manufacturer support are required on non-Honeywell/proprietary systems? **Answer:** County will contact those proprietary vendors if work needs to be done on those panels.	11/05/2026
Q9	**Question: Replacement Batteries** Page 9, Item 21 states that all batteries being replaced annually. Does this mandate require replacing every sealed lead-acid (SLA) control panel and power supply battery every year, or does it apply only to batteries that fail load testing? Additionally, does this requirement include wireless peripheral device batteries? and if so how many? **Answer:** Battery replacement is for all wireless devices only.	11/05/2026
Q10	**Question: Alarm signal transmission** Page 5 (Assignment) and Page 7 (Item 8, Subcontractors): Please confirm that utilizing third-party telecommunication providers, cellular carriers, and network aggregators for alarm signal transmission does not violate the assignment or subcontractor restrictions **Answer:** The use of third-party telecommunication providers, cellular carriers, and network aggregators for alarm signal transmission is allowed.	11/05/2026
Q11	**Question: IMSA certification** Page 9, Item 19 lists IMSA fire alarm certification under qualified personnel examples. Please confirm that NICET Level II (or higher) fire alarm certification satisfies this requirement without needing IMSA certification. **Answer:** NICET Level II (or higher) fire alarm certification is acceptable.	11/05/2026
Q12	**Question: Repair Billing** Page 9, Item 19 states repairs are billed on a time and material basis, while Page 9, Item 22 states emergency service response shall be provided at no additional cost. Please clarify if no additional cost applies strictly to emergency trip/dispatch charges (with labor and materials billed at contract rates), or if emergency labor is expected to be included at no charge. If emergency labor is billable, where should after-hours/emergency hourly rates be entered on the Exhibit A Fee Schedule? **Answer:** Please enter your emergency hourly rates on page 20 (Exhibit A - Section 9 - Comments).	11/05/2026

No	Question/Answer	Question Date
Q13	**Question: Central Station Operators** Page 8, Item 11 states Central Station Operators must complete SIA, NBFAA, CSAA, or equivalent trade training. Please confirm that this qualification applies exclusively to live central station alarm dispatch operators, and does not apply to administrative, accounting, or service scheduling personnel who answer incoming business calls. **Answer:** Applies only to live central station alarm dispatch operators.	11/05/2026
Q14	**Question: Central station** Page 7, Items 9 & 10: Please confirm that an operating model where alarm dispatch and call handling are conducted at a UL-listed central station within 75 miles (Centennial, CO), distributed/hybrid infrastructure supported by geographically separated, fully redundant live backup monitoring stations in Utah and Idaho (exceeding the 100-mile separation requirement), fully complies with the primary and backup monitoring specifications **Answer:** This is acceptable.	11/05/2026