Financial Services
Purchasing Division
215 N. Mason St. 2nd Floor
PO Box 580
Fort Collins, CO 80522

970.221.6775
fortcollins.gov

ADDENDUM NO. 1

SPECIFICATIONS AND CONTRACT DOCUMENTS

Description of BID 10366: Transfort Overhead Door Replacements

OPENING DATE: 3:00 PM (Our Clock) on December 2, 2026

To all prospective bidders under the specifications and contract documents described above, the following changes/additions are hereby made and detailed in the following sections of this addendum:

Exhibit 1 – Questions and Answers

If you have any questions regarding this addendum, please contact Dennis Ralph, Senior Buyer, at (970) 221-6281 or dralph@fortcollins.gov.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED BY A WRITTEN STATEMENT ENCLOSED WITH THE BID STATING THAT THIS ADDENDUM HAS BEEN RECEIVED.

Exhibit 1
Questions and Answers

Q1: Hardware Note 3 (exterior wireless opener on Doors 03 and 16): Is this an exterior wireless keypad, a radio transmitter, or something else?

A1: We are using a two-channel remote control that would operate both doors

How many transmitters are required per door?

A1: Two (2) two-channel remote controls for doors 03 and 16 only. No other doors require transmitters.

Q2: Safety devices: The spec calls only for a monitored sensor edge, but during the walkthrough safety eyes were requested. Are you wanting Photo eyes or safety sensors?

A2: Photo Eyes are required

Q3: Since federal dollars apply to this project, is there an SDVOSB set-aside, or are there preference points for a Service-Disabled Veteran-Owned Small Business?

A3: There is not a SDVOSB set-aside or preference points for a SDVOSB for this project