Questions & Answers - 1

Project	2026-006 - 2026-006 Fencing
Buying Organization	Elbert County Government

No	Question/Answer	Question Date
Q1	**Question: Chain Link Gate type** I see that there is a specification for the 4' walk through single swing gates in the construction documents. I do not see a gate type or specification for the larger 12'-0" and 14'-0" gates. What type of gate are these? Will a detail drawing or spec be provided **Answer:** We would like the 12' agricultural gate on the south side of the new chainlink fence, where the barbed wire is currently located, to be a green 12' sixrail livestock gate, as shown in the attached document. For the 14' and 12' chainlink gates, we would like them to be the standard style, the same as the 4' singleswing walkthrough gates. **Attachments:** 12_ AG Gate Example.pdf	10/13/2026