Scope of Work – Kitchen Hood Inspections

1. Annual inspections and reporting to meet NFPA 96 and IFC 606.3
    a. AHJ (Authority Having Jurisdiction) reporting within two weeks of completion of inspections
    b. Inspection items
        1. Exhaust hood canopy – check for accumulation of grease build up, damage or corrosion
        2. Grease filters and filter banks – check for clogs, wear, or improper installation
        3. Ductwork (accessible sections) - inspector for grease deposits, leaks, or obstructions
        4. Exhaust fan assembly - check for motor function, loose fan belts, worn-out fan belts, and cleanliness
        5. Make-up air system – check for proper function
        6. Access panels and cleanout doors – check for proper function and any repair issues
        7. Hood lighting and electrical connections – check for cleanliness, proper operation, safety hazards
        8. Grease containment systems – check for level of fullness
        9. Welds, seams, and structural supports – check for deficiencies
        10. System integrity – inspect for broken hinges, grease leaks, or structural damage to ductwork

2. Kitchen Exhaust Cleanings
    a. Comply with NFPA 96 and IFC 606.3 requirements
    b. Annual cleanings unless inspections determine more frequent cleaning is needed
    c. Provide protection of surfaces not being cleaned such as countertops, provide method to capture water, and wrap hood
    d. Areas to be cleaned include:
        i. Kitchen Hoods

- Clean interior surfaces of hoods removing grease and grime
- Wipe and sanitize exterior surfaces of hood

ii. Exhaust fans and blowers
- Clean exhaust fans, blowers, and motor housing
- Degrease blades, housings, and motor areas
- Ensure proper lubrication of fan motors as needed

iii. Ductwork accessible from kitchen and rooftop
- Access ductwork to remove grease buildup
- Clean exhaust fans

iv. Light fixtures associated with hood system – clean as needed
v. Clean and reinstall filters
vi. Surrounding surfaces that are affected by grease accumulation – degrease and clean as needed
vii. Post service provide area mop up and cleaning

3. Exclusions:
    a. Fire suppression recharge or repairs
    b. Repairs of motors and bearings
    c. Exhaust fan preventative maintenance service

4. Documentation and Reporting:
    a. Report to customer that includes:
        i. Date of inspection
        ii. Equipment identification
        iii. Inspection findings
        iv. Photographs of deficiencies and before/after cleaning
        v. Recommended corrective actions
        vi. Inspector name and certification
        vii. Reports due to Poudre School District within two weeks of inspection

viii. Compliance reports into AHJ database (Brycer Compliance Engine) within two weeks inspection
ix. Affix inspection certification tag to each unit inspected