Questions & Answers - 1

Solicitation	26-53 - Security Electronics Maintenance & Support Services
Buying Organization	Arapahoe County

No	Question/Answer	Question Date
Q1	**Question: SLA requirements** What is your SLA requirements, and can you provide any history on how often service calls have been initiated with your current provider? on a monthly basis would be preferred. **Answer:** As stated in the RFP Section II. The required SLA is 4-hour on-site response for critical failures; 24-hour restoration of service. Provide 24/7 on-call support for critical system outages or security events. We currently have anywhere from 3 to 6 service calls per month.	11/05/2026
Q2	**Question: Equipment Included in Agreement** 1.Page 9>II. Scope of Work & Deliverables>Maintenance & Support>Preventative Maintenance: a.Please confirm/verify all CCTV(Video) PC's, servers, monitors and software are included in this scope of work. b.Please confirm/verify all Door Control PC's, servers, monitors and software are included in this scope of work. **Answer:** Yes. The preventative maintenance scope includes PCs, servers, monitors, and software for both the CCTV (video) and door control systems, please refer to Attachment B for the inventory of CCTV and door control equipment and software. Attachment B reflects an audit conducted by the County's current vendor under the existing contract and is the most accurate inventory the County has available at this time. The awarded contractor may need to conduct a new audit to verify the inventory.	11/05/2026
Q3	**Question: Corrective Maintenance** 2.Page 9>II. Scope of Work & Deliverables>Maintenance & Support>Corrective Maintenance: a.How will the contractor be notified of a critical failure that requires a billable onsite emergency visit? **Answer:** As stated in the RFP The awarded contractor must provide a phone number for 24/7 emergency support. County staff will call that number to report a critical failure and request an emergency on-site visit. As stated in Section II, the contractor must respond on-site within four hours for critical failures.	11/05/2026
Q4	**Question: Corrective Maintenance** 2.Page 9>II. Scope of Work & Deliverables>Maintenance & Support>Corrective Maintenance: b.Please clarify if emergency support and/or on-site support visits and/or restorative visits are billable. **Answer:** Please identify in your Fee Schedule whether emergency support, on-site support visits, and follow-up visits to restore service are included in your proposed maintenance contract price or billed separately. For any service proposed as a separate charge, identify the applicable rate and when it would apply.	11/05/2026

No	Question/Answer	Question Date
Q5	**Question: Corrective Maintenance** 2.Page 9>II. Scope of Work & Deliverables>Maintenance & Support>Corrective Maintenance: c.If a failure of a device or system that is NOT included as part of this contract (detention lock, gate, building power, water intrusion, existing cabling, card access) causes a system outage or failure of the supported systems, what is the expected effort, deliverables and billing arrangement to remedy this failure even though it is not part of the scope of this contract? **Answer:** The contractor is expected to respond to the outage and troubleshoot the supported systems. For a critical failure, the four-hour on-site response requirement applies even if troubleshooting later identifies a cause outside the contract scope. If the contractor identifies an out-of-scope cause, it must promptly notify the County and document the affected systems, diagnostic findings, recommended corrective action, and any steps needed to restore service. The County will coordinate repair of the out-of-scope equipment or condition. Once that issue is resolved, the contractor will verify that the supported systems and their required integrations are operating properly and document the results. Restoration services for supported systems will be billed in accordance with the awarded agreement and fee schedule. Any request for the contractor to perform out-of-scope repairs requires separate County authorization before that work begins.	11/05/2026
Q6	**Question: Vendor Coordination** 3.Page 9>II. Scope of Work & Deliverables>Advisory & Parts Replacement>Vendor Coordination a.Will Arapahoe County provide a single point of contact for all aspects of this contract, or will the awarded contractor be responsible for coordinating across the following entities: Detention Sheriff's Office staff, Courthouse Sheriff's Office staff, Detention Maintenance, Courthouse Maintenance, Administration, Arapahoe County HR, Arapahoe County IT, Arapahoe County Finance, and Arapahoe County Facilities? **Answer:** A POC list will be provided for non-emergent calls. For emergent calls, those will be received from any watch commander or IT representative. These would be identified during contract negotiations with the contracted vendor	11/05/2026
Q7	**Question: Critical Failures** 4.Page 9>II. Scope of Work & Deliverables>Advisory & Parts Replacement>Emergency Support a.What is the definition of a "critical failure" that requires 4-hour onsite response? **Answer:** Anything that affects the safety or well-being of any detainee or law-enforcement officer is considered a critical failure.	11/05/2026
Q8	**Question: Training Requirements** 5.Page 9>II. Scope of Work & Deliverables>System Support Requirements>Training a.Depending on required frequency by end users, will this training be billable, or is it to be included in the base maintenance contract pricing? **Answer:** On-site training for County staff is required under Section II. In the Fee Schedule, clearly state whether training is included in the proposed base maintenance contract price or billed separately.	11/05/2026

No	Question/Answer	Question Date
Q9	**Question: Communication Procedures** 6.Page 10>II. Scope of Work & Deliverables>Reporting & Communication>Communication a.What is the expectation or escalation procedure of the operational staff of the facilities (Detention & Justice Center) for support and escalation? (Are any and all staff authorized to call vendor directly, or do they escalate internally prior to contacting vendor?) **Answer:** A POC list will be provided for non-emergent calls. For emergent calls, those will be received from any watch commander or IT representative. These would be identified during contract negotiations with the contracted vendor.	11/05/2026
Q10	**Question: Response Time** 7.Page 10>II. Technical Requirements>Response Time a.Are the 4-hour on-site and 24-hour restoration of service hours, resources & material to be billable or included in the maintenance agreement? **Answer:** Use the Fee Schedule requirements in the RFP to provide your pricing. Ensure your proposed pricing accounts for all labor, resources, and materials needed to meet: • The four-hour on-site response requirement for critical failures. • The 24-hour service restoration requirement. Clearly identify which costs are included in the base maintenance price and list any separately billed charges in the Fee Schedule.	11/05/2026
Q11	**Question: Response Time** 7.Page 10>II. Technical Requirements>Response Time b.Regarding the response times and required resources to remedy – in the event of a critical event, does the response time begin at the time of received call, or upon approval of estimated resources to remedy? What is the typical timeframe for approval of estimated resources in an emergency situation? **Answer:** • The four-hour on-site response period begins when the contractor receives the County's call reporting a critical failure. The contractor must respond within that period while any required approval of estimated repair resources is pending. • The County has not established a standard turnaround time for approving emergency repair estimates. The County and the awarded contractor will establish the approval and escalation procedures during contract negotiations.	11/05/2026
Q12	**Question: Manufacturer Warranty** 8.Page 10>II. Technical Requirements>Warranty a.Should a piece of equipment fail that is covered by manufacturer warranty, but outside of vendor warranty, how is replacement/billing for labor and/or material to be handled? Is it billable or to be included in the maintenance contract? **Answer:** If equipment remains under the manufacturer's warranty after the contractor's warranty has expired, the contractor must coordinate with the County to process the warranty claim and obtain any covered replacement equipment or parts. Use the RFP's Fee Schedule to identify pricing for any labor or materials that the manufacturer's warranty does not cover. Clearly state which costs are included in the proposed base maintenance contract price and list the applicable rates or charges for any costs billed separately.	11/05/2026

No	Question/Answer	Question Date
Q13	**Question: Manufacturer Warranty** 8.Page 10>II. Technical Requirements>Warranty b.How is a contractor to determine what is under manufacturer warranty? **Answer:** Please refer to Attachment B. The County relies on the equipment inventory provided by its current contractor, which is based on an audit and is the most accurate list available to the County. The awarded contractor should use Attachment B as a starting point and confirm warranty coverage with the manufacturer using the equipment model and serial number, as applicable.	11/05/2026
Q14	**Question: Response Format** Page 10>IV. RESPONSE FORMAT a.Can the proposal 25-page maximum be increased or waived? For the amount of information being requested, it may be beneficial to allow for more information to be submitted. **Answer:** he 25-page maximum remains in effect. Pricing, including the Fee Schedule, does not count toward the 25-page limit. Cover pages, the table of contents, dividers, and the following required forms and documentation are also excluded: • Completed Submittal Forms • Certificate of Liability Insurance • Completed Vendor Security and Compliance Assessment (Attachment A)	11/05/2026
Q15	**Question: Fee Schedule** 10. Page 11>FEE SCHEDULE>Maintenance Contract Pricing a.Are there a set number of visits, hours, frequency desired? b.Is remote support to be included in this portion? **Answer:** **10(a).** The Fee Schedule does not specify a set number of visits, hours, or visit frequency. Proposers should base their maintenance contract pricing on the RFP's scope of work and state the number and frequency of visits and the estimated labor hours included in their price. **10(b).** The Fee Schedule does not specify how remote support must be priced. Proposers should clearly state whether remote support is included in the maintenance contract price. If included, describe the coverage and any limits. If billed separately, identify the applicable rates in the Fee Schedule.	11/05/2026
Q16	**Question: Equipment questions** do you have an equipment list that is more detailed, such as OEM, and can you confirm what is under mfg support **Answer:** Please refer to Attachment B for the equipment inventory. The County relies on the audit provided by its current contractor, and Attachment B is the most detailed and accurate inventory available to the County. The County does not have a separate OEM equipment list or confirmed manufacturer support status for individual devices. The awarded contractor may need to verify equipment details and confirm current support status with the applicable manufacturers.	11/05/2026
Q17	**Question: Attendee list** Can you can share the list of attendees that were available for the site walk **Answer:** The site walk attendee list is included in the Question and Answer Addendum.	11/05/2026

No	Question/Answer	Question Date
Q18	**Question: Existing Partner** can you divulge who the existing partner is that is supporting you currently, and what has the experience been? are you shopping this due to lack of effective support, or what areas do you feel they have gaps, and not providing the service you expect? **Answer:** KUBL Group is the County's current service provider. The existing contract is nearing the end of its term, so the County is required to issue a new solicitation. The RFP outlines the County's service and support expectations. Proposers should describe how they will meet those requirements.	11/05/2026
Q19	**Question: SLA clarity** you mention a sla of 4hrs for critical failures. please define what critical failures mean. **Answer:** Anything that affects the safety or well-being of any detainee or law-enforcement officer is considered a critical failure.	11/05/2026