FACILITIES MANAGEMENT
COLORADO STATE UNIVERSITY

DQ-2026-024-BC / 260316D / Biology Duct Insulation Damage

RFC #	Date Received	RFQ/RFP/AFB Section Reference	RFC Topic	RFC Question	RFC Response
1				Will builders risk policy be required as per 25.6?	Yes
2				Article 23 (of the sample contract) defines requirements for staging area, contractor trailer, restroom facilities etc. Given scope of work being limited to the roof confirm extent of requirements, and confirm location if necessary.	Given the limited scope of work, extensive contractor staging is not anticipated. Due to the occupied building and limited access around the building, dedicated onsite staging is not available. Limited staging may be accommodated in limited 20-minute loading zones and J service vehicle parking spaces on the East side of the building and for temporary periods approved by CSU prior to mobilization. Contractor trailers and dedicated restroom facilities are not anticipated to be necessary.
3				Article 23.6 (of the sample contract) indicates a 4'x8'sign, confirm requirement.	A project sign will not be required for this project.
4				Where will permitted construction parking be available?	Contractor parking shall be coordinated with CSU Parking and Transportation Services. Parking is not guaranteed adjacent to the building, and all applicable parking regulations and fees shall apply Refer to CSU Parking and Transportation website https://pts.colostate.edu or call them directly to confirm contractor parking requirements.
5				What are the holiday break dates for CSU campus?	CSU's Fall Recess is November 21-29. CSU's Winter Recess is December 19 - January 18. Refer to full calendar details at https://calendar.colostate.edu
6				Will the Biology Building be occupied(open)during holiday break?	The Biology Building may remain occupied and operational during the holiday breaks, with reduced occupancy anticipated. Contractor shall coordinate all work activities, access, and potential disruptions with CSU and plan around occupied buildings and campus.
7				Article 27.2 (of the sample contract) references prevailing wages, are they required for the project?	prevailinge wage does not apply to this contract
8				Will the roof be certified 'leak free' prior to start of work?	CSU will not provide a separate certification that the existing roof is leak-free. Following the initial wind damage event, CSU engaged a roofing contractor to complete repairs, and no subsequent leaks have been reported. Contractor shall document existing conditions prior to commencing work and notify CSU of any observed deficiencies or areas of concern. Contractor shall protect the existing roofing surface throughout construction and shall be responsible for any damage resulting from its operations. To maintain the existing roof warranty, roofing repairs will be managed by CSU and performed by the roofing contractor already retained on the project and any costs associated with contractor-caused damage will be the responsibility of the contractor.
9				Can the street be closed for use of a crane?	Temporary closure of Libbie Coy Way may be considered, subject to CSU approval and coordination with applicable campus departments. Transfort operates the Around the Horn bus route along this roadway; therefore, any closure or detour must be coordinated with and approved by the appropriate transit and campus authorities. Contractor shall be responsible for obtaining applicable City of Fort Collins permits and paying associated fees. Contractor shall submit the proposed crane location, lift plan, traffic control plan, and anticipated closure duration for review prior to scheduling. CSU recommends considering early morning or weekend closures, with durations limited to approximately 2–4 hours where feasible, to minimize campus impacts. No street closure is approved at this time.
10				Drawing note calls for filter change out, confirm/provide maintenance listing for required filters.	CSU Facilities Management will be responsible for any filter change out as part of their routine maintenance and will not be part of the contractors scope of work
11				Confirm location for location of 40'rolloff dumpster.	Dumpster placement shall be coordinated with and approved by CSU prior to mobilization. Placement shall not obstruct building entrances, emergency access, or pedestrian circulation. Limited 20-minute loading zones and J service vehicle parking spaces are available on the east side of the building along Libbie Coy Way. CSU may coordinate temporary use of these spaces during construction activities, provided they are restored to normal use at the end of each workday. Contractor shall verify available dimensions and access requirements. Due to space limitations, a smaller dumpster may be considered for short durations of a few days at a time; continuous placement for the full project duration is not anticipated. Refer to the photos attached to Addendum 2 showing locations outlined in red. .
12				Confirm elevator may be used for material handling.	Use of the building elevator may be permitted subject to CSU approval and coordination with building occupants. Contractor shall protect elevator flooring/wall finishes and comply with posted weight and dimensional limitations.
13				Confirm acceptable substitution of Venturecladd 1577 CW-E as alternative to scheduled Alumaguard (data sheet attached).	Submitted jacketing appears to be a lightweight product vs. the heavy duty product specified. Substitution not accepted. Bid per plans.