Questions & Answers - 1

Solicitation 039-26 - Semi-Annual Maintenance for Uninterruptible Power Supply
Buying Organization Douglas County Government

No	Question/Answer	Question Date
Q1	**Question: Level of Service** Hello! Due to the UPS models age and being obsolete, we are unable to support Full Emergency Service coverage. We are able to offer a PM only option for this IFB if this would be acceptable. Please let us know as this will determine whether we can bid. Thank you! **Answer:** Douglas County requires Full Emergency Service coverage. Most complete bids will be accepted and will meet all requirements per IFB.	10/19/2026
Q2	**Question: Questions from LD Power, Inc** Battery information: Except for the Parker Yard Crew Building, the Maintenance Locations and Bid Schedule list only "with Battery System." We cannot determine battery quantity or make/model from the UPS make and model alone. For each UPS, please provide the battery quantity (including number of strings or cabinets), battery manufacturer and model or part number, and battery install date or age. **Answer:** This information is available via make, model, and product specification sheets.	10/19/2026
Q3	**Question: Questions from LD Power, Inc** Replacement battery brand: When batteries are replaced, must they be the same brand and model as the existing batteries, or are technically equivalent batteries (same voltage, Ah rating, form factor and performance specifications) acceptable? **Answer:** Alternative brand name batteries meeting the same specificaitons are acceptable.	10/19/2026
Q4	**Question: Questions from LD Power, Inc** Technician licensing: Mandatory Information item 2 requires resumes of "licensed/certified Colorado state technicians." UPS battery technicians are not licensed or certified through the State of Colorado. Can this requirement be waived or modified to accept manufacturer training or industry certifications and documented UPS experience? **Answer:** Manufacturer training or industry certifications and documented UPS experience is acceptable.	10/19/2026
Q5	**Question: Questions from LD Power, Inc** Technician location: Mandatory Information item 2 requires technicians to be based within seventy-five (75) miles of Douglas County. Does this apply to each assigned technician, or may qualified technicians who travel to the County from outside that radius be assigned? **Answer:** This requires 3 technicians to be based within 75 miles of Douglas County. This is to ensure timely emergency response.	10/19/2026

No	Question/Answer	Question Date
Q6	**Question: Questions from LD Power, Inc** Emergency service: The IFB title and Scope of Work describe semi-annual maintenance, but the Instructions to Bidders ask for emergency response times, and the Bid Schedule asks for after-hours and weekend/holiday labor rates. Is emergency UPS service a requirement of this contract? If so, what response time does the County expect, and will emergency calls be billed at the hourly labor rates on the Bid Schedule? **Answer:** Emergency UPS service is a requirement of this contract. The County expects a technician to respond within 3 hours. Please provide your emergency response times. Labor rates are to be billed at the rates on the bid schedule.	10/19/2026
Q7	**Question: Questions from LD Power, Inc** Monthly Maintenance Cost column: The requirement is for semi-annual maintenance, but the Bid Schedule asks for a "Monthly Maintenance Cost." Please clarify what this column represents. Should bidders enter the annual cost divided by twelve, and will the County multiply it by twelve to compare bids? **Answer:** Please provide the cost for a single PM for the specific location in this column.	10/19/2026
Q8	**Question: Questions from LD Power, Inc** Billing: Does the County prefer monthly billing or billing after each semi-annual service visit? Since the work is semi-annual, we suggest invoicing once each site's service is completed. Is that acceptable? **Answer:** Billing for PM Service is once per year at the beginning of the year. Battery replacements will be as needed.	10/19/2026
Q9	**Question: Questions from LD Power, Inc** Battery Cost column: The Instructions to Bidders state that battery replacements and installations will be quoted at the time of service, but the Bid Schedule includes a "Battery Cost" column. Please clarify what should be entered in this column (for example, price for a full battery replacement of that UPS). **Answer:** This column is used for comparison of future battery costs the County can expect from your company.	10/19/2026
Q10	**Question: Questions from LD Power, Inc** Quantities on the Bid Schedule: The Scope of Work lists two EvenLite inverters for each of two models at the Parker Yard Crew Building, but the Bid Schedule shows one line for each model. Should the price shown be per unit or for both units? **Answer:** This should be per unit.	10/19/2026
Q11	**Question: Emergency Services** Do you want emergency services included in this coverage, or will they be billed if needed? **Answer:** Please include your billing rates for both normal, and after hours responses.	10/20/2026
Q12	**Question: Manufacture Dates** Can you provide the manufacture dates for each of these UPS systems? **Answer:** The scope of work is only for testing, not replacement of parts.	10/20/2026

No	Question/Answer	Question Date
Q13	**Question: Obsolete Systems** Some of the listed equipment is obsolete (end of life), and replacement parts are no longer available. For these units, will the agency accept maintenance coverage that excludes parts and labor, or is parts and labor coverage required on all equipment regardless of end-of-life status and parts availability? **Answer:** Part and labor coverage is required on all equipment.	10/20/2026
Q14	**Question: Technician Requirements and Qualifications** The IFB requires bidders to submit resumes of licensed/certified Colorado technicians with a minimum of three years of experience working with the specified UPS systems and who are based within 75 miles of Douglas County. Could the County please clarify the following: a. How many technician resumes must be submitted, or is there a minimum number of technicians required for this contract? b. What specific licenses or certifications are required for these technicians? Could the County identify the acceptable certifications or licensing credentials? c. Would the County consider extending the 75-mile radius requirement to 100 miles or more? **Answer:** Minimum of 3 technicians. Manufacturer training, industry certifications, and documented UPS experience are acceptable. No, Douglas County requires technicians within 75 miles to ensure timely emergency response.	10/21/2026
Q15	**Question: Battery Quantities and Pricing** The bid schedule includes a separate battery cost column for the listed UPS systems. However, the maintenance locations list does not specify the battery quantities for each system, except for certain equipment where battery details are provided. Could the County please provide the required battery quantities and specifications for each listed UPS system so that bidders can prepare accurate and comparable pricing? **Answer:** This information is available via make, model, and product specification sheets.	10/21/2026
Q16	**Question: Emergency Service** Is 24x7 emergency service/parts/labor billable at T&M Rates or is to be covered by the annual maintenance amount? **Answer:** 24/7 response is to be billed at T&M rates. Please provide your rate for both normal, and after hours responses.	10/22/2026
Q17	**Question: CJIS - Training** Is there a charge for the background check / CJIS training? If yes, what is that amount? **Answer:** No there is not.	10/22/2026
Q18	**Question: PM Schedule** Do you need PMs to be performed After Hours or can they be completed Normal Hour? **Answer:** All PMs can be completed during normal business hours.	10/22/2026