

Certificate of constancy of performance,

0832-CPR-F1178

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

X5200G Conventional UV/IR Flame Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

Detector Electronics Corporation

**6901 West 110th Street
Minneapolis
Minnesota
55438
USA**

and produced in the manufacturing plant(s)

Detector Electronics Corporation

**6901 West 110th Street
Minneapolis
Minnesota
55438
USA**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-10:2002 + A1:2005 - Flame detectors - Point detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 26 August 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 26 August 2016
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR-F1178

Ancillary

Q9033 Mounting Arm

Notes:

1. Meets the requirements of EN54-10: 2002 Class 1, 2 and 3 at any combination of High and Very High sensitivity settings for UV and IR sensors only.
2. Meets the requirements of EN 54-10:2002 Class 2 at any combination of Medium, High and Very High sensitivity settings for UV and IR sensors only.
3. Meets the requirements of EN 54-10:2002 Class 3 at any combination of Low, Medium, High and Very High sensitivity settings for UV and IR sensors only.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 26 August 2016
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.