

BRE Global**Notified Body No. 0832**

BRE Global Limited
 Bucknalls Lane, Garston, Watford,
 Hertfordshire, UK, WD25 9XX
 Telephone: +44 (0) 333 321 8811
 Fax: +44 (0)1923 664603
 Email: enquiries@breglobal.com
 Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F2189

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

6500F Analogue Addressable Beam Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Chubb France
Parc Saint Christophe – Bât. Magellan 1
10 Av de l'Entreprise
95862
Cergy-Pontoise Cedex
France

and produced in the manufacturing plant(s):

Pittway Tecnologica Srl
Via Caboto 19/3
34147 Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-12:2002 - Smoke detectors - Line detectors using an optical light beam
EN 54-17:2005 - Short circuit isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 06 September 2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 6 September 2017

Date of Issue: 06 September 2017

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2189**6500F Analogue Addressable Beam Detector****Ancillaries:**

RTS151-KEY	Remote Test Station
6500-LRK/BEAMLRK	Long Range Kit
6500-MMK/BEAMMMK	Multi-Mounting Kit
6500-SMK/BEAMSMK	Surface Mounting Kit

Sensitivity Settings:

Sensitivity settings 1, 2, 3, 4 & acclimate levels 1 & 2

Variants:

6500FS – With Self Test Facility

A handwritten signature in black ink, appearing to read 'P. Halligan'.

P Halligan, Certification Manager,
On behalf of BRE Global Limited

Date of First Issue: 6 September 2017

Date of Issue: 06 September 2017

Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.