



**CASS**  
Industries  
Limited

## **CERTIFICATE OF TESTING** **CI02203a4**

The following item supplied for testing

**Vimpex : Fire-Cryer<sup>®</sup>**  
**Chubb Sécurité : Sw Me**

has met the performance criteria set by;

**BS EN 55022 :1998**  
for  
**Radiated Emissions (Class B)**

**BS EN 50130-4 :1996**  
for  
**Immunity to Radiated Electromagnetic Fields**  
**Immunity to Fast Transient Bursts - DC Power Lines**  
**Immunity to Fast Transient Bursts - Signal Lines**  
**Immunity to Conducted Field - DC Power Lines**  
**Immunity to Conducted Field - Signal Lines**  
**Immunity to Voltage Surges - Signal Lines**  
**Immunity to Voltage Surges - DC Power Lines**  
**Immunity to Electrostatic Discharge**

**APPROVED BY:**

6<sup>th</sup> October 2004

**S. M. Austin**  
**Director**  
for  
**CASS Industries Limited**  
**Weybrook Road**  
**Manchester**  
**M19 2QD**