

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 2031

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Kidde GX20 Check Valves

(For full product details and conditions of use refer to appendix)

placed on the market by

Kidde Products Ltd
Station Road, High Bentham, Lancaster

and produced in the factory

Kidde Products Ltd
Station Road, High Bentham, Lancaster


is submitted by the manufacturer to a factory production control and that the notified body BRE Certification Limited has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard

EN 12094-13:2001

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 11 July 2007 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



B. W. Lywood
Certification Scheme Manager
On behalf of BRE Certification Limited

Date of issue: 11 July 2007

Issue number: 1

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

Appendix to EC-Certificate of Conformity 0832 - CPD - 2031

Conditions of Use

The Check Valves covered by this Certificate of Conformity placed upon the market by Kidde Products Ltd are identified below and must be installed and maintained in accordance with the manufacturers installation instructions reference 59812-422 Issue D:

Product Name	Description	Agents	Operating Temperature Range	Maximum Working Pressure
1-B6793-808	1" Check Valve	HFC227ea	-20°C to +50°C	34 bar
1-B6793-809	1¼" Check Valve	HFC227ea	-20°C to +50°C	34 bar
1-B6793-810	1½" Check Valve	HFC227ea	-20°C to +50°C	34 bar
1-B6793-811	2" Check Valve	HFC227ea	-20°C to +50°C	34 bar
1-B6793-812	3" Check Valve	HFC227ea	-20°C to +50°C	34 bar

B. W. Lywood
Certification Scheme Manager
On behalf of BRE Certification Limited

Date of issue: 11 July 2007

Issue number: 1