



Notified body  
under n°1116

CE  
1116

## **EC CERTIFICAT OF CONFORMITY**

**1116 – CPD – 025**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the directive 93/68/EEC CE of the Council of European Communities of 22 July 1993, it has been stated that the construction products below:

**Container valve assemblies and their actuators  
for gas fire extinguishing systems HFC 227 ea / FK 5-1-12  
valve 3" K63536-04 / valve 2" B6793-792 / valve 1.5" B6793-793  
manual actuator B6793-705  
pneumatic actuator B6793-707  
manual and pneumatic actuator B6793-706  
solenoids actuators B6793-709, B6793-859**

placed on the market by

**KIDDE PRODUCTS Ltd**  
Station Road – High Bentham  
LANCASTER LA2 7NA  
United Kingdom

and produced in the factory

**Kidde Fenwal Inc**  
400 Main Street - Ashland  
MA 01721  
United States

are submitted by the manufacturer to a factory production control (FPC) and to further testing of samples taken at the factory in accordance with a prescribes test plan.

*The approved body, **CNPP**, has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the FPC and performs the continuous surveillance, assessment and approval of the FPC.*

**This certificate attests that all provisions concerning the attestation of conformity and the performance described in Annex ZA of the standard**

**EN 12094-4 : 2004**

**were applied and that the product fulfils all prescribed requirements.**

*This certificate was first issued on 27 February 2008 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.*

Saint Marcel, le 27 Février 2008

**CNPP ASSOCIATION**  
MARIANNE BEAUVALLÉE  
Directrice CNPP Cert.  
F - 27950 SAINT-MARCEL



Organisme notifié  
sous le n°1116

CE  
1116

## **CERTIFICAT DE CONFORMITE**

**1116 – CPD – 025**

Conformément à la directive 89/106/CEE du Conseil de la Communauté Européenne du 21 décembre 1988 relative au rapprochement des dispositions législatives, réglementaires et administratives des Etats membres, concernant les produits de construction (Directive Produits de construction – DPC), modifiée par la directive 93/68/CE du 22 juillet 1993, il a été établi que le produit de construction désigné ci-dessous

**VANNES DE RESERVOIR ET LEURS DECLENCHEURS**  
**pour systèmes d'extinction gaz HFC 227 ea / FK 5-1-12**  
**K63536-04 : vanne 3'' / B6793-792 : vanne 2'' / B6793-793 : vanne 1.5''**  
**B6793-705 : déclencheur manuel**  
**B6793-707 : déclencheur pneumatique**  
**B6793-706 : déclencheur manuel et pneumatique**  
**B6793-709, B6793-859 : déclencheurs solénoïdes**

mis sur le marché par

**KIDDE PRODUCTS Ltd**  
**Station Road – High Bentham**  
**LANCASTER LA2 7NA**  
**ROYAUME UNI**

et produit dans l'unité de fabrication

**Kidde Fenwal Inc**  
**400 Main Street - Ashland**  
**MA 01721**  
**Etats Unis**

fait l'objet par le fabricant d'un contrôle de production en usine (CPU) et d'essais sur des échantillons prélevés dans l'unité de fabrication selon un plan d'essais pré-établi.

*En sa qualité d'organisme certificateur notifié, le CNPP a réalisé les essais de type initiaux pour les caractéristiques concernées du produit ainsi que l'inspection initiale de l'usine et du CPU. Il exerce la surveillance continue du CPU (évaluation et acceptation).*

**Ce certificat garantit que toutes les dispositions concernant l'attestation de conformité et les caractéristiques décrites en annexe ZA de la norme**

**EN 12094-4 : 2004**

**ont été appliquées et que le produit satisfait aux exigences requises.**

*Ce certificat, délivré initialement le 27 février 2008, demeure valide tant que les conditions fixées dans les spécifications techniques harmonisées citées en référence ou les conditions de production ou le CPU lui même n'ont pas été modifiés de façon significative.*

Saint Marcel, le 27 février 2008

**CNPP ASSOCIATION**  
**MARIANNE BEAUVILLE**  
Directrice CNPP Cert.  
F - 27950 SAINT-MARCEL