

BRE Global**Notified Body No. 0832**

BRE Global Limited
 Bucknalls Lane, Garston, Watford,
 Hertfordshire, UK, WD25 9XX
 Telephone: +44 (0) 333 321 8811
 Fax: +44 (0)1923 664603
 Email: enquiries@breglobal.com
 Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F0566

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

DB3 – Conventional Sounder Type B

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Eaton MEDC Ltd
Unit B, Sutton Parkway
Oddicroft Lane
Sutton-In-Ashfield
NG17 5FB
United Kingdom

and produced in the manufacturing plant(s):

Eaton MEDC Ltd
Unit B, Sutton Parkway
Oddicroft Lane
Sutton-In-Ashfield
NG17 5FB
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3: 2001 + A1: 2002 + A2: 2006 - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 24 June 2014 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 24 June 2014

Date of Issue: 19 July 2017

Issue number 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F0566

DB3 – Conventional Sounder Type B

Sounder Tones:

Tone 3 – Sweeping 800 / 970Hz at 1Hz
Tone 7 – Slow Whoop 500-1200Hz 3.5 seconds / 0.5sec gap.
Tone 8 – Sweep 1200-500Hz at 1Hz
Tone 15 – 554Hz for 100ms / 440Hz for 400ms
Tone 19 – Continuous at 660Hz
Tone 20 – Alt 554 / 440Hz at 1Hz



P Halligan, Certification Manager,
On behalf of BRE Global Limited

Date of First Issue: 24 June 2014

Date of Issue: 19 July 2017

Issue number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.