

Inertia Emulation Control Strategy for VSC-HVDC Transmission Systems

Jiebei Zhu, Campbell D. Booth, Grain P. Adam, Andrew J. Roscoe, and Chris G. Bright

Abstract—There is concern that the levels of inertia in power systems may decrease in the future, due to increased levels of energy being provided from renewable sources, which typically have little or no inertia. Voltage source converters (VSC) used in high voltage direct current (HVDC) transmission applications are often deliberately controlled in order to de-couple transients to prevent propagation of instability between interconnected systems. However, this can deny much needed support during transients that would otherwise be available from system inertia provided by rotating plant.

This paper proposes a novel VSC-HVDC control system termed “INEC” (INertia Emulation Control) which enables a VSC-HVDC system to provide support that emulates the inertia of a synchronous generator (SG). The energy to do so comes from the capacitance of the HVDC connection, which may be augmented by the installation of additional capacitance. This paper indicates that the proposed INEC system allows a VSC-HVDC system with a fixed capacitance to emulate a wide range of inertia constants (H) by specifying the amount of permissible DC voltage variation. The proposed INEC scheme has been demonstrated through simulations, and its performance is evaluated for transients that include faults and also changes in load.

Index Terms—Frequency response, HVDC converters, HVDC transmission control, inertia emulation, synthetic inertia, voltage source converter.

I. INTRODUCTION

THERE is now an intensive focus on renewable energy development as a solution to the world’s energy needs and to reduce carbon emissions. The 2009 European Union Renewable Energy Directive, has a target of generating over 32% total power from renewable by 2030, with a target of 100% by 2050 [1]. In order to facilitate renewable generation connection, the U.K. transmission system operators are recommending that after 2014, there should be an increase in the power in-feed loss limit (i.e., the amount of generation can be lost in a single event without causing undue system disturbances) from 1320 MW to 1800 MW. This will cater for larger capacity units and installations, without significantly affecting AC system stability [2].

Manuscript received January 25, 2012; revised May 26, 2012; accepted July 11, 2012. Date of publication October 02, 2012; date of current version April 18, 2013. This work was supported in part by the U.K. Engineering and Physical Sciences Research Council and Rolls-Royce plc. under the grant Dorothy Hodgkin Postgraduate Award. Paper no. TPWRS-00077-2012.

J. Zhu, C. D. Booth, G. P. Adam, and A. J. Roscoe are with the Institute for Energy and Environment, Department of Electronic and Electrical Engineering, University of Strathclyde, Glasgow, G1 1XW, U.K. (e-mail: zhu.jiebei@eee.strath.ac.uk; c.booth@eee.strath.ac.uk; grain.adam@eee.strath.ac.uk; andrew.roscoe@eee.strath.ac.uk).

C. G. Bright is with Rolls-Royce Strategic Research Centre, Derby, U.K. (e-mail: chris.bright@rolls-royce.com).

Color versions of one or more of the figures in this paper are available online at <http://ieeexplore.ieee.org>.

Digital Object Identifier 10.1109/TPWRS.2012.2213101

With such an increased power in-feed loss limit, if a large power plant trips, the system frequency is at greater risk of falling to an unacceptable level before frequency response control systems can mitigate the situation. Large system inertia can help stabilize frequency and give ample opportunity for control systems to act.

At present, many renewable generators are connected via power electronics, especially DC sources such as PV. Power electronics effectively decouples the generators from the system and prevents the kinetic energy in the inertia of the renewable power sources from mitigating system transients. There is evidence of a decrease in system inertia on the eastern interconnector in the United States during a period of more than 10 years [5] and this is believed to be due to the increasing connection of renewable energy sources. Inevitably, reduced inertia presents a greater risk of instability requiring mitigation such as changes to control systems, greater amounts of spinning reserve, and more frequent starting of generation installed to support the system.

In an attempt to address this issue, several inertia emulation control strategies for wind power generators have been proposed [3], [4], [6], [8]. These strategies enable wind power generators to contribute inertia during AC grid disturbances. The authors in [3] studied the dynamic contribution of doubly-fed induction generators (DFIG) to provide an inertial response. However, the authors stated that DFIG turbines may stall if excessive energy is drawn from the rotor. Reference [4] proposes a control scheme for fully rated, converter-interfaced, permanent magnet synchronous generator (PMSG) wind generators that can provide frequency support/control capability. This is achieved by controlling the inverter output power according to the rate of change in grid frequency. The disadvantage with this scheme is that the recovery of the rotor speed can be difficult after a deceleration of the machine rotor.

HVDC transmission systems are accepted as the solution for connecting distant offshore wind farms [7]. However, existing HVDC converters also decouple the kinetic energy that may be available “beyond” the terminals of the DC system. The authors in [6] propose a coordinated control strategy for wind farms connected via line-commutated-converter (LCC) HVDC links. This strategy allows such wind farms to participate in inertial response and primary frequency control. The control strategy uses the time derivative of the grid frequency to adjust the delivered power from the wind farm via the LCC-HVDC. This in turn adjusts the blade angles of the wind turbines to increase or decrease the power captured from the wind. Nevertheless, this disadvantage is considered to be similar to the problems associated with [3], [4], [8], i.e., the risk of stalling wind turbines and the consequent difficulty of recovering rotor speed.




Fig. 1. Single-line diagram of VSC-HVDC transmission system, with the conventional control system.

This paper presents an inertia emulation control (INEC) strategy that uses the energy stored in the DC link capacitors of the VSC-HVDC systems to emulate inertia. This supports the AC network during and following disturbances, with minimal impact on the systems connected beyond the terminals of the HVDC system. This can be realized by modifying the HVDC control systems. The proposed strategy is capable of emulating a wide range of inertia time constants H_{VSC} using relatively small constant capacitances connected to the DC circuit. Additionally, the proposed strategy does not rely on df/dt measurement, unlike the methods reported in [3], [4], and [6]. Therefore it will be less sensitive to any potential noise amplification caused by df/dt measurement, which in turn may cause control system instability. Moreover, the INEC acts to isolate one AC power system from the consequences of frequency disturbance on another AC power system by only using the electro-static energy in the DC link capacitors plus and the comparatively smaller capacitance of the DC circuit. Simulations using a point-to-point VSC-HVDC system connecting two AC networks have demonstrated the proposed INEC strategy. The model comprises a relatively weak power system with a DC connection to an offshore wind farm using DFIGs.

II. SYNCHRONOUS MACHINE INERTIA

In power systems, a difference between generation and demand will result in changes in system frequency which will be counteracted initially by the mechanical inertia and then by the governor action of prime movers. Reference [9] defines a fictitious “inertial center” for a large-scale power system, which has a mean angular speed $\bar{\omega}$ for all electrical machines in the system, and [9] derives the following equation:

$$\frac{d\bar{\omega}}{dt} = -\frac{\Delta P}{2\sum H}. \quad (1)$$

Equation (1) indicates that for a certain power imbalance ΔP between generation and load, the aggregate inertia $\sum H$ of a power system determines the mean change in network angular speed (i.e., acceleration or deceleration). A higher aggregate inertia reduces the rate of change in angular speed, leading to an increase in the overall stability of the power system.

III. VSC-HVDC SYSTEM AND CONTROL

Fig. 1 illustrates a point-to-point VSC-HVDC system with converter station VSC_1 regulating DC voltage and reactive power, with VSC_2 controlling active and reactive power. VSC_2 is connected to a weak offshore grid through interfacing reactors, AC side filters and a coupling transformer. The VSC-HVDC system offers a degree of control freedom by allowing independent control of active and reactive power. As shown in Fig. 1, the active power can be controlled either directly using a power set-point or indirectly by regulating the DC voltage. The reactive power is controlled either directly using a reactive power set-point, or by regulating the AC voltage magnitude at the point of common coupling (PCC). The choice of control mode depends on the nature of the specific application. However, at least one of the VSC stations must be assigned to control the DC voltage. The details of the inner current control loop and various outer controllers for VSC-HVDC, as shown in Fig. 1, are described in the following subsections.

A. Inner Current Controller

Fig. 2 shows a schematic diagram of a three-phase VSC connected to an AC grid with three-phase voltage v_{abc} at the PCC. v_{abc1} represents the three-phase voltage generated at the converter terminals. The AC-side dynamics of the converter can be expressed by the following equation:

$$v_{abc1} - v_{abc} = L \frac{di_{abc}}{dt} + Ri_{abc}. \quad (2)$$




Fig. 2. Three-phase VSC equivalent model.

In (2), i_{abc} represents the three-phase currents flowing through interfacing reactor and coupling transformer, and L and R are the equivalent combined inductance and resistance of the phase reactor and transformer.

A synchronous $d-q$ reference approach is conventionally employed to facilitate VSC-HVDC control [10], [11]. The positive-sequence three-phase voltages v_{abc} and currents i_{abc} measured at the PCC are transformed to $d-q$ components v_{dq} and i_{dq} via the Park Transformation [12]:

$$v_{dq} = v_d + jv_q = \frac{2}{3}je^{-j\omega t} \left(v_a + e^{j\frac{2}{3}\pi}v_b + e^{-j\frac{2}{3}\pi}v_c \right) \quad (3)$$

$$i_{dq} = i_d + ji_q = \frac{2}{3}je^{-j\omega t} \left(i_a + e^{j\frac{2}{3}\pi}i_b + e^{-j\frac{2}{3}\pi}i_c \right). \quad (4)$$

A phase-locked-loop (PLL) block is used to synchronize the HVDC converter to the grid voltage at the PCC and to align the voltage vector of the grid with the d -axis (when the network voltage at the PCC remains constant and balanced, $v_q = 0$). In the synchronous $d-q$ reference frame, the dynamics of the VSC station in (4) can be expressed as

$$v_{d1} = L \frac{di_d}{dt} + Ri_d - \omega Li_q + v_d \quad (5)$$

$$v_{q1} = L \frac{di_q}{dt} + Ri_q + \omega Li_d + v_q \quad (6)$$

where v_{d1} and v_{q1} are the d -axis and q -axis converter side voltage vectors.

In order to track the reference currents i_d^* and i_q^* , the inner current control uses proportional-integral (PI) controllers with feedback to regulate the current vectors i_d and i_q . Therefore, the VSC voltage vector references v_{d1}^* and v_{q1}^* for VSC are computed as follows:

$$v_{d1}^* = \left(k_p + \frac{k_i}{s} \right) (i_d^* - i_d) + Ri_d - \omega Li_q + v_d \quad (7)$$

$$v_{q1}^* = \left(k_p + \frac{k_i}{s} \right) (i_q^* - i_q) + Ri_q + \omega Li_d + v_q. \quad (8)$$

The voltage vector references v_{d1}^* and v_{q1}^* are transformed to a three-phase value v_{abc1}^* for pulse width modulation (PWM) to produce the desired converter three-phase voltage.

The active and reactive powers that the VSC-HVDC inject into the AC system are expressed in the dq -axis as

$$P_{AC} = \frac{3}{2}(v_d i_d + v_q i_q) = \frac{3}{2}v_d i_d \quad (9)$$

$$Q_{AC} = \frac{3}{2}(v_q i_d - v_d i_q) = -\frac{3}{2}v_d i_q. \quad (10)$$

In (9) and (10), the decoupled control of active and reactive powers is achieved. During steady state, active and reactive powers are proportional to i_d and i_q , respectively.

B. Outer Controllers

The outer controllers are shown at the left hand side of the cascaded control system in Fig. 1. In order to ensure stability, they must be slower-acting than the inner current control loops introduced in the previous section [10].

The active power controller produces the d -axis current reference i_d^* for the inner current controller according to the active power reference P_{AC}^* :

$$i_d^* = \frac{P_{AC}^*}{\frac{3}{2}v_d}. \quad (11)$$

In a similar way, the reactive power controller calculates the q -axis current reference i_q^* from the reactive power reference Q_{AC}^* according to

$$i_q^* = \frac{Q_{AC}^*}{\frac{3}{2}v_d}. \quad (12)$$

Assuming the VSC is lossless, the active powers of the AC and DC sides are obtained by the following:

$$i_{DC} = \frac{\frac{3}{2}v_d \cdot i_d}{V_{DC}} \quad (13)$$

where V_{DC} and i_{DC} refer to the DC side voltage and current.

The charging and discharging of the DC capacitor in Fig. 2 can be expressed using

$$C \cdot \frac{dV_{DC}}{dt} = i_{DC} - i_{load}. \quad (14)$$

The combination of (13) and (14) gives the d -axis current reference i_d^* , which represents the output of the DC voltage controller:

$$i_d^* = \frac{V_{DC}^*}{\frac{3}{2}v_d} \left(C \frac{dV_{DC}}{dt} + i_{load} \right). \quad (15)$$

For the control of the AC voltage amplitude at the PCC, the magnitude of the voltage drop across the reactor and transformer impedance $R + j\omega L$ is approximated as

$$\Delta v = |v_{abc1}| - |v_{abc}| = \frac{RP_{AC} + \omega LQ_{AC}}{v_d} \approx \frac{\omega L}{v_d} Q_{AC} \quad (16)$$

where $|v_{abc1}| = \sqrt{v_{d1}^2 + v_{q1}^2}$ and $|v_{abc}| = \sqrt{v_d^2 + v_q^2}$.

In the reactor and the transformer, $\omega L \gg R$, thus the voltage amplitude drop only depends on the reactive power flow Q_{AC} . The reactive component q -axis current i_q^* is thus calculated in the AC voltage amplitude controller, from the error between the PCC voltage amplitude set point $|v_{abc}^*|$ and the actual voltage amplitude $|v_{abc}|$.

With PI controllers, the equations of active power, reactive power, DC voltage and AC voltage controllers in the s -domain are as follows:

$$i_d^* = \frac{P_{AC}^*}{\frac{3}{2}V_d} + \left(k_p + \frac{k_i}{s} \right) (P_{AC}^* - P_{AC}) \quad (17)$$

$$i_q^* = \frac{Q_{AC}^*}{\frac{3}{2}V_d} + \left(k_p + \frac{k_i}{s}\right)(Q_{AC}^* - Q_{AC}) \quad (18)$$

$$i_d^* = \left(k_p + \frac{k_i}{s}\right)(V_{DC}^* - V_{DC}) \quad (19)$$

$$i_q^* = \left(k_p + \frac{k_i}{s}\right)(|v_{abc}^*| - |v_{abc}|). \quad (20)$$

VSC-HVDC converters do not normally possess any overload capability [10]. Severe network disturbances such as AC system faults will stress the converter switches with overcurrent. Therefore, current limitation must be included in both the outer controllers and the inner current control schemes to protect against overcurrent.

IV. VSC-HVDC INERTIA EMULATION CONTROL

The proposed INEC uses stored energy in the HVDC DC capacitors to provide an inertial response, which can not only support frequency stability but also contribute to primary frequency control of the supplied AC network. Energy for the INEC is provided solely from DC link capacitors by using the converters to control the DC link voltage. The INEC algorithm contains the following four steps:

- 1) machine inertia time constant versus capacitor time constant;
- 2) capacitor DC voltage and emulated inertia time constant;
- 3) VSC-HVDC INEC design loop;
- 4) frequency change versus DC voltage change.

A. Machine Inertia Time Constant versus Capacitor Time Constant

The inertia constant H , which determines the response of SG angular speed to any changes in input power, can be expressed by

$$H = \frac{W_K}{S_M} = \frac{\frac{1}{2}J\omega^2}{S_M} \quad (21)$$

where W_K represents kinetic energy stored in the rotating mass of the machine (MVA·sec), J refers to the moment of inertia (kg·m²) and S_M is the generator rating (MVA).

Capacitors are used in VSCs for DC voltage stability and filtering [10]. The size of the DC capacitors is characterized by a capacitor time constant τ , given in (22):

$$\tau = \frac{W_E}{S_{VSC}} = \frac{\frac{1}{2}CNV_{DC}^2}{S_{VSC}} \quad (22)$$

where W_E represents the electro-static energy stored in the capacitor, S_{VSC} represents the VSC rated power capability, C is the capacitance of a single DC capacitor and N is the total number of capacitors installed on the DC link (in the example of Fig. 1, there are two capacitors in total for the three-level neutral-point clamped VSC, therefore $N = 2$).

To some extent, the electro-static energy stored in DC capacitors is similar to the mechanical energy stored in the inertia of SGs, as both the angular speed ω of the SGs, and DC voltage V_{DC} of the VSC-HVDC capacitors are squared in (21) and (22), respectively.

B. Capacitor DC Voltage and Emulated Inertia Time Constant

The equation of the machine angular motion is given in (23):

$$\frac{2H}{f_0} \cdot \frac{df}{dt} = P_M - P_E = \Delta P_1 \text{ (pu)} \quad (23)$$

where H is the inertia time constant in sec, f_0 is the nominal frequency in Hz, P_M is the mechanical power in pu, P_E is the electrical power in pu and ΔP_1 is the kinetic power absorbed by or released from the inertia of the machine during a speed change (in pu).

In order to equate the available power of the DC capacitors to that of an electrical machine, the capacitor dynamics (in terms of DC voltage and output power) are presented in (24):

$$\frac{NCV_{DC}}{S_{VSC}} \cdot \frac{dV_{DC}}{dt} = P_{in} - P_{out} = \Delta P_2 \text{ (pu)}. \quad (24)$$

In (24), N represents the total number of capacitors (two in this case), S_{VSC} represents the VSC rated power capability in watts, P_{in} is VSC power input to the two capacitors in pu, P_{out} is the VSC power output in pu, and ΔP_2 is the dynamic electro-static power stored or released across both capacitors in pu.

Equation (24) indicates that any variation in DC voltage changes the stored energy in the capacitors. This energy is charged or discharged by varying the DC voltage according to the DC voltage controller as discussed in Section III. Due to the low resistance of the DC cables, the DC voltage difference between the rectifier and inverter is negligible. For this reason, the DC voltages at the rectifier and inverter are assumed to be the same for the purposes of this analysis.

A further task is to assign a specific emulated “inertia” constant H_{VSC} to the HVDC system. Equating the SG power variation ΔP_1 in (23) with capacitor power ΔP_2 in (24) yields

$$\frac{2H_{VSC}}{f_0} \cdot \frac{df}{dt} = \frac{NCV_{DC}}{S_{VSC}} \cdot \frac{dV_{DC}}{dt}. \quad (25)$$

Integrating both sides of (25) yields (26) below. This process cancels df/dt and dV_{DC}/dt on the two sides into (27):

$$\int \frac{2H_{VSC}}{f_0} \cdot df = \int \frac{NCV_{DC}}{S_{VSC}} \cdot dV_{DC} \quad (26)$$

$$\frac{2H_{VSC} \cdot f}{f_0} = \frac{NCV_{DC}^2}{2S_{VSC}} + K_1. \quad (27)$$

The constant K_1 is the constant of integration which is calculated according to the specified values of H_{VSC} , total combined DC capacitance NC , the nominal DC voltage V_{DC0} and the converter power rating S_{VSC} . This is shown in (28):

$$K_1 = \frac{2H_{VSC} \cdot f_0}{f_0} - \frac{NCV_{DC0}^2}{2S_{VSC}} = 2H_{VSC} - \frac{NCV_{DC0}^2}{2S_{VSC}}. \quad (28)$$

The full INEC equation can then be expressed in (29):

$$\frac{2H_{VSC} \cdot f}{f_0} = \frac{NCV_{DC}^2}{2S_{VSC}} + \left(\frac{2H_{VSC} \cdot f_0}{f_0} - \frac{NCV_{DC0}^2}{2S_{VSC}} \right). \quad (29)$$




Fig. 3. Proposed inertia emulation control system for VSC-HVDC.

Equation (29) can also be written in another format, shown in (32), that can be used to evaluate the influence of DC voltage change ΔV_{DC} on the VSC-HVDC emulated inertia time constant for a given change of network frequency Δf :

$$2H_{VSC} \cdot \frac{f - f_0}{f_0} = \frac{NC}{2S_{VSC}} (V_{DC}^2 - V_{DC0}^2) \quad (30)$$

$$2H_{VSC} \cdot \frac{\Delta f}{f_0} = \frac{NC \cdot V_{DC0}^2}{2S_{VSC}} \cdot \left[\left(\frac{\Delta V_{DC}}{V_{DC0}} + 1 \right)^2 - 1 \right] \quad (31)$$

$$H_{VSC} = \frac{\frac{1}{2} \cdot \frac{NC \cdot V_{DC0}^2}{S_{VSC}} \cdot \left[\left(\frac{\Delta V_{DC}}{V_{DC0}} + 1 \right)^2 - 1 \right]}{2 \cdot \frac{\Delta f}{f_0}} \quad (32)$$

Equation (32) implies that to emulate a specific inertia time constant H_{VSC} , the DC voltage level in VSC-HVDC link must vary according to the AC network frequency, although the variation will be nonlinear. A large value of H_{VSC} will require a correspondingly large variation in DC voltage and this must be considered in the design of the VSC-HVDC system.

C. VSC-HVDC Inertia Emulation Control Loop


As already stated, the DC voltage of the VSC-HVDC must vary according to AC network frequency. Equation (27) is transformed to (33) to facilitate DC voltage control:

$$V_{DC}^* = \sqrt{\frac{4S_{VSC}H_{VSC}}{NCf_0} \cdot f - K_2} \quad (33)$$

where $K_2 = (4S_{VSC}H_{VSC})/(NC) - V_{DC0}^2$.

Fig. 3 illustrates the design of the INEC. The DC voltage reference V_{DC}^* varies with AC network frequency f . The prevailing AC network frequency, which is estimated by the PLL, is used to compute the DC voltage reference through the gains and square root operations based on (33). Other variables, including the initial integration state factor K_2 , the VSC rated power capability S_{VSC} and specified inertia time constant H_{VSC} are all included in the INEC loops.

The DC voltage reference should be limited within upper and lower constraints, for example $\pm 15\%$ of nominal DC voltage although the exact figures would depend on insulation requirements, current ratings and PWM functionality.

Fig. 4. Three-dimensional relationship between emulated inertia, frequency, and DC voltage deviations from rated value (total DC link capacitance = 2×7.5 mF).

Unlike the proposed inertia emulation control in [3], [4], and [6], the implementation of INEC in (33) avoids the processing of frequency differential terms df/dt with the consequent risk of measurement noise threatening stability especially in response to step transients [13].

The INEC strategy has the potential for implementation in multi-terminal HVDC (MTDC) systems. In (33), N is the total number of capacitors present in the MTDC network. With the INEC strategy, the converter terminal with DC voltage controller is able to make an inertial contribution to its connected AC grid. For power systems that are coupled via HVDC links, the possibility of INEC implementation is dictated by converter control that varies the DC voltage to make the energy from the DC link capacitance available to the AC system(s). In an HVDC link connecting two AC systems, it is not recommended that both terminals of the link employ INEC, as if both are attempting to dictate the DC voltage simultaneously, there is the potential for deterioration of DC voltage stability and DC link power flow control.

D. Frequency Change versus DC Voltage Change

It is clear from the previous discussions that VSC-HVDC has the potential to emulate a wide range of inertia time constants, if its DC voltage is allowed to vary by a wide margin. A range of inertia constants from 0 s to 4 s along with the associated resultant DC voltage changes for specific frequency changes is plotted in Fig. 4. The maximum inertia time constant that can be provided will depend on the degree of permissible DC voltage variations, the value of DC link capacitors as shown in (32) and the converter's active power limit.

Equation (31) presents the relationship between the square of DC voltage variation and DC capacitance, which is inversely proportional in nature. Relatively large capacitors (e.g., 7.5 mF in this paper) are used in order to lower DC voltage variations. Large DC capacitors will obviously require DC link protection; smaller values of DC capacitance could be used, with inertial responses being provided using larger DC voltage variations—see Section V for examples of the use of different capacitor values. It is important to emphasize that the scheme reported in this paper is intended to provide an “instantaneous” inertial response, and would obviously be required to be backed up by a longer term controlled response for events involving major loss of generation/transmission capacity in the supplied AC system.

TABLE I
PARAMETERS FOR THE VSC-HVDC LINK

Item	Value
Rated VSC power S_{VSC}	300 MW
Rated VSC AC rms voltage V_{VSC}	150 kV
Nominal DC voltage V_{dc}	300 kV
Reactor inductance L	0.15 pu
Reactor resistance R	0.005 pu
DC capacitor C_{dc}	7.5 mF
Total capacitor number N	2
Switching frequency f_{sw}	1350 Hz
Rated AC rms voltage in System 1	150 kV

TABLE II
PARAMETERS FOR SYNCHRONOUS GENERATOR

Item	Value
Rated MVA S_g	200 MVA
Terminal Voltage V_g	13.8 kV
Inertia time constant	3.2 s
x_d, x_d', x_d''	1.305, 0.296, 0.252
x_q, x_q'', x_l	0.474, 0.243, 0.18
$\tau_d', \tau_d'', \tau_q'$	1.01, 0.053, 0.1
Stator resistance R_s	2.8544e-3 pu
Pole pairs p	32
Turbine permanent droop R_p	0.05
Turbine time constant T_w	2.67 s
Servo-motor time constant	0.07 s
Exciter regulator gain	300
Exciter time constant	0.001 s

DC links and controllers could also be used for this purpose, with excess energy being delivered and sourced from other AC systems and/or wind farms (if available and permissible).

V. PERFORMANCE EVALUATION

The evaluation scenario as illustrated in Fig. 5 is simulated by SimpowerSystems in Matlab. A point-to-point VSC-HVDC link comprises three-phase converters VSC₁ and VSC₂, with parameters as presented in Table I. VSC₂, which is connected to the wind farm, regulates the active and reactive power by controlling offshore grid frequency and AC voltage amplitude in System 2. VSC₁ supplies power to System 1 at B₁ which represents a relatively weak system consisting of one synchronous generator and associated loads. The fixed load $P_{L1} + Q_{L1}$ is 400 MW +100 MVar, whereas the load $P_{L2} + Q_{L2}$ can be switched in or out and is 20 MW +5 MVar. The loads in System 1 are therefore being supplied by both the synchronous generator in System 1 and by System 2 via the HVDC system.

The synchronous generator (SG) is modeled using a seventh-order model with IEEE parameters [14], [15] as shown in Table II, where the electromagnetic transients and mechanical dynamics are incorporated. To illustrate the effectiveness of the proposed INEC strategy, the simulations comprise three different situations: emulated inertia time constants $H_{VSC} = 0$ (conventional VSC-HVDC control), $H_{VSC} = 1$ s and $H_{VSC} = 3$ s, which are specified individually in the INEC design in Fig. 3.




Fig. 5. Single-line diagram of the simulated test system.

Two scenarios are considered:

- Sudden load changes using $P_{L2} + jQ_{L2}$ in System 1
- AC network side faults at busbar B₂ in System 1

A. Sudden Load Changes

Figs. 6 and 7 show the obtained results for a load increase and decrease, respectively. The switchable load at B₂ in Fig. 5 which represents 5% of the pre-transient existing load is introduced and then switched in and out to simulate changes in load.

Figs. 6 presents the response to a total load increase. It is observed in Fig. 6(a) that with an increased emulated inertia time constant (from the VSC-HVDC), the rate of change of the SG rotor speed is damped, demonstrating that the emulated inertia supplied by the VSC-HVDC improves system stability. The initial SG load angle perturbation, as illustrated in Fig. 6(b), is reduced in magnitude as greater amounts of emulated inertia are supplied. The behavior of the SG load angle also shows the stability of the test power system as it settles at a new value following the load increase. Fig. 6(c) illustrates that progressively larger values of emulated inertia result in greater variations of the DC link voltage.

Fig. 6(d) shows the active power output from the converter VSC₁ during a load increase. The specified inertia constant H_{VSC} determines the magnitude and shape of the converter's inertial response. More active power is provided by VSC₁ for higher values of H_{VSC} . This shows how the INEC can provide frequency support. From Fig. 6(d) and (e), it is clear that the VSC₁ briefly increases its active power output, until the SG increases its active power to cope with the power mismatch in System 1. Once stable conditions are restored, the converter restores its active power to the original value. Therefore, the INEC enables the VSC-HVDC system to react fast enough to support the primary frequency control. This also reduces the magnitude of the initial transient increase in output power demanded from the SG. Fig. 6(f) illustrates the network frequency at VSC₁'s PCC of B₁ and shows an increase in the emulated inertia reduces the frequency transients. This is a potentially very useful benefit of the scheme, and this may become more important if renewable energy replaces conventional generation and especially if significant renewable energy is connected via power electronics.

Figs. 7 presents the case of a sudden load reduction, which is simulated by switching out $P_{L2} + Q_{L2}$. It is evident that the INEC scheme successfully damps the rotor speed deviation as presented in Fig. 7(a). The magnitude of initial SG load angle perturbations is also significantly reduced due to the action of the INEC scheme, as shown in Fig. 7(b). The INEC acts to increase DC link voltage as shown in Fig. 7(c), with




Fig. 6. INEC response for 5% load increase: (a) SG rotor speed; (b) SG load angle; (c) HVDC DC link voltage; (d) VSC1 active power; (e) SG active power; (f) Network frequency.




Fig. 7. INEC response for 5% load increase: (a) SG rotor speed; (b) SG load angle; (c) HVDC DC link voltage; (d) VSC1 active power; (e) SG active power; (f) Network frequency.

the capacitors absorbing the excess energy. This results in an instant decrease of the active power output from VSC₁ as shown in Fig. 7(d), with the response of the SG shown in Fig. 7(e). Fig. 7(f) shows that increasing the value of H_{VSC} reduces the AC network frequency transients. In all cases, the DC link voltage is maintained within 5% (15 kV) of the nominal voltage level of 300 kV. Increasing the permissible limits on DC voltage (and possibly capacitor ratings) could offer higher emulated inertia.

Fig. 8 shows the active power inputs by VSC₂ from the Power System 2 for both cases of the load increase and decrease remain unchanged. It is clear that offshore VSC₂ active power input is not affected by the VSC₁ active power output variations and the DC capacitor voltage variations. Therefore, the INEC still provides the attractive HVDC attribute of decoupling Systems 1 and 2, avoiding transients in one system propagating through to another system(s). This feature will become more important because of the continuing trend for AC power systems




Fig. 8. VSC₂ active power injected by the offshore wind farm.




Fig. 9. Comparison of different capacitance for the INEC: (a) SG rotor speed; (b) SG load angle; (c) HVDC DC link voltage; (d) VSC₁ active power; (e) SG active power; (f) Network frequency.

to interconnect via HVDC especially if sub-sea interconnection is used.

In order to illustrate the impact of DC link capacitor sizing on the INEC performance, difference capacitances for DC capacitors, namely, $C = 7.5$ mF (for the base case), 4 mF and 2 mF are used to synthesize the same inertia time constant $H_{VSC} = 1$ s for the case of 5% load increase, as seen in Fig. 9. These results have shown no differences in the system response for different values of DC link capacitances as evident from SG rotor speed behavior in Fig. 9(a), SG load angle in Fig. 9(b), VSC₁ active power output in Fig. 9(d), SG active power in Fig. 9(e), and network frequency in Fig. 9(f). However, it is noticeable that this performance is achieved at the expense of increased DC link voltage variation of the converter VSC₁ as the DC link capacitance reduces. These results indicate that to ensure proper system operation when INEC is implemented in one or more terminals, the DC link capacitance must be sized taken into account the maximum permissible DC link voltage variation from the rated voltage.

B. AC Faults

Figs. 10 and 11 compare the INEC performance for electrical close and remote faults. In both cases, three-phase faults are initiated at $t = 1$ s and cleared at $t = 1.14$ s.

As shown in the zoomed Fig. 10(a) the fault results in a AC voltage amplitude drop of 75% at busbar B₂. Generator rotor speed, with emulated inertia $H_{VSC} = 3$ s, recovers more slowly than for cases with lower values of H_{VSC} from the speed increase due to the fault, with relatively lower first and subsequent swing magnitudes, as observed in Fig. 10(b). This actually exhibits the electro-mechanical effect of system inertia. Fig. 10(c) illustrates the load angle of SG for different values of emulated inertia in the post-fault period. Fig. 10(e) presents the VSC₁ active power output with and without INEC, which influences behavior throughout each of the three simulation cases. This is directly reflected in Fig. 10(f), where the SG active power output with larger inertia $H_{VSC} = 3$ s changes less than for cases where $H_{VSC} = 1$ s and without INEC. During the fault the VSC₁'s current is saturated due to the significant undervoltage therefore the active powers for $H_{VSC} = 3$ s, 1 s and 0 remain the same during this time. It is interesting to see post the fault VSC₁'s active power with larger inertia $H_{VSC} = 3$ s holds the active power on when the fault is cleared. This can be interpreted by the equal area criterion for SG that the kinetic energy collected by the SG during the fault must be released after the fault, and the reduction on VSC₁'s active power actually facilitates this process. This is important with respect to the first swing stability of a power system. The network frequency at B₂ is shown in Fig. 10(g), which obviously has a similar trend to SG rotor speed.

The effectiveness of INEC strategy in enhancing system stability for distant faults is more obvious, as shown in Fig. 11. The distant fault is represented by a resistive fault applied at B₂ leading to a voltage drop of 25% as shown in zoomed Fig. 11(a). VSC₁'s current output is not saturated due to the relatively smaller voltage drop. It is clear, in the circled region of Fig. 11(e), that during the fault (from $t = 1$ s to 1.14 s) VSC₁ effectively interacts with the network with different active power outputs for different emulated inertia time constants. This leads to different SG load angle and




Fig. 10. INEC response for 140-ms three-phase-to-ground close fault: (a) zoomed AC voltage amplitude at B₂; (b) SG rotor speed; (c) zoomed SG load angle; (d) HVDC DC link voltage; (e) zoomed VSC₁ active power; (f) zoomed SG active power; (g) Network frequency.




Fig. 11. INEC response for 140-ms three-phase-to-ground distant fault: (a) zoomed AC voltage amplitude at B₂; (b) SG rotor speed; (c) zoomed SG load angle; (d) HVDC DC link voltage; (e) zoomed VSC₁ active power; (f) zoomed SG active power; (g) Network frequency.

active power output behaviors as shown in Fig. 11(c) and (f). As illustrated in Fig. 11(b) and (g), respectively, the SG rotor

speed and network frequency drops associated with larger emulated inertia $H_{VSC} = 3$ s are significantly less than for

$H_{VSC} = 1s$. As observed in Fig. 11(d), DC voltage drop for larger values of emulated inertia is higher in order to supply relatively higher values of instantaneous active power as shown in Fig. 11(e). It is interesting to see that the network voltage at B_2 as shown in Fig. 11(a) is also influenced by different values of emulated inertia due to the interactions between VSC_1 and the SG.

The AC fault simulation study clearly shows the INEC strategy for VSC-HVDC systems in increasing system fault ride-through capability.

VI. CONCLUSION

This paper has proposed and evaluated an INEC system for VSC-HVDC transmission systems. INEC employs the electro-static energy stored in the DC capacitors to enable the inverter to provide an inertial response to load and frequency changes in the power system, in a similar fashion to a synchronous generator. The INEC varies the DC voltage to exercise the capacitor energy and the amount of energy exercised varies with the magnitude of the inertia time constants being emulated. INEC possesses the following significant features: 1) Inertia time constants H_{VSC} can be specified and varied; 2) DC voltage variations are limited within a specific range; 3) The INEC provided at the inverter terminals of the HVDC links has no impact on the rectifier-side offshore wind power system. Simulations verify that the INEC for VSC-HVDC transmission system is capable of interacting with connected generators, counteracting, and damping generator rotor speed (and system frequency) changes. It allows the VSC-HVDC system to contribute to both the damping of low-frequency oscillations, enhancement of the primary frequency control of the AC networks and consolidation of system fault ride-through capability. In the future, this is likely to become more important due to the continuing trend of HVDC interconnection and also the possible replacement of conventional generation by renewable generation with lower inertia constants.

REFERENCES

- [1] EU Energy Policy to 2050, European Wind Energy Association. [Online]. Available: http://www.ewea.org/fileadmin/ewea_documents/documents/publications/reports/EWEA_EU_Energy_Policy_to_2050.pdf.
- [2] "Largest power infed loss amendment to GSR007 proposals," GB National Electricity Transmission System Security and Quality of Supply Standard, Aug. 2011, [Online]. Available: <http://www.national-grid.com/NR/rdonlyres/749C9FD8-1651-4059-8219-564940C4678C/44473/ReporttoAuthorityfinal.pdf>.
- [3] M. Kayikci and J. V. Milanovic, "Dynamic contribution of DFIG-based wind plants to system frequency disturbances," *IEEE Trans. Power Syst.*, vol. 24, no. 2, pp. 859–867, May 2009.
- [4] J. F. Conroy and R. Watson, "Frequency response capability of full converter wind turbine generators in comparison to conventional generation," *IEEE Trans. Power Syst.*, vol. 23, no. 2, pp. 649–656, May 2008.
- [5] J. W. Ingleson and E. Allen, "Tracking the eastern interconnection frequency governing characteristic," in *Proc. 2010 IEEE Power and Energy Society General Meeting*, Jul. 25–29, 2010, pp. 1–6.
- [6] M. Zhixin, F. Lingling, D. Osborn, and S. Yuvarajan, "Wind farms with HVdc delivery in inertial response and primary frequency control," *IEEE Trans. Energy Convers.*, vol. 25, no. 4, pp. 1171–1178, Dec. 2010.
- [7] P. Bresesti, W. L. Kling, R. L. Hendriks, and R. Vailati, "HVDC connection of offshore wind farms to the transmission system," *IEEE Trans. Energy Convers.*, vol. 22, no. 1, pp. 37–43, Mar. 2007.
- [8] K. Clark, N. W. Miller, and J. J. Sanchez-Gasca, 2009, "Modeling of GE wind turbine-generators for grid studies," Aug. 2011. [Online]. Available: <http://www.pes-psrc.org/c/C17/GE%20WTG%20Modeling-v4%202.pdf>.
- [9] P. Anderson and A. A. Fouad, *Power System Control and Stability*. Ames, IA: Iowa State Univ. Press, 1977.
- [10] C. Du, "VSC-HVDC for industrial power systems," Ph.D. dissertation, Dept. Energy and Environ., Chalmers Univ. Technol., Göteborg, Sweden, 2007.
- [11] J. Zhu and C. Booth, "Future multi-terminal HVDC transmission systems using voltage source converters," in *Proc. Int. Univ. Power Eng. Conf.*, Cardiff, U.K., Sep. 2010, pp. 1–6.
- [12] MathWorks MATLAB Simulink SimPowerSystems blockset, May 2011. [Online]. Available: <http://www.mathworks.com/>.
- [13] S. Bennett, "Development of the PID controller," *IEEE Trans. Control Syst.*, vol. 13, no. 6, pp. 58–62, Dec. 1993, 64–5.
- [14] MathWorks, Hydraulic Turbine and Governor, Aug. 2011, [Online]. Available: <http://www.mathworks.com/>.
- [15] IEEE Working Group on Prime Mover and Energy Supply Models for System Dynamic Performance Studies, "Hydraulic turbine and turbine control models for dynamic studies," *IEEE Trans. Power Syst.*, vol. 7, no. 1, pp. 167–179, Feb. 1992.



Jiebei Zhu received the B.S. degree in microelectronics from Nankai University, Tianjin, China, and the M.Sc. degree in electronic and electrical engineering from the University of Strathclyde, Glasgow, U.K., in 2008 and 2009, respectively. He is pursuing the Ph.D. degree in the Institute of Energy and Environment at the University of Strathclyde.

His research interests involve VSC-HVDC transmission technologies, synthetic inertia contribution by voltage source converters, control of multi-terminal DC networks, converter hardware-in-the-loop for microgrid applications, and power system stability and control.



Campbell D. Booth received the B.Eng. and Ph.D. degrees in electronic and electrical engineering from the University of Strathclyde, Glasgow, U.K., in 1991 and 1996, respectively.

He is currently a Senior Lecturer with the Institute for Energy and Environment, University of Strathclyde. His research interests include power system protection; plant condition monitoring and intelligent asset management; applications of intelligent system techniques to power system monitoring, protection, and control; knowledge management; and decision support systems.



Grain P. Adam received the Ph.D. degree in power electronics from the University of Strathclyde, Glasgow, U.K., in 2007.

He is a research fellow with the Institute of Energy and Environment, University of Strathclyde. His research interests are fault tolerant voltage source multilevel converters for HVDC systems, control of HVDC transmission systems and multi-terminal HVDC networks, voltage source converter based FACTS devices, and grid integration issues of renewable energies. He has authored and co-authored

several technical reports, and journal and conference papers in the area of multilevel converters and HVDC systems, and grid integration of renewable power.

Dr. Adam has contributed in the reviewing process for several IEEE and IET transactions, journals, and conferences.



Andrew J. Roscoe received the B.A. and M.A. degrees in electrical and information sciences at Pembroke College, Cambridge, U.K., in 1991 and 1994, respectively; the M.Sc. degree in the field of “Energy systems and the Environment” from the University of Strathclyde, Glasgow, U.K., in 2004; and the Ph.D. degree in 2009 for developing new power system measurement and microgrid control algorithms.

He worked for GEC Marconi from 1991 to 1995, where he was involved in antenna design and calibration, specializing in millimeter wave systems and solid-state phased-array radars. He worked from 1995 to 2003 with Hewlett Packard and subsequently Agilent Technologies, in the field of microwave communication systems, specializing in the design of test and measurement systems for personal mobile and satellite communications. He is currently a lecturer in Smart Grid Integration at the University of Strathclyde, working on micro-grid management, power system measurements, marine power systems, laboratory demonstration with power-hardware-in-the loop capability, connection of off-shore renewable generation, and inverter control within microgrids.



Chris G. Bright received the B.Sc. degree in electrical engineering in 1980 and the M.Phil. degree in induction motor control in 1987, both from the University of Southampton, Southampton, U.K.

He worked for 22 years in the U.K. electricity supply industry before joining the Electrical Systems and Instrumentation Group, Rolls-Royce Strategic Research Centre, Derby, U.K., where he has worked as an Electrical Systems Specialist for seven years.