

BEACON AI Energy Optimization Report

Generated automatically using EnergyPlus, Python and Ollama.

Metric	Baseline	Optimized
Outdoor Temp (°C)	25.58	25.58
Building Electricity (J)	257,872,140,000	257,872,140,000
Facility Electricity (J)	377,653,423,040	364,161,184,779
Cooling Setpoint	-	25.0 °C
Energy Savings	-	3.57%

Estimated Facility Energy Savings: 3.57%

The AI analyzed simulation outputs, selected an optimized cooling setpoint, modified the EnergyPlus model automatically, reran the simulation, and evaluated the resulting energy performance.