

www.hilti.com

Company:		Page:	1
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

Specifier's comments:

1 Anchor Design

1.1 Input data

Anchor type and diameter:	HIT-HY 200 V3 + HAS-V-36 (ASTM F1554 Gr.36) 1/2	
Item number:	2198021 HAS-V-36 1/2"x4-1/2" (element) / 2334276 HIT-HY 200-R V3 (adhesive)	
Specification text:	HILTI Ø 1/2 IN HIT-HY 200 V3 + HAS-V-36 (ASTM F1554 GR.36) WITH 2.75 IN NOMINAL EMBEDMENT DEPTH PER ICC-ES ESR-4868 , HAMMER DRILL BIT INSTALLATION PER MPII	
Effective embedment depth:	$h_{ef,opti} = 2.750 \text{ in.}$ ($h_{ef,limit} = 10.000 \text{ in.}$)	
Material:	ASTM F1554 Grade 36	
Evaluation Service Report:	ESR-4868	
Issued Valid:	11/1/2024 11/1/2026	
Proof:	Design Method ACI 318-19 / Chem	
Shear edge breakout verification:	Row closest to edge (Case 3 only from ACI 318-19 Fig. R.17.7.2.1b)	
Stand-off installation:	$e_b = 0.000 \text{ in.}$ (no stand-off); $t = 0.500 \text{ in.}$	
Anchor plate ^{CBFEM} :	$l_x \times l_y \times t = 12.564 \text{ in.} \times 12.000 \text{ in.} \times 0.500 \text{ in.};$	
Profile:	Rectangular HSS (AISC), HSS8X2X.125; (L x W x T) = 8.000 in. x 2.000 in. x 0.125 in.	
Base material:	cracked concrete, 2500, $f'_c = 2,500 \text{ psi}$; $h = 420.000 \text{ in.}$, Temp. short/long: 32/32 °F	
Installation:	Hammer drilled hole, Installation condition: Dry	
Reinforcement:	tension: not present, shear: not present; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar	

^{CBFEM} - The anchor calculation is based on a component-based Finite Element Method (CBFEM)


Geometry [in.] & Loading [kip, ft.kip]



Design loads



Sustained loads



www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Concrete - May 23, 2026

Page:

Specifier:

E-Mail:

Date:

3

5/24/2026

1.1.1 Design results


Case	Description	Forces [kip] / Moments [ft.kip]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 0.000; $V_x = 0.000$; $V_y = 0.000$; $M_x = 0.00000$; $M_y = 10.00000$; $M_z = 0.00000$;	no	389

1.2 Load case/Resulting anchor forces

Anchor reactions [kip]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	9.646	0.038	-0.002	0.038
2	0.000	0.003	0.002	-0.002
3	9.647	0.038	-0.002	-0.038
4	0.000	0.003	0.002	0.002



Resulting tension force in (x/y)=(-4.000/0.000): 19.293 [kip]

Resulting compression force in (x/y)=(0.971/0.001): 20.614 [kip]

Anchor forces are calculated based on a component-based Finite Element Method (CBFEM)

1.3 Tension load

	Load N_{ua} [kip]	Capacity ϕN_n [kip]	Utilization $\beta_N = N_{ua}/\phi N_n$	Status
Steel Strength*	9.647	6.172	157	not recommended
Bond Strength**	19.293	4.990	387	not recommended
Sustained Tension Load Bond Strength*	N/A	N/A	N/A	N/A
Concrete Breakout Failure**	19.293	4.963	389	not recommended

* highest loaded anchor **anchor group (anchors in tension)



www.hilti.com

Company:		Page:	4
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

1.3.1 Steel Strength

N_{sa} = ESR value refer to ICC-ES ESR-4868
 $\phi N_{sa} \geq N_{ua}$ ACI 318-19 Table 17.5.2

Variables

$A_{se,N}$ [in. ²]	f_{uta} [psi]
0.14	58,000

Calculations

N_{sa} [kip]
8.230

Results

N_{sa} [kip]	ϕ_{steel}	ϕN_{sa} [kip]	N_{ua} [kip]
8.230	0.750	6.172	9.647

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Concrete - May 23, 2026

Page:

Specifier:

E-Mail:

Date:

5

5/24/2026

1.3.2 Bond Strength

$$N_{ag} = \left(\frac{A_{Na}}{A_{Na0}} \right) \psi_{ec1,Na} \psi_{ec2,Na} \psi_{ed,Na} \psi_{cp,Na} N_{ba} \quad \text{ACI 318-19 Eq. (17.6.5.1b)}$$

$$\phi N_{ag} \geq N_{ua} \quad \text{ACI 318-19 Table 17.5.2}$$

$$A_{Na} \text{ see ACI 318-19, Section 17.6.5.1, Fig. R 17.6.5.1(b)}$$

$$A_{Na0} = (2 c_{Na})^2 \quad \text{ACI 318-19 Eq. (17.6.5.1.2a)}$$

$$c_{Na} = 10 d_a \sqrt{\frac{\tau_{uncr}}{1100}} \quad \text{ACI 318-19 Eq. (17.6.5.1.2b)}$$

$$\psi_{ec,Na} = \left(\frac{1}{1 + \frac{e_N}{c_{Na}}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.5.3.1)}$$

$$\psi_{ed,Na} = 0.7 + 0.3 \left(\frac{c_{a,min}}{c_{Na}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.5.4.1b)}$$

$$\psi_{cp,Na} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{c_{Na}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.5.5.1b)}$$

$$N_{ba} = \lambda_a \cdot \tau_{k,c} \cdot \pi \cdot d_a \cdot h_{ef} \quad \text{ACI 318-19 Eq. (17.6.5.2.1)}$$

Variables

$\tau_{k,c,uncr}$ [psi]	d_a [in.]	h_{ef} [in.]	$c_{a,min}$ [in.]	$\alpha_{overhead}$	$\tau_{k,c}$ [psi]
2,220	0.500	2.750	∞	1.000	1,135
$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	c_{ac} [in.]	λ_a		
0.000	0.000	3.988	1.000		

Calculations

c_{Na} [in.]	A_{Na} [in. ²]	A_{Na0} [in. ²]	$\psi_{ed,Na}$
7.071	313.14	200.00	1.000
$\psi_{ec1,Na}$	$\psi_{ec2,Na}$	$\psi_{cp,Na}$	N_{ba} [kip]
1.000	1.000	1.000	4.903

Results

N_{ag} [kip]	ϕ_{bond}	ϕN_{ag} [kip]	N_{ua} [kip]
7.676	0.650	4.990	19.293

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Concrete - May 23, 2026

Page:

Specifier:

E-Mail:

Date:

6

5/24/2026

1.3.3 Concrete Breakout Failure

$$N_{cbg} = \left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \quad \text{ACI 318-19 Eq. (17.6.2.1b)}$$

$$\phi N_{cbg} \geq N_{ua} \quad \text{ACI 318-19 Table 17.5.2}$$

$$A_{Nc} \text{ see ACI 318-19, Section 17.6.2.1, Fig. R 17.6.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-19 Eq. (17.6.2.1.4)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.2.3.1)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.2.4.1b)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.2.6.1b)}$$

$$N_b = k_c \lambda_a \sqrt{f_c} h_{ef}^{1.5} \quad \text{ACI 318-19 Eq. (17.6.2.2.1)}$$

Variables

h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]	$\psi_{c,N}$
2.750	0.000	0.000	∞	1.000
c_{ac} [in.]	k_c	λ_a	f_c [psi]	
3.988	17	1.000	2,500	

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [kip]
134.06	68.06	1.000	1.000	1.000	1.000	3.876

Results

N_{cbg} [kip]	$\phi_{concrete}$	ϕN_{cbg} [kip]	N_{ua} [kip]
7.635	0.650	4.963	19.293



Hilti PROFIS Engineering 3.1.31

www.hilti.com

Company:		Page:	7
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

1.4 Shear load

	Load V_{ua} [kip]	Capacity ϕV_n [kip]	Utilization $\beta_v = V_{ua} / \phi V_n$	Status
Steel Strength*	0.038	3.211	2	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength (Bond Strength controls)*	0.038	4.207	1	OK
Concrete edge failure in direction **	N/A	N/A	N/A	N/A

* highest loaded anchor ** anchor group (relevant anchors)

1.4.1 Steel Strength

V_{sa} = ESR value refer to ICC-ES ESR-4868
 $\phi V_{steel} \geq V_{ua}$ ACI 318-19 Table 17.5.2

Variables

$A_{se,V}$ [in. ²]	f_{uta} [psi]
0.14	58,000

Calculations

V_{sa} [kip]
4.940

Results

V_{sa} [kip]	ϕ_{steel}	ϕV_{sa} [kip]	V_{ua} [kip]
4.940	0.650	3.211	0.038

www.hilti.com

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Concrete - May 23, 2026

Page:

Specifier:

E-Mail:

Date:

8

5/24/2026

1.4.2 Pryout Strength (Bond Strength controls)

$$V_{cp} = k_{cp} \left[\left(\frac{A_{Na}}{A_{Na0}} \right) \psi_{ed,Na} \psi_{cp,Na} N_{ba} \right] \quad \text{ACI 318-19 Eq. (17.7.3.1a)}$$

$$\phi V_{cp} \geq V_{ua} \quad \text{ACI 318-19 Table 17.5.2}$$

$$A_{Na} \text{ see ACI 318-19, Section 17.6.5.1, Fig. R 17.6.5.1(b)}$$

$$A_{Na0} = (2 c_{Na})^2 \quad \text{ACI 318-19 Eq. (17.6.5.1.2a)}$$

$$c_{Na} = 10 d_a \sqrt{\frac{\tau_{uncr}}{1100}} \quad \text{ACI 318-19 Eq. (17.6.5.1.2b)}$$

$$\psi_{ec,Na} = \left(\frac{1}{1 + \frac{e_N}{c_{Na}}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.5.3.1)}$$

$$\psi_{ed,Na} = 0.7 + 0.3 \left(\frac{c_{a,min}}{c_{Na}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.5.4.1b)}$$

$$\psi_{cp,Na} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{c_{Na}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-19 Eq. (17.6.5.5.1b)}$$

$$N_{ba} = \lambda_a \cdot \tau_{k,c} \cdot \pi \cdot d_a \cdot h_{ef} \quad \text{ACI 318-19 Eq. (17.6.5.2.1)}$$

Variables

k_{cp}	$\alpha_{overhead}$	$\tau_{k,c,uncr}$ [psi]	d_a [in.]	h_{ef} [in.]	$c_{a,min}$ [in.]	$\tau_{k,c}$ [psi]
2	1.000	2,220	0.500	2.750	∞	1,135
$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	c_{ac} [in.]	λ_a			
0.000	0.000	3.988	1.000			

Calculations

c_{Na} [in.]	A_{Na} [in. ²]	A_{Na0} [in. ²]	$\psi_{ed,Na}$
7.071	122.57	200.00	1.000
$\psi_{ec1,Na}$	$\psi_{ec2,Na}$	$\psi_{cp,Na}$	N_{ba} [kip]
1.000	1.000	1.000	4.903

Results

V_{cp} [kip]	$\phi_{concrete}$	ϕV_{cp} [kip]	V_{ua} [kip]
6.009	0.700	4.207	0.038

1.5 Combined tension and shear loads, per ACI 318-19 section 17.8

β_N	β_V	ζ	Utilization β_{NV} [%]	Status
3.888	0.012	1.000	325	not recommended

$$\beta_{NV} = (\beta_N + \beta_V) / 1.2 \leq 1$$



Hilti PROFIS Engineering 3.1.31

www.hilti.com

Company:		Page:	9
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

1.6 Warnings

- The anchor design methods in PROFIS Engineering require rigid anchor plates per current regulations (EN1992-4, ACI318, IS1946, AS 5216:2021, ETAG 001/Annex C, EOTA TR029 etc.). This means load re-distribution on the anchors due to elastic deformations of the anchor plate are not considered - the anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the design loading. PROFIS Engineering calculates the minimum required anchor plate thickness with CBFEM to limit the stress of the anchor plate based on the assumptions explained above. The proof if the rigid base plate assumption is valid is not carried out by PROFIS Engineering. Input data and results must be checked for agreement with the existing conditions and for plausibility!
- The equations presented in this report are based on imperial units. When inputs are displayed in metric units, the user should be aware that the equations remain in their imperial format.
- Condition A applies where the potential concrete failure surfaces are crossed by supplementary reinforcement proportioned to tie the potential concrete failure prism into the structural member. Condition B applies where such supplementary reinforcement is not provided, or where pullout or pryout strength governs.
- Design Strengths of adhesive anchor systems are influenced by the cleaning method. Refer to the INSTRUCTIONS FOR USE given in the Evaluation Service Report for cleaning and installation instructions.
- For additional information about ACI 318 strength design provisions, please go to <https://viewer.joomag.com/profis-design-guide-us-en-summer-2021/0841849001625154758?short&/>
- Installation of Hilti adhesive anchor systems shall be performed by personnel trained to install Hilti adhesive anchors. Reference ACI 318-19, Section 26.7.
- The anchor design methods in PROFIS Engineering require rigid anchor plates per current regulations (EN1992-4, AS5216, etc.). This means load re-distribution on the anchors due to elastic deformations of the anchor plate are not considered - the anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the design loading. PROFIS Engineering calculates the minimum required anchor plate thickness with FEM to limit the stress of the anchor plate based on the assumptions explained above. The proof if the rigid anchor plate assumption is valid is not carried out by PROFIS Engineering. Input data and results must be checked for agreement with the existing conditions and for plausibility!

www.hilti.com

Company:		Page:	10
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

1.7 Installation data

Profile: Rectangular HSS (AISC), HSS8X2X.125; (L x W x T) = 8.000 in. x 2.000 in. x 0.125 in.

Hole diameter in the fixture: $d_f = 0.562$ in.

Plate thickness (input): 0.500 in.

Drilling method: Hammer drilled

Cleaning: Compressed air cleaning of the drilled hole according to instructions for use is required

Anchor type and diameter: HIT-HY 200 V3 + HAS-V-36 (ASTM F1554 Gr.36) 1/2

Item number: 2198021 HAS-V-36 1/2"x4-1/2" (element) / 2334276 HIT-HY 200-R V3 (adhesive)

Maximum installation torque: 0.03000 ft.kip

Hole diameter in the base material: 0.562 in.


Hole depth in the base material: 2.750 in.

Minimum thickness of the base material: 4.000 in.

Hilti $\varnothing$ 1/2 in HIT-HY 200 V3 + HAS-V-36 (ASTM F1554 Gr.36) with 2.75 in nominal embedment depth per ICC-ES ESR-4868 , Hammer drill bit installation per MPII

1.7.1 Recommended accessories

Drilling	Cleaning	Setting
• Suitable Rotary Hammer • Properly sized drill bit	• Compressed air with required accessories to blow from the bottom of the hole • Proper diameter wire brush	• Dispenser including cassette and mixer • Torque wrench



Coordinates Anchor [in.]

Anchor	x	y	c _{-x}	c _{+x}	c _{-y}	c _{+y}
1	-4.000	-4.000	-	-	-	-
2	4.000	-4.000	-	-	-	-
3	-4.000	4.000	-	-	-	-
4	4.000	4.000	-	-	-	-



www.hilti.com

Company:		Page:	11
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

2 Anchor plate design

2.1 Input data

Anchor plate:	Shape: Rectangular $I_x \times I_y \times t = 12.564 \text{ in} \times 12.000 \text{ in} \times 0.500 \text{ in}$ Calculation: CBFEM Material: ASTM A36; $F_y = 36,000 \text{ psi}$; $\epsilon_{lim} = 5.00\%$
Anchor type and size:	HIT-HY 200 V3 + HAS-V-36 (ASTM F1554 Gr.36) 1/2, $h_{ef} = 2.750 \text{ in}$
Anchor stiffness:	The anchor is modeled considering stiffness values determined from load displacement curves tested in an independent laboratory. Please note that no simple replacement of the anchor is possible as the anchor stiffness has a major impact on the load distribution results.
Design method:	AISC and LRFD-based design using component-based FEM
Stand-off installation:	$e_b = 0.000 \text{ in}$ (No stand-off); $t = 0.500 \text{ in}$
Profile:	HSS8X2X.125; $(L \times W \times T \times FT) = 8.000 \text{ in} \times 2.000 \text{ in} \times 0.125 \text{ in} \times -$ Material: ASTM A500 Gr.B Rect; $F_y = 46,000 \text{ psi}$; $\epsilon_{lim} = 5.00\%$ Eccentricity x: 0.000 in Eccentricity y: 0.000 in
Base material:	Cracked concrete; 2500; $f_{c,cyl} = 2,500 \text{ psi}$; $h = 420.000 \text{ in}$
Welds (profile to anchor plate):	Type of redistribution: Plastic Material: E70xx
Mesh size:	Number of elements on edge: 8 Min. size of element: 0.394 in Max. size of element: 1.969 in



www.hilti.com

Company:		Page:	12
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

2.2 Summary

	Description	Profile		Anchor plate		Hole bearing [%]	Welds [%]	Concrete [%]
		σ_{Ed} [psi]	ϵ_{Pl} [%]	σ_{Ed} [psi]	ϵ_{Pl} [%]			
1	Combination 1	37,931	0.10	36,035	0.12	1	76	24

2.3 Anchor plate classification

Results below are displayed for the decisive load combinations: Combination 1

Anchor tension forces	Equivalent rigid anchor plate (CBFEM)	Component-based Finite Element Method (CBFEM) anchor plate design
Anchor 1	6.599 kip	9.646 kip
Anchor 2	-0.001 kip	0.000 kip
Anchor 3	6.599 kip	9.647 kip
Anchor 4	-0.001 kip	0.000 kip

User accepted to consider the selected anchor plate as rigid by his/her engineering judgement. This means the anchor design guidelines can be applied.



www.hilti.com

Company:		Page:	13
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

2.4 Profile/Stiffeners/Plate


Profile and stiffeners are verified at the level of the steel to concrete connection. The connection design does not replace the steel design for critical cross sections, which should be performed outside of PROFIS Engineering.

2.4.1 Equivalent stress and plastic strain

Part	Load combination	Material	f_y [psi]	ϵ_{lim} [%]	σ_{Ed} [psi]	ϵ_{Pl} [%]	Status
Plate	Combination 1	ASTM A36	36,000	5.00	36,035	0.12	OK
Profile	Combination 1	ASTM A500 Gr.B Rect	46,000	5.00	37,931	0.10	OK
Profile	Combination 1	ASTM A500 Gr.B Rect	46,000	5.00	46,029	0.10	OK
Profile	Combination 1	ASTM A500 Gr.B Rect	46,000	5.00	33,154	0.04	OK
Profile	Combination 1	ASTM A500 Gr.B Rect	46,000	5.00	33,144	0.04	OK


2.4.1.1 Equivalent stress

Results below are displayed for the decisive load combination: 1 - Combination 1



2.4.1.2 Plastic strain

Results below are displayed for the decisive load combination: 1 - Combination 1



www.hilti.com

Company:		Page:	16
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

2.4.2 Plate hole bearing resistance, AISC 360-16 Section J3

Decisive load combination: 1 - Combination 1

Equations

$$R_n = \min(1.2 l_c t F_u, 2.4 d t F_u) \text{ (AISC 360-16 J3-6a, c)}$$

$$\phi R_n = 0.75 R_n$$

$$V \leq \phi R_n$$

Variables

	l_c [in]	t [in]	F_u [psi]	d [in]	R_n [kip]
Anchor 1	1.723	0.500	58,000	0.500	34.800
Anchor 2	10.751	0.500	58,000	0.500	34.800
Anchor 3	1.723	0.500	58,000	0.500	34.800
Anchor 4	10.751	0.500	58,000	0.500	34.800

Results

	V [kip]	ϕR_n [kip]	Utilization [%]	Status
Anchor 1	0.038	26.100	1	OK
Anchor 2	0.003	26.100	1	OK
Anchor 3	0.038	26.100	1	OK
Anchor 4	0.003	26.100	1	OK

www.hilti.com

Company:		Page:	17
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

2.5 Welds

Profiles are modeled without taking the corner radius into account. Special rules for welding (e.g. for cold-formed profiles ...) are not taken into account by the software.

2.5.1 Anchor plate to profile

Decisive load combination: 1 - Combination 1

Equations

$$F_{nw} = 0.6 F_{EXX} (1.0 + 0.5 \sin^{1.5} \Theta)$$

$$\phi R_n = \phi F_{nw} A_w$$

$$\text{Utilization} = \frac{F_n}{\phi R_n}$$

Variables

Edge	X_u	T_h [in]	L_s [in]	L [in]	L_c [in]	F_{EXX} [psi]	Θ [°]	A_w [in²]
Member 1-tfl 1	E70xx	0.246	0.348	1.994	0.665	70,000	22.9	0.16
Member 1-bfl 1	E70xx	0.246	0.348	1.994	0.665	70,000	62.5	0.16
Member 1-w 1	E70xx	0.246	0.348	7.730	0.773	70,000	65.4	0.19
Member 1-w 2	E70xx	0.246	0.348	7.730	0.773	70,000	65.4	0.19

Results


Edge	F_n [kip]	ϕR_n [kip]	Utilization [%]	Status
Member 1-tfl 1	4.359	5.779	76	OK
Member 1-bfl 1	5.302	7.304	73	OK
Member 1-w 1	6.460	8.590	76	OK
Member 1-w 2	6.459	8.589	76	OK

Company:		Page:	18
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

2.6 Concrete

Decisive load combination: 1 - Combination 1

2.6.1 Compression in concrete under the anchor plate



2.6.2 Concrete block compressive strength resistance check, AISC 360-16 Section J8

Equations

$$F_p = \phi f_{p,max}$$

$$f_{p,max} = 0.85 f'_c \sqrt{\frac{A_2}{A_1}} \leq 1.7 f'_c; \sqrt{\frac{A_2}{A_1}} \leq 2$$

$$\sigma = \frac{N}{A_1}$$

$$\text{Utilization} = \frac{\sigma}{F_p}$$

Variables

N [kip]	f'_c [psi]	ϕ	A_1 [in ²]	A_2 [in ²]
20.614	2,500	0.65	32.28	577,086.90



Hilti PROFIS Engineering 3.1.31

www.hilti.com

Company:		Page:	19
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

Results

Load combination	F _p [psi]	σ [psi]	Utilization [%]	Status
Combination 1	2,762	639	24	OK

Company:		Page:	20
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

2.7 Symbol explanation

A_1	Loaded area of concrete
A_2	Supporting area
A_w	Effective area of weld critical element
d	Nominal diameter of the bolt
ε_{lim}	Limit plastic strain
ε_{Pl}	Plastic strain from CBFEM results
f_c	Concrete compressive strength
f'_c	Concrete compressive strength
F_{EXX}	Electrode classification number, i.e. minimum specified tensile strength
F_u	Specified minimum tensile strength of the connected material
F_n	Force in weld critical element
F_{nw}	Nominal stress of the weld material
F_p	Concrete block design bearing strength
$f_{p,max}$	Concrete block design bearing strength maximum
f_y	Yield strength
l_c	Clear distance, in the direction of the force, between the edge of the hole and the edge of the adjacent hole or edge of the material
L	Length of weld
L_c	Length of weld critical element
L_s	Leg size of weld
N	Resulting compression force
σ	Average stress in concrete
σ_{Ed}	Equivalent stress
ϕ	Resistance factor
ϕR_n	Factored resistance
R_n	Resistance
t	Thickness of the anchor plate
Θ	Angle of loading measured from the weld longitudinal axis
T_h	Throat thickness of weld
V	Resultant of shear forces V_y , V_z in bolt.
X_u	Filler metal tensile strength

2.8 Warnings

- By using the CBFEM calculation functionality of PROFIS Engineering you may act outside the applicable design codes and your specified anchor plate may not behave rigid. Please, validate the results with a professional designer and/or structural engineer to ensure suitability and



www.hilti.com

Company:		Page:	21
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

- adequacy for your specific jurisdiction and project requirements.
- The anchor is modeled considering stiffness values determined from load displacement curves tested in an independent laboratory. Please note that no simple replacement of the anchor is possible as the anchor stiffness has a major impact on the load distribution results.



www.hilti.com

Company:		Page:	22
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

3 Summary of results

Design of the anchor plate, anchors, welds and other elements are based on CBFEM (component based finite element method) and AISC.

	Load combination	Max. utilization	Status
Anchors	Combination 1	389%	NOT OK
Anchor plate	Combination 1	100%	OK
Welds	Combination 1	76%	OK
Concrete	Combination 1	24%	OK
Profile	Combination 1	83%	OK

Fastening does not meet the design criteria!



www.hilti.com

Company:		Page:	23
Address:		Specifier:	
Phone I Fax:		E-Mail:	
Design:	Concrete - May 23, 2026	Date:	5/24/2026
Fastening point:			

4 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.