Karlsruher Institut für Technologie

Evaluating the benefit of grid-based weather information in energy forecasting

Marcel Herm

INSTITUT FÜR AUTOMATION UND ANGEWANDTE INFORMATIK



Acknowledgements

Introduction

Karlsruher Institut für Technologie

Related Works

paper	type of weather data	forecast time series	methods	forecast horizon
Ludwig u. a. (2015)	station-based	energy prices	ARMA,ARMAX,LASSO,RF	24h
Salcedo-Sanz u. a. (2018)	grid-based	solar radiation	ELM,CRO,MARS,MLR,SVR,GGA	24h
Diagne u. a. (2013)	grid-based	solar radiation	ARMA,ARIMA,CARDS,NN,WNN	5 min-6h
Aguiar u. a. (2016)	mixed	solar radiation	NN	1-6h
Bofinger und Heilscher (2006)	mixed	solar power	MOS,IDW	24-120h
Haben u. a. (2018)	station-based	low voltage electricity load	KDE,SSLR,ARWD,ARWDY,HWT	up to 4 days
Alessandrini u. a. (2015)	station-based	wind power	ANEN	0-132h
Sperati u. a. (2016)	grid-based	solar power	PDF,NN,VD,EMOS,PE	0-72h
De Felice u. a. (2015)	grid-based	electricity demand	LR,SVM	1-2 months
Davò u. a. (2016)	grid-based	wind power,solar radiation	PCA,ANEN,NN	0-72h
This thesis	grid-based	electricity load	ARMA,ARMAX	1h

Methodology

ARMA

$$y_t = c + \sum_{i=1}^{p} \phi_i y_{t-i} + \sum_{j=1}^{q} \rho_j \epsilon_{t-j} + \epsilon_t \tag{1}$$

ARMAX

$$y_t = c + \sum_{i=1}^{p} \phi_i y_{t-i} + \sum_{j=1}^{q} \rho_j \epsilon_{t-j} + \sum_{k=1}^{n} \eta_k x_k + \epsilon_t \tag{2}$$

Mean Absolute Percentage Error

$$MAPE = \frac{1}{k} \times 100 \sum_{i=1}^{k} \left| \frac{y_i - \hat{y}_i}{y_i} \right| \ . \tag{3}$$

Evaluation I

Data filtered using shapefile from Eurostat[1].





[1] `https://ec.europa.eu/eurostat/de/web/gisco/geodata/reference-data/administrative-units-statistical-units/nuts`

Evaluation II

Stuffy stuff.



Evaluation III

Wing stuffy[2]. Be no wowy, mesa no talk much about disa.



[2] `https://wingware.com/`

Evaluation IV

Autocorrelation and partial autocorrelation function.





Evaluation V

	MA(q) > AR(p) v	0	1	2	3	4	5
AIC	1	489489.23	472851.05	467543.07	466091.08	465622.11	464728.34
BIC		489513.76	472883.76	467583.96	466140.14	465679.35	464793.76
HQIC		489497.15	472861.61	467556.27	466106.92	465640.59	464749.47
AIC	2	464699.50	464253.96	464204.94	464190.14	464054.46	463634.12
BIC		464732.21	464294.85	464254.01	464247.39	464119.87	463707.72
HQIC		464710.06	464267.16	464220.79	464208.63	464075.58	463657.89
AIC	3	464324.69	464226.02	464202.92	463643.15	462483.99	462271.48
BIC		464365.58	464275.09	464260.16	463708.57	462557.59	462353.25
HQIC		464337.89	464241.87	464221.4	463664.27	462507.75	462297.88
AIC	4	464171.28	464173.25	462433.17	462985.37	462149.01	-
BIC		464220.35	464230.49	462498.59	463058.97	462230.78	
HQIC		464187.13	464191.73	462454.29	463009.14	462175.41	
AIC	5	464173.18	463588.38	462944.78	-	462138.70	-
BIC		464230.42	463653.80	463018.38		462228.65	
HQIC		464191.66	463609.50	462968.54		462167.74	

Evaluation VI

Only load ARMA(2,2) from 2017/12/31 to 2018/01/08 using load data from 2015/01/080 to 2017/12/31 for training.



Evaluation VII

Forecast from 2017/12/31 to 2018/01/08 for ARMAX(2,2) with load data from 2015/01/08 to 2017/12/31 for train and grid points of ten regions with highest pop as exog.



Evaluation VIII

forecast from 2017/12/31 to 2018/01/08 for ARMAX(2,2) with load data from 2015/01/08 to 2017/12/31 for train and load data shifted back in time by 1 week for same time range as exog.



Evaluation IX

Forecast from 2017/12/31 to 2018/01/08 for ARMAX(1,0) with load data from 2017/01/01 to 2017/12/31 for train and all 1435 grid points of the t2m variable as exog.



Evaluation X

ARMA/ARMAX performance using different input data and models.

model	shifted load	t2m mean	counter	weekend	top ten regions	RMSE	MAE	MPE	MAPE
ARMA(1,0)	✗	✗	✗	✗	✗	2621.940	1961.213	0.006	3.460
ARMA(2,2)	✗	✗	✗	✗	✗	1727.742	1216.559	0.220	2.114
ARMAX(2,2)	✓	✓	✗	✗	✗	1024.265	628.298	-0.020	1.103
ARMAX(2,2)	✓	✓	✓	✗	✗	1024.310	628.331	-0.006	1.103
ARMAX(2,2)	✓	✓	✗	✓	✗	1024.251	628.292	-0.020	1.103
ARMAX(2,2)	✓	✓	✓	✓	✗	1024.295	628.324	-0.006	1.103
ARMAX(2,2)	✓	✗	✗	✗	✗	1030.753	633.436	0.101	1.112
ARMAX(2,2)	✓	✗	✗	✓	✗	1030.756	633.433	0.101	1.112
ARMAX(2,2)	✓	✗	✓	✗	✗	1029.191	633.093	-0.165	1.114
ARMAX(2,2)	✓	✗	✓	✓	✗	1029.199	633.103	-0.165	1.114
ARMAX(2,2)	✓	✗	✗	✗	✓	1043.292	649.564	-0.018	1.144
ARMAX(2,2)	✓	✗	✓	✗	✓	1043.711	650.046	-0.012	1.145
ARMAX(2,2)	✓	✗	✓	✓	✓	1051.469	659.243	-0.012	1.164
ARMAX(2,2)	✓	✓	✗	✓	✓	1051.801	659.805	-0.021	1.165
ARMAX(2,2)	✓	✓	✓	✓	✓	1051.956	660.006	-0.004	1.165
ARMAX(2,2)	✓	✓	✗	✗	✓	1062.208	667.663	-0.011	1.179
ARMAX(2,2)	✓	✗	✓	✗	✗	1656.760	1178.435	0.021	2.043
ARMAX(2,2)	✗	✓	✗	✗	✗	1662.298	1179.187	0.185	2.039
ARMAX(2,2)	✗	✓	✗	✓	✗	1661.909	1179.681	0.187	2.040
ARMAX(2,2)	✗	✓	✓	✓	✗	1656.224	1179.021	0.022	2.044
ARMAX(2,2)	✗	✗	✓	✗	✗	1730.620	1226.238	-0.382	2.119
ARMAX(2,2)	✗	✗	✓	✓	✗	1730.620	1226.237	-0.382	2.119
ARMAX(2,2)	✗	✓	✓	✓	✓	1811.407	1321.255	0.043	2.315
ARMAX(2,2)	✗	✗	✓	✗	✓	2004.932	1444.396	-0.036	2.547
ARMAX(2,2)	✗	✓	✓	✗	✓	2032.248	1456.478	-0.025	2.570
ARMAX(2,2)	✗	✗	✗	✗	✓	2130.514	1508.978	0.211	2.663

Conclusion

Memba NN?



References I

Aguiar, L. M., B. Pereira, P. Lauret, F. Díaz und M. David (2016). “Combining solar irradiance measurements, satellite-derived data and a numerical weather prediction model to improve intra-day solar forecasting”. In: *Renewable Energy* 97, S. 599–610.

Alessandrini, S., L. Delle Monache, S. Sperati und J. N. Nissen (2015). “A novel application of an analog ensemble for short-term wind power forecasting”. In: *Renewable Energy* 76, S. 768–781.

Bofinger, S. und G. Heilscher (2006). “Solar electricity forecast : Approaches and first results”. In: *Proceedings of the 21st European Photovoltaic Solar Energy Conference and Exhibition*.

Davò, F., S. Alessandrini, S. Sperati, L. Delle Monache, D. Airoldi und M. T. Vespucci (2016). “Post-processing techniques and principal component analysis for regional wind power and solar irradiance forecasting”. In: *Solar Energy* 134, S. 327–338.

De Felice, M., A. Alessandri und F. Catalano (2015). “Seasonal climate forecasts for medium-term electricity demand forecasting”. In: *Applied Energy* 137, S. 435–444.

Diagne, M., M. David, P. Lauret, J. Boland und N. Schmutz (2013). “Review of solar irradiance forecasting methods and a proposition for small-scale insular grids”. In: *Renewable and Sustainable Energy Reviews* 27, S. 65–76.

References II

Haben, S., G. Giasemidis, F. Ziel und S. Arora (2018). "Short term load forecasting and the effect of temperature at the low voltage level". In: *International Journal of Forecasting* 35.4, S. 1469–1484.

Ludwig, N., S. Feuerriegel und D. Neumann (2015). "Putting Big Data analytics to work: Feature selection for forecasting electricity prices using the LASSO and random forests". In: *Journal of Decision Systems* 24.1, S. 19–36.

Salcedo-Sanz, S., R. C. Deo, L. Cornejo-Bueno, C. Camacho-Gómez und S. Ghimire (2018). "An efficient neuro-evolutionary hybrid modelling mechanism for the estimation of daily global solar radiation in the Sunshine State of Australia". In: *Applied Energy* 209.July 2017, S. 79–94.

Sperati, S., S. Alessandrini und L. Delle Monache (2016). "An application of the ECMWF Ensemble Prediction System for short-term solar power forecasting". In: *Solar Energy* 133, S. 437–450.