

Building Energy Analysis Report

Building · generated 2026-07-12 15:24 · job 20260712-152213-e08440

RUN INFORMATION

Input files	Duplex_A.ifc
Weather file	USA_CA_San.Francisco.Intl.AP.724940_TMY3.epw
Simulation engine	F:/ProgramWEnergyPlusV25-2-0Wenergyplus.exe
Engine diagnostics	18 warnings · 7 severe · 0 fatal
Analysis date	2026-07-12 15:22:13

ANNUAL TOTALS

Zones 21	Floor area 391.7 m ²	Heating 2,847 kWh/yr
Cooling 6,697 kWh/yr	Heating EUI 7.3 kWh/m ² ·yr	Cooling EUI 17.1 kWh/m ² ·yr

MONTHLY HEATING / COOLING (ALL ZONES, KWH)

Month	Heating	Cooling
January	919	13
February	460	52
March	240	201
April	115	423
May	59	742
June	49	824
July	12	1,139
August	12	1,230
September	11	1,211
October	60	707
November	235	118
December	676	37

ZONE BREAKDOWN

Zone	Storey	Area m ²	Vol m ³	Heat kWh	Cool kWh	Heat kWh/m ²	Cool kWh/m ²	T̄ °C
B102	Level 1	27.7	71.4	549	0	19.9	0.0	21.1
A201	Level 2	14.9	115.0	276	12	18.6	0.8	21.9
B101	Level 1	15.6	40.2	261	0	16.7	0.0	20.7

B201	Level 2	14.9	71.8	199	1	13.4	0.1	21.7
B203	Level 2	22.0	56.9	193	394	8.7	17.9	23.3
B103	Level 1	12.9	33.5	186	0	14.3	0.0	21.2
A102	Level 1	27.7	71.4	172	103	6.2	3.7	22.2
A101	Level 1	15.6	40.2	168	0	10.8	0.0	21.0
B105	Level 1	3.8	20.8	157	0	41.4	0.0	20.7
A105	Level 1	3.8	20.8	135	0	35.4	0.0	20.8
R301	Roof	135.2	405.4	120	2,187	0.9	16.2	23.9
A103	Level 1	12.9	33.5	109	0	8.4	0.0	21.5
B104	Level 1	3.2	8.2	79	0	25.1	0.0	20.5
A104	Level 1	3.2	8.2	70	0	22.1	0.0	20.6
A202	Level 2	22.0	56.9	56	1,208	2.5	54.8	24.3
B202	Level 2	22.0	56.9	53	1,506	2.4	68.3	24.4
B204	Level 2	4.8	12.3	50	9	10.4	1.9	22.8
B205	Level 2	1.4	3.6	10	18	7.0	13.0	23.6
A204	Level 2	4.7	12.2	3	26	0.6	5.5	23.6
A203	Level 2	22.0	56.9	2	1,204	0.1	54.6	24.9
A205	Level 2	1.4	3.7	1	27	1.0	19.1	24.0

Generated by BIM → BEM Energy Analyzer · simulation by EnergyPlus. The full EnergyPlus tabular report is available from the app (E+ report link).