8. AUDIT OBSERVATION AND RECOMMANDATIONS

8.1 Annexure - A: Areas of Improvement

Sr. No.	Observations	Recommendations
Legal / General		
1.	QHSE policy was not display in Local Language.	QHSE Policy Should be display in Local language.
2.	Refresher first aid training was not evident.	First aid training should be provided at regular intervals through a state-recognized first aid institute.
3.	On-site emergency plan (OSEP) available, but not compliant with Schedule 11 of The Manufacture, Storage and Import of Hazardous Chemical Rules, 1989.	OSEP to be prepared in accordance with Rule 13 (1), Schedule 11 of The Manufacture, Storage and Import of Hazardous Chemical Rules, 1989.
4.	As per IS 2190-2024 Year of Manufacture missing in Register of Fire Extinguisher.	As per IS 2190-2024 to be Updated Register of Fire Extinguisher.
Plant Round		
5.	Manual call point (MCP) at shed entrance was not tagged and lacked a defined testing schedule.	Affix proper tagging on the MCP and establish a regular inspection and testing schedule as per safety standards.
6.	Safety shower at the entrance had choked water nozzles, lacked a cleaning procedure, and was not numbered.	Implement a periodic cleaning protocol, assign identification numbers, and ensure functionality through regular checks.
7.	In the CNC mounting plate area, a worker was observed drilling without wearing hand gloves and earplugs, contrary to procedure PNL/PW/29 Rev02.	Reinforce the mandatory use of specified PPE and conduct refresher training on procedural compliance.
8.	Drilling machine in CNC area had no identification tag and lacked a documented testing schedule.	Tag the machine with an ID number and maintain a documented routine maintenance/testing schedule.
9.	Pathway in the CNC area was obstructed by a trolley loaded with materials, posing a movement hazard.	Ensure designated walkways remain unobstructed. Material trolleys must be parked in assigned zones.
10.	Battery storage room temperature exceeded the defined limit (25.3°C vs specified 20–25°C range).	Install automatic temperature monitoring with alerts. Regularly verify and calibrate HVAC systems.
11.	Fire Hose Reel (HR-4) near the gate was missing a nozzle.	Fit the appropriate nozzle and include it in the fire safety equipment checklist for inspection.
12.	During bolt tightening, an employee was not using hand gloves as required by SOP.	Reinforce PPE compliance through supervision and safety toolbox talks.
13.	In the Tin bus bar section, an employee conducting filing activity was not wearing gloves or goggles.	Ensure availability and mandatory usage of PPE (gloves and goggles) for conductive tasks.
14.	2000L air vessel (No. 50001270) had an overdue hydro test, and vessel number was missing from its certificate.	Conduct immediate hydro testing, update the certificate, and ensure vessel number is recorded accurately.
15.	500L air vessel also had an overdue hydro test with vessel number missing from the certificate.	Perform required testing and include all relevant identification data on certification documents.

Sr. No.	Observations	Recommendations
16.	Safety valve of 2000L vessel had a valid floating certificate, but the valve lacked tagging and next due date on certificate	Tag the valve clearly and mention the next test due date on both the valve and documentation.
17.	Safety valve on 500L vessel also lacked tagging and the certificate did not include the next due date.	Apply visible tagging and update certification with future due dates.
18.	DG set logbook lacked parameter limit ranges (high/low) to guide operators.	Update the logbook with acceptable parameter ranges to aid in operational decision-making.
19.	DG set logbook was not being reviewed by a senior officer for oversight.	Assign a responsible officer to periodically review and sign off on logbook entries.
20.	Diesel pipe and cable tray layout posed trip and fall hazards, especially during low visibility or emergency.	Reorganize routing of diesel lines and trays. Apply floor marking and cover to eliminate tripping hazards.
21.	Diesel tank (1000L) had a gauge glass that was not visible.	Replace the gauge glass periodically and ensure visibility is maintained for level monitoring.
22.	Diesel tank cleaning schedule was not defined.	Implement annual cleaning of the diesel tank and document it as part of preventive maintenance.
23.	Diesel for forklift was being filled using a plastic can, risking static discharge.	Replace plastic containers with grounded metal cans to eliminate static electricity hazards.
24.	Emergency lights in the DG room lacked a test schedule, and a light was missing in front of the DG set.	Conduct a light survey, install required emergency lighting, and implement a testing and maintenance schedule.
25.	No smoke detectors available in Security office & Cable Preparation	Detection system should be install in security office
26.	Emergency chart to be displayed at plant	Emergency chart to be displayed at plant

9. Occupational Health & Safety Audit as per IS 14489: 2018

9.1 ANNEXURE – B: Examination of Records (IS 14489: 2018)

Observations including nonconformities and good practices by the auditee factory are given below in Annexure B to C. Necessary recommendations / suggestions or improvement measures are also suggested in the last column.

Sr. No.	List Of Records / Documents	Pertaining Legal Requirement	Current Status / Observation
1.	OH & S policy	As per The State Factory Rules	OH & S policy available in the Organisation.
2.	Safety organization chart	The FA 1948 –Section 40- B.	Safety Organisation Chart available in the Organisation
3.	Training records on safety fire and first aid	The FA 1948 - 7 (A), 111 (A)	Internal Training records on safety, fire and first-aid maintained and available in organization
4.	Record of plant safety inspections	As per The State Factory Rules	Record of plant safety inspections maintained and available in organization.
5.	Accident investigation reports	As per The State Factory Rules	Accident investigation reports was available.
6.	Accidents, dangerous occurrences and near miss incidents - statistics and analysis	As per The State Factory Rules	Accidents, dangerous occurrences and near miss incidents - statistics and analysis were available.
7.	Record of tests and examinations of equipment and structures as per statutes	As per The State Factory Rules	Form No- 9, 10 and stability certificate available and found valid.
8.	Standard Operating Procedures (SOP) for various operations	---	Standard Operating Procedures (SOP) for various operations were available
9.	Record of work permits;	As per The State Factory Rules	Record of work permits were availble. **List of work permits**: 1. Work at height 2. Electrical work 3. Confined Space 4. Hot work
10.	Record of work environment monitoring (flammable, toxic and explosive substances)	The FA 1948 Section 7-A (2) (E).	Record of work environment monitoring was evident.
11.	Maintenance, testing and calibration records of fire detection and firefighting equipment	As per The State Factory Rules	Maintenance, testing and calibration records of fire detection and firefighting equipment was available.

Sr. No.	List Of Records / Documents	Pertaining Legal Requirement	Current Status / Observation
12.	Medical records of employees	As per The State Factory Rules	Medical records of employees (Form No. 32/33) were available.
13.	Records of industrial hygiene surveys (noise, ventilation, illumination, dust etc.)	The FA 1948 -Section 7A (2)(E).	Records of industrial hygiene surveys i.e., noise, illumination, ventilation was available.
14.	Material Safety Data sheets	MSIHC Rule 1989, Rule 17, Schedule 9.	MSDS of All chemicals, RM, Intermediates and Product were available
15.	On-site emergency plans and record of Mock Drills	CA EPPR 1996, The FA 1948 Schedule – 8-A.	On-site emergency plan was available Last Updated Date – 11/11/2024 Record of Mock Drills was available. Last Mock drill Date – 19/02/2025
16.	Records of storage of hazardous solid waste and its disposal	The FA 1948 section 12.	Records of storage of hazardous solid waste and its disposal was available.
17.	Records of gaseous emissions and effluent discharges to the environment	The FA 1948 section 12.	Records of gaseous emissions and effluent discharges to the environment was availble at Environmental Department. (Environmental monitoring done by Unistar Environment and Research Labs Pvt. Ltd. – Vapi)
18.	Housekeeping inspection records	The FA 1948 section 11.	Housekeeping inspection records was available.
19.	Minutes of safety committee meetings	As per The State Factory Rules	Minutes of safety committee meetings was available. Monthly meeting done. Plant Safety Committee (last meeting held on 21/03/2025) Chairman – Mr. Sankar A. Secretary –Mr. Tapan Beura
20.	Statutory licenses and approvals	As per The State Factory Rules	Available
21.	Records of any modifications carried out in plant or process	As per The State Factory Rules	Records were available for any modifications carried out in the plant or process
22.	Maintenance procedure and records	---	Preventive Maintenance procedure and records were available.
23.	Instrumentation and equipment calibration and testing records	The FA 1948, Section 36.	Instrumentation and equipment calibration and testing records available at technical department.
24.	Planned shutdown maintenance procedures	---	Procedure for shut down & Maintenance was available.

Sr. No.	List Of Records / Documents	Pertaining Legal Requirement	Current Status / Observation
25.	In service inspection manuals, records including that of material handling	---	All material handling equipment service inspection records, manuals available.
26.	OH & S budget	As per The State Factory Rules	As & when required. OH & S budget available.
27.	Inspection books and other statutory records;	As per The State Factory Rules	Inspection books and other statutory records were available.
28.	Records of previous audits and safety analysis;	As per The State Factory Rules	Records of previous audit was available and previous audit compliance report was also available.
29.	Procedures for safe transportation of hazardous substances;	MV Act.	Procedures for safe transportation of hazardous substances was available.
30.	Calibration records;	---	Instrumentation and equipment calibration and testing records availble.
31.	Records for breakdown of plants during the process of manufacture;	---	Informal Records for breakdown of plants during the process of manufacture was available
32.	Records for waste material generated and their disposal;	---	Records for waste material generated and their disposal record was available.
33.	SOP for disposal of waste materials; and	---	SOP for disposal of waste materials was available.
34.	Records for issue of PPE items to the personnel working in process building.	---	Records for issue of PPE items to the personnel working in process building was available.

9.2 ANNEXURE – C: General Points (IS 14489: 2018)

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	C-1 OH & S Management		
	C-1.1 OH & S Policy		
1.	Does the organization have OH & S Policy?	Organization have EHS Policy.	---
2.	Who has signed the OH & S policy?	Signed by Group Director Mr. Vinod T. Tanti	---
3.	Whether the OH & S policy is per guidelines of the statutory provisions?	OH & S policy was as per guidelines s	---
4.	When was the OH & S policy declared and	OH & S policy declared and adopted in 2006.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	adopted?		
5.	Whether the OH & S policy reviewed periodically?	We came to know EHS policy has been reviewed periodically. (Two times)	---
6.	Whether the OH & S policy is available in local language and made known to all?	OH & S policy was available in English & Hindi language. but displayed in only English.	• OH & S Policy Should be display in Local language.
7.	What was the last date of updation?	OH & S policy was last updated on 01/12/2023	---
	C-2 OH & S Organizational Set Up		
	C-2.1 Safety Department		
8.	Does the factory have a safety department and what is strength of safety department?	Factory has a Safety department and strength of safety department was 2 person.	---
9.	Whether the strength and qualifications of Safety Officers are as per the statutes?	We observed that, strength and qualifications of Safety Officers were as per the statutes.	---
10.	Does the head of safety department report to the Chief Executive?	Head of Safety department reporting to Unit Head (Plant Head) & Corporate HSE Team.	---
11.	How often are the safety officers retrained in the latest techniques of total safety management? What is the frequency of retraining?	Yes – frequently visited external	---
12.	What additional duties the safety officer is required to do?	HSE officer looked only HSE related job.	---
13.	What is the power of safety officer vis-a-vis unsafe condition or unsafe act?	The power of safety officer is, to stop any dangerous operation. If there are any unsafe conditions or acts, these will be brought to the notice of the concerned HOD and in the case of imminent danger, the job stopped until unsafe conditions/ act were removed / corrected.	---
	C-2.2 Safety Committee(s)		

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
14.	Does the factory has a safety committee(s)? What are the types, structures and terms of reference of the committees?	Minutes of safety committee meetings was available. Monthly meeting done. Last Safety Committee meeting held on 21/03/2025 Chairmen – Mr. Sankar A. Secretary – Mr. Tapan Beura	---
15.	Is the constitution of the safety committee(s) as per the statute?	Constitution of the safety committee(s) was as per the statute.	---
16.	How are the members of safety committee(s) selected? (elected / nominated)	Members of the safety committees were nomited.	---
17.	How often are the meetings of safety committee(s) held?	Meetings of safety committee(s) held monthly.	---
18.	Are the recommendations of the committees(s) implemented?	The recommendations of the committees(s) were implemented by action plan by concern person in time bound manner.	---
19.	Are the minutes of the safety committee(s) meetings circulated among the members?	Minutes of the safety committee(s) meetings were circulated among the members by e mail.	---
20.	Are the minutes forwarded to the trade union(s) and chief executive and occupier?	Yes, minutes forwarded to the occupier.	---
21.	Whether the management and trade union play their active roles in supporting and accepting the committee(s) recommendations?	We informed that management and trade unions actively involved and support in compliance of recommendations of safety committee.	---
22.	How are the safety committee(s) members apprised of the latest development in safety, health and environment?	Members of the safety committee's were participating in safety training.	• Members of the safety committee's to be sent to participate in external safety training program i.e., at DGFASLI, NSC etc.
	C-2.3 Safety Budget		
23.	What is the annual safety budget?	OH & S budget available As & When required.	---
24.	How much percentage is	Adequate- made available	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	this budget of the total turnover of the company?	as and when required	
25.	How much budget has been utilized till date?	Data available at QHSE department	---
26.	Is the safety budget adequate?	Safety budget was adequate.	---
27.	How is the safety budget arrived at?	Based on the previous year's utilization & present requirements	---
28.	What is the pattern of expenditure for the last five years?	Mostly Increasing trend. Price hike & the requirement.	---
29.	What are the approved sanctions for the expenditure in this budget?	Data available with HSE department	---
30.	Does this budget get reflected in the annual report of the company?	We came to know that Safety budget get reflected in the annual report of the company.	---
	C-3 Safety Manual		
31.	What is the periodicity of updation / review of safety manual?	Safety manual was available.	---
32.	Does the safety manual adequately address all the hazards in the plant?	Yes	---
33.	Are the employee made aware of safety rules?	Yes, employee made aware of safety rules.	---
	C-4 Standard Operating Procedures (SOP)		
34.	Are written Standard / safe operating procedures available for all operations and processes?	Standard Operating Procedures (SOP) for various manufacturing operations were available.	---
35.	Whether the written Standard / safe operating procedures are displayed or made available and explained in the local language to the workers?	The written Standard / safe operating procedures were displayed or made available and explained in the english only.	• SOP shall be prepared in local language and communicated to all concerned.
36.	Whether concerned section and safety department prepares standard / safe operating procedure jointly?	Concerned section and safety department prepares standard / safe operating procedure jointly.	---
37.	Are standard / safe operating procedures	Standard / safe operating procedures reviewed and	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	reviewed and updated?	updated by concerned section as and when required.	
38.	Have The Workers Been Informed of The Consequences Of Failure To Observe The Standard /Safe Operating Procedures?	In Training, Workers Were Informed About the Consequences of failure to observe the standard / safe operating procedures during training.	---
	C-5 Plant Modification Procedures		
39.	What is the system for effecting any change in the existing plant, equipment or process?	MOC was available for effecting any change in the existing plant, equipment or process.	• MOC shall be strengthen.
40.	Whether the P & I diagram, and other related documents are updated accordingly?	We came to know that P & ID/PFD diagram, and other related documents were updated after change realization.	---
41.	Whether hazard assessment done before implementation of modification?	Hazard assessment (HIARO) done before implementation of modification.	---
	C-6 WORK PERMIT SYSTEM		
42.	What types of work permits exist in the factory?	Record of work permits were availble. **List of work permits**: 1. Work at height 2. Electrical Permit 3. Confined Space 4. Hot work Permit	---
43.	Are the necessary forms detailing required safety precautions have been prepared and used for each type of work-permit?	Necessary forms detailing required safety precautions have been prepared and used for each type of work-permit. Printed Format in Original, Duplicate & Triplicate was developed for all permit	---
44.	Is the responsibility assigned to authorized person for issuing of safety work permit?	Responsibility assigned to concern department head for issuing of safety work permit.	---
45.	Is the copy of safe work permit sent to safety officer before execution of the job?	The copy of safe work permit sent to safety officer before execution of the job.	---
46.	Is validity period specified in the safety	Date, time, location and validity was mentioned in the	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	work permit?	safety work permit.	
47.	Are the records of work permit available and maintained in proper order?	Records of work permit was available and maintained in proper order.	---
	C- 6.1 Control Measures for Work at Height		
48.	Is adequate safe access provided to all places where workers need to work?	Adequate access provided where workers need to work.	---
49.	Are all such access in good condition?	All access in good condition.	• Ensure that Regular inspection to be carried out.
50.	Are all scaffolds are properly designed and erected?	Evident of scaffolding uses was not found.	• When scaffolds used, all scaffolds should be properly designed and erected.
51.	Are scaffolds inspected every day before work begins?	Evident of scaffolding uses was not found.	• When scaffolds used, scaffolds to be inspected every day before work begins
52.	Are ladders securely clamped or lashed in place?	Evident of scaffolding uses was not found.	• When scaffolds used, ladders should be securely clamped or lashed in place
53.	Are planks in good condition?	Evident of scaffolding uses was not found.	• When scaffolds used, planks always to be kept good condition.
54.	Are scaffold walkaways, platforms, runs or stairs free of debris, grease, any unnecessary obstruction and projecting nails?	Evident of scaffolding uses was not found.	• When scaffolds used, scaffold walkaways, platforms, runs or stairs free of debris, grease, and any unnecessary obstruction and projecting nails.
55.	Are the scaffolds higher than 20 m.? If yes, is netting or intermediate railing provided between toe-boards and hand railings?	No scaffolds higher than 20 m. Third party hired for above 20 m height work.	---
56.	Are folding stepladders properly used?	Folding stepladders was not in use.	---
57.	Are ladders set up at the proper slope of about 1:4?	Evident of ladders uses was not found.	---
58.	Do workers use hand lines to lift tools or	Workers used hand lines to lift tools & materials.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	materials?		
59.	Are proper ladders used around electrical hazards?	Proper ladders around electrical hazards was not evident.	• Special non-metallic ladders should be used all the time around electrical hazards.
60.	On sloping roofs, are crawling boards, lifelines, safety belts and edge protection provided where needed?	Safety harness, lifeline, Safety belt, helmet and edge protection was provided where necessary.	---
61.	Whether the weak spots, skylights, or deteriorated asbestos-cement boards through which a worker might fall while working in the roof has been identified and safety net provided appropriately?	Week spot, skylights, or deteriorated asbestos-cement boards was not seen.	---
62.	Are the workers being medically examined for their fitness to work at height?	Contract workers done fitness to work at height.	• Ensure that medical examination records available for fitness to work at height.
	C-6.2 Work in Confined Space		
63.	Is work permit system followed for working in confined space?	Yes, work permit system followed for working in confined space Only water tank available.	• Confined space entry to be done with competent person authorization only as and when required.
64.	Whether monitoring of the atmosphere inside the confined space is carried out and ensured that there is no flammable or toxic gas in the area?	Monitoring of the atmosphere inside the confined space was carried out for flammable or toxic gas in the area as and when required.	---
65.	Whether the person entering the confined space is using suitable personal protective equipment (PPE)?	We came to know that the person entering the confined space was using suitable personal protective equipment.	---
66.	Is rescue team available in case of any emergency?	Rescue team available in case of any emergency. Rescue team was available round the clock in organization.	---
	C-7 CONTRACTORS' SAFETY SYSTEM		
67.	Is there any system for	Contractor management	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	selection of contractors?	system was available.	
68.	Are there any guidelines on contractor's safety and training?	Yes, Guidelines on contractor's safety and training record was available.	---
69.	Whether contract document includes necessary safety and welfare clauses as per statutes?	Yes, as per Contractor management system all documents available.	---
70.	Is there any programme to ensure use of PPE by contractors' personnel?	Contractor management system, Training, supervision and site monitoring to ensure use of PPE by contractors' personnel.	---
71.	Do the contractors have their own safety organization?	We came to know some Contractors have Supervisor (as per contractor management system) and they co-ordinate with factory Safety Department.	---
72.	Are the contractors reporting all accidents and injuries?	The contractors reporting accidents and injuries.	---
73.	Are contractor workers trained to observe safety at workplace?	Contractor workers trained by safety officer to observe safety at workplace.	---
74.	Whether contractor workers are engaged in process / operations? If yes, are they aware of safe operating procedures?	Contractor workers were engaged in process / operations.	---
	C-8 Plant Design And Layout		
75.	Whether hazardous operations in the plant are segregated?	Hazardous operations in the plant were segregated.	---
76.	Whether occupational health & safety aspects are considered during the design?	Occupational health & safety aspects were considered during the design.	---
77.	Are all the equipment provided with adequate space for working, maintenance etc.?	The equipment provided with adequate space for working, maintenance, etc.	---
78.	Are the storage tanks provided with enough space Clearance	No storage tank available	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	between them?		
79.	Whether the plant layout has taken care of the movement of firefighting equipment and emergency exits?	The plant layout has taken care of the movement of firefighting equipment and emergency exits	---
	C-9 Medical Management Of Accidents		
80.	Are medical facilities available with trained first aid staff and equipment in round the clock shift for all including contractors?	Occupational health centre: Available at Unit-5 (within 1 km distance) First aid box: 4 Nos. First aider: 5 Nos.	---
81.	Is the ambulance van available for round the clock basis with the dedicated driver?	Ambulance van available at factory unit within 1 km distance. Emergency vehicle available for the emergency.	---
82.	Is there any mutual aid scheme available with the nearest hospitals to manage and treat injuries during emergency?	Yes, mutual aid scheme available with Haria Hospital, Vapi.	---
83.	Are the workers / contractor workers aware of emergency medical facilities?	Workers / contractor worker adequate aware about the emergency medical facilities.	---
	C-10 Management of Emergencies (Natural / Man-Made)		
84.	Does the system exist to detect and control these Emergencies?	Yes, Emergency Response Plan (OSEP) plan was in place.	---
85.	Are the employees aware of the measures to be taken during emergencies?	Workers found aware about the measure to be taken during emergencies. Regular basis training given & mock drill carried out.	---
	C-11 Employees Selection and Placement		
86.	Whether norms are available for selection of different category of employees?	Job Description criteria available at Manager for selection of different category of employees.	---
87.	Whether pre-employment medical examination is being conducted for employees?	Pre-employment medical examination (Form No. 33) Maintained.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
88.	Is there any procedure to evaluate safety awareness and record of the employees during their promotion?	Performance managment system available for promotion.	---
	C-12 Safety Culture		
	C-12.1 Attitudes of Managers		
89.	Do the managers follow the plant safety rules at all times?	Managers follow the plant safety rules.	---
90.	What are their attitudes towards safety reviews and audits?	Positive attitudes towards safety reviews and audits.	---
91.	What is the response of management to safety violation?	Counselling of workers upon safety Violation.	---
92.	Whether safety related decisions are taken in consultation with the workers?	Critical safety related decisions were taken in consultation with the workers.	---
93.	What is the attitude of the managers towards non-use of personal protective equipment?	Manager Acts as per Safety violation policy & norms, non-use of personal protective equipment.	---
	C-12.2 Attitudes of Workers		
94.	Whether workers are aware of the consequences of their wrong actions?	Workers were informed during Daily Tool Box Talk (TBT) / plant round about the consequences of their wrong actions.	---
95.	Are laid down safe working procedures followed strictly?	Working procedures followed.	---
96.	What is the attitude of the workers towards their own mistake, which can prejudice safety?	We came to know that Workers followed safety rules and producers. They try to follow safety producers. If deviation observed by anybody they will accept and correct it.	---
97.	Do the workers report near miss incidents and suggest safety improvements?	industry's Incident portal was available for near miss, Unsafe act, unsafe condition & accident.	---
98.	Are the workers aware of the system of rewards and sanctions relating to	Workers were aware about the safety rewards.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	safety matters?		
99.	What is the attitude of workers towards use of personal protective equipment?	Positive attitude of workers towards uses of personal protective equipment. Most of workers were used PPEs.	---
	C-13 Statutory Licenses, Approvals And Records		
100.	Whether all the safety related Acts / Rules (with latest amendments) applicable to your organization identified, informed to all employees and complied?	Legal register with all applicable Acts /Rules identified, maintained, amended time to time and communicated with all concerned. Kindly refer Chapter-7 "Applicable Laws and Statutory Requirements" & Chapter-9, "Annexure-B: Examination of Records (IS 14489:2018)"	---
101.	Whether the licenses have been validated?	All licenses found in valid status. For Details kindly refer "Annexure-1 List of Licenses/ Certification and its validity ".	---
	C-14 MOTIVATIONAL AND PROMOTIONAL MEASURES FOR OH & S		
102.	Does the factory have occupational health and safety suggestion scheme?	1 No. of Suggestion box available.	---
103.	Are occupational health and safety contests organized in the factory?	Yes, During safety week celebration.	---
104.	Does the factory participate in National Awards?	Yes, participated in National Award	---
105.	Has the factory been awarded during last five years?	Yes, Gold Award – NAMC-2021 Silver Award – IGMC-2022 CII Pinnacle Awards for Excellence in Manufacturing-2022 Frost & Sullivan - Indian Manufacturing Excellence Award- Silver Award - 2023 National Safety Council Appreciation Award – 2023 "Best Kaizen –GOLD category Winner" by	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
		WTG Daman at QCFI, Baroda - 2024	
106.	Does the organization publish safety bulletin /Newsletters?	Organization published Windchimes every monthly.	---
107.	Whether the safety bulletins are widely distributed?	Safety bulletins//Newsletters were widely distributed by mail.	---
108.	How is the occupational health and safety information including accident statistics disseminated in the factory? (Bulletin boards, Newsletter etc.)	The occupational health and safety information including accident statistics disseminated in the factory by Bulletin boards, Newsletter.	---
109.	What are the activities conducted during National Safety Day / week?	First aid training, Safety quiz, safety slogan, safety poster, quiz, drawing competition, safety speech, On the spot quiz, etc.	---
110.	What is the percentage of Workers participating in the various safety promotional activities?	Majority Workers participating in the various safety promotional activities.	---
	C-15 Hazard Identification And Job Safety Analysis		
111.	Was an initial process hazard analysis (PHA) completed?	Yes, HIARO carried out.	• Ensure that all recommendations of HIARO are complied.
112.	What are the stages of PHA? Whether a dedicated group is identified for PHA?	Dedicated group was identified for PHA.	---
113.	Was the PHA appropriate for the complexity of the process and identify, evaluate, and control the hazards involved in the process?	Yes, the PHA (HIARO) appropriate for the complexity of the process and identify, evaluate, and control the hazards involved in the process.	• Ensure that all recommendations of PHA are complied.
114.	Does the hazard evaluation use one or more of the following PHA methodologies: What-If Analysis, Process Checklist, Hazard and Operability Study (HAZOP), Failure	Following methodologies used for hazard evaluation PHA (HIARO)	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	Mode and Effects Criticality Analysis (FMECA), Fault Tree Analysis (FTA) or any other appropriate equivalent methodology?		
115.	Does PHA assure addressing issues of inherent safety features with respect to material and their properties?	We observed PHA assured addressing issues of inherent safety features with respect to material and their properties.	---
116.	Does the PHA address the hazard identification, incidents history, consequences of failures (engineering and administrative controls), human factors, consequent analysis with respect to possible safety and health effects of failure of controls?	Observed that HIARO, addressed the hazard identification, consequences of failures (engineering and administrative controls), human factors, consequent analysis with respect to possible safety and health effects	---
117.	What are the stages of PHA? Whether a dedicated group is identified for PHA?	Dedicated group was identified for PHA.	---
118.	Does the system exists to promptly address findings and recommendations of PHA?	Tracking system available	---
119.	Are the PHA's updated and revalidated at least every five years by a qualified team to assure that the PHA is consistent with the current process?	PHA was carried out.	---
120.	Whether the activities requiring Job Safety Analysis have been identified?	Hazard Identification and Risk Assessment carried out for routine activities & Job Safety Analysis have been identified for non-routine activities.	---
121.	Whether the identified jobs for Hazard Identification have been	The identified jobs for Hazard Identification and Risk Assessment carried out	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	carried out by trained and experienced persons?	by internally trained and experienced persons.	
122.	Whether the checklists have been prepared on each Job Safety Analysis and are being used while carrying out the job?	The checklists prepared on each Job Safety Analysis are being used while carrying out the job.	---
	C-16 Product Safety		
123.	Whether hazards arising from use of the products are identified?	No hazardous product. (Assembling only)	---
124.	Whether material safety data sheet prepared for the products?	Material safety data sheet prepared for the products.	---
125.	Are all the products labelled and packed appropriately?	All the products labelled and packed appropriately.	---
126.	Whether safety instructions are given along with products?	Mandatory safety instructions including are given along with products.	---
127.	Whether policy exists for recall of products?	Process was available for recall of products.	---
	C-17 Safety Training		
128.	Whether training needs have been identified?	Training needs identification available and also including contractor.	---
129.	Is there any programme of induction training, its duration and topics covered?	Induction training was provided to the employees/Workers.	---
130.	Whether the assessment of the trainees has been carried out?	The assessment of the trainees has been carried out by traning feedback & evalution form availble.	---
131.	What are the infra-structural facilities available for training?	Training Hall, LCD Projector, Table bench, etc. available.	---
132.	Whether training is conducted by qualified person?	Training was provided internally by Safety Officer & Externally by Third Party.	• First Aider Training should be Carried out in regular interval.
133.	Whether trainers are being re-trained from time to time?	Trainers were being re-trained from time to time by internally.	• Ensure Trainers to be re-trained from time to time by externally.

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
134.	Whether proper records of training program conducted are maintained?	Training records of training program conducted were maintained.	---
135.	How training programs are evaluated?	Training programs were evaluated traning feedback & evalution form.	---
136.	Whether schedule for training on occupational health and safety is available and maintained?	Yearly training Calendar prepared and accordingly trainings were conducted.	---
137.	Whether the training programmes are reviewed?	Regular basis training programmes were reviewed.	---
138.	Are all the employees periodically trained / retrained and what is the frequency of such training?	As per monthly training calendar all the employees periodically trained / retrained. As per HSE training calendar	---
139.	Are the retraining needs identified whenever a new process / products and change in existing process introduced?	Retraining needs identified whenever a new process / products and change in existing process was introduced.	---
140.	Whether training covers top management?	Training covers employees of factory and top management.	---
141.	How many hours of safety training is given to different employees?	Data available from HSE /HR Department.	---
	C-18 Change Management		
	C-18.1 Management of Change		
142.	Are there written procedures for managing change to process chemicals, technology, equipment and procedures and changes to facilities that affect the plant process / system operation?	MOC System was available.	---
143.	Do the procedures assure that the technical basis for the proposed change addressed prior to any change?	Yes, procedure assure that the technical basis for the proposed change addressed prior to any change. SOP for MOC was developed.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
144.	Do the procedures assure that the impact of the change on safety and health addressed prior to any change?	The procedures assured that the impact of the change on safety and health addressed prior to any change.	---
145.	Do the procedures assure that modifications to operating procedures are addressed prior to any change?	The procedures assured that modifications to operating procedures were addressed prior to any change.	---
146.	Do the procedures assure that the necessary time period for the change is addressed prior to any change?	The procedures assured that the necessary time period for the change is addressed prior to any change.	---
147.	Do the procedures assure that the authorization requirements for the proposed change are addressed prior to any change?	The procedures assured that the authorization requirements for the proposed change are addressed prior to any change.	---
148.	Are employees involved in operating a process, and maintenance and contract employees whose job tasks will be affected by change informed of, and trained in, the change prior to the start-up of process or affected part of process / operations?	Employees involved in operating a process, and maintenance and contract employees whose job tasks will be affected by change informed of, and trained in, the change prior to the start-up of process or affected part of process / operations.	---
149.	Is the safety information is reviewed and updated on changes?	The safety information was reviewed and updated on changes as per Management of change procedures.	---
150.	Are the operating procedures or practices updated?	Operating procedures / practices updated as when required.	---
	C-18.2 Mechanical Integrity		
151.	Does the mechanical integrity program include for all mechanical equipment including pressure vessels and storage tanks, piping and components, relief devices and vent	Mechanical equipment including pressure vessels and storage tanks, piping and components, relief devices and vent systems, emergency shutdown systems, pumps, control systems included in	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	systems, emergency shutdown systems, pumps, control systems?	mechanical integrity program. Testing done as per norms. Form No. 10 and Stability of the Building available and valid.	
152.	Are there written procedures to maintain the on-going integrity of process equipment?	Written procedures available (Preventive maintenance schedule) to concern department to maintain the on-going integrity of such equipment.	---
153.	Whether training been provided to each employee involved in maintaining the on-going integrity of process equipment?	Informal training was imparted to employees on PM of equipment.	---
154.	Are inspections and tests performed on each item of process equipment included in the program?	Examination, inspection and testing carried out of process equipment.	---
155.	Does the inspection and test frequencies meet the manufacturer's recommendation and good engineering practice?	Inspection and test frequencies meet the manufacturer's recommendation and good engineering practice.	---
156.	Are inspections and tests performed more frequently if determined necessary by operating experience?	Inspections and tests performed more frequently when determined necessary by operating experience.	---
157.	Are deficiencies in equipment that are outside limits corrected before further use so as to assure safe operation?	Deficiencies in equipment that are outside limits corrected before further use so as to assure safe operation.	---
158.	In the construction of new plants and equipment, whether quality assurance programme is implemented to ensure that equipment fabricated is suitable for	The construction of new plants and equipment, whether quality assurance programme was implemented to ensure that equipment fabricated was suitable for the process.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	the process?		
159.	Are appropriate checks and inspections made during equipment installation stage?	Appropriate checks and inspections made during equipment installation stage. Equipment Qualification was available at Engg. Department.	---
160.	Are the suitability of maintenance materials, spare parts and equipment ensured during maintenance?	Yes, all suitability of maintenance materials, spare parts and equipment ensured during maintenance.	---
	C-19 Physical Hazard		
	C-19.1 Housekeeping		
161.	Are all the passages, floors and the stairways in good condition?	The passages, floors and the stairways in good condition at most of place.	---
162.	Is glass door taped or otherwise marked to make it visible to workers?	Glass door was taped or marked.	---
163.	Do you have the system to deal with the spillage?	Company had system to deal with the spillage. Spill kit and Sand buckets were available.	---
164.	Do you have sufficient disposable bins clearly marked and whether these are suitably located? Are containers of refuse (waste) and trash emptied at the end of every day or soon after they are full? Are the containers or bins regularly cleaned?	Sufficient disposable bins clearly marked and suitably located. All containers or bins regularly cleaned.	---
165.	Are drip trays positioned wherever necessary?	Drip trays were positioned wherever necessary.	---
166.	Do you have adequate localized extraction and scrubbing facilities for dust, fumes and gases? Please specify.	Adequate localized extraction system provided.	---
167.	Whether walkways are clearly marked and free from obstruction?	Walkways were clearly marked.	---
168.	Do you have any inter-	Inter-departmental	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	departmental competition for good housekeeping?	competition was carried out.	
169.	Has your organization elaborated good housekeeping practices and standards and made them known to the employees?	Organization was elaborated good housekeeping practices and standards and made them known to the employees.	---
170.	Are there any working conditions, which make the floors slippery? If so, what measures are taken to make them safe?	Working conditions, which make the floors slippery was not evident.	---
171.	Does the company have adequate measures to suppress polluting dust arising out of materials stored on the roadside?	Yes, all internal roads were kept clean & clear.	---
	C-19.2 Machine and General Area Guarding		
172.	Whether machinery and equipment which can cause physical injuries to operator have been identified?	The rotating & moving parts machinery and equipment identified, which can cause physical injuries to operator.	---
173.	Are all moving parts and point of operation of machinery adequately guarded?	We observed that moving parts of machinery adequately guarded most of place.	---
174.	Are all fixed guards securely bolted in position and in good condition?	Fixed guards were securely bolted in position and in good condition.	---
175.	Are all interlock guards for prevention of physical injury in good condition?	Interlock guards provided for prevention of physical injury and observed in good condition.	---
176.	Are all emergency stop buttons effective and clearly labelled?	Emergencies stop buttons was clearly labelled.	---
177.	Are the operators for machines having moving parts aware of the danger of working with loose clothing?	Operators for machines having moving parts aware by training of the danger of working with loose clothing.	---
178.	Are the openings where	No openings available where	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	there is free fall hazard covered or fenced securely?	there was free fall hazard.	
	C-19.3 Material Handling		
179.	Are adequate equipment available for handling materials?	EOT Crane, Electrical Chain Hoist, Fork Lift, Stacker etc. available for handling materials. Manual material handling also carried out.	---
180.	Are the workers aware of the hazards associated with material being handled?	Workers found aware by training of the hazards associated with material being handled.	---
181.	Where manual handling is necessary, are the workers been trained? Do they practice this? Are workers warned for lifting of excessive weight? (Maximum weight of material for adult male and female are 55 Kg and 30 Kg respectively)	Workers trained where manual handling necessary. All workers warned for lifting of excessive weight.	---
182.	Do workers follow safe procedures for storage of materials?	Workers followed safe procedures for storage of materials.	---
183.	Is the register maintained to record particulars of examination of all lifting machines, tools and tackles?	Register was maintained to record particulars of examination of all lifting machines, tools and tackles. (Ref.: Form No. 10 available and valid)	---
184.	Are all the statutory examinations and tests carried out and certified by competent person(s)?	All the statutory examinations and tests were carried out and certified by competent person(s).	---
185.	Are the operators of crane, lifts, hoists and other mechanized operations adequately qualified?	We observed that operators of mechanized operations adequately qualified. Record available at concern department.	---
186.	Is the safe working load clearly marked?	SWL was marked on most of the equipment	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
187.	Has the person employed to operate crane, forklift, or to give signals to crane been medically examined for eyesight and colour vision?	Person employed to operate crane, or to give signals to crane been medically examined for eyesight and colour vision.	---
188.	Is the frequency of eyesight and colour vision examination as per the latest rules?	Frequency of eyesight and colour vision examination as per the latest rules.	---
	C-19.4 Electrical Safeguarding		
189.	Are licensed electricians available for electrical work?	We come to know Licensed electricians were available for electrical work.	---
190.	Whether area classification for electrical equipment has been carried out?	Area classification for electrical equipment was not evident.	• Area classification for electrical equipment to be carried out.
191.	Do the electrical fittings conform to area classification for electrical equipment?	Data available with electrical dept.	---
192.	Is a ground fault current interrupter system (ELCB) in use?	ELCB used in plant.	---
193.	Are all connections made by using appropriate plugs, receptacles or enclosures? Are fuses provided?	All connections made by using appropriate plugs, receptacles or enclosures.	---
194.	Are there any makeshift connection bare wires or damaged cables?	Makeshift connection, bare wires or damaged cables was not observed.	---
195.	Is there a system of ensuring periodical inspection of hand tools, extension boards used for electrical work?	Electrical equipment checklist established for ensuring periodical inspection of hand tools, extension boards used for electrical work.	---
196.	Do the workers use proper types of PPE during the working on live line?	Workers used proper types of PPE during the working on live line.	---
197.	Is the separate work permit issued for working	Yes, separate Electrical work permit was available.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	on high voltage line?		
198.	Whether the process(s) and equipment that generate and accumulate static charge have been identified?	No such process evident that accumulate static charge.	---
199.	Whether all such equipment including pipelines for flammable materials are properly bonded and earthed?	Yes, adequately bonded and earthed.	---
200.	Whether earth pit resistance is measured, and the record maintained?	Earth pit resistance was measured, and the record was maintained by electrical department.	---
201.	Whether lightning arrestor has been installed and is adequate?	02 Nos. of Lightning arrestor has been installed.	• Ensure that installed lightning arrestors as per lightening arrestor survey.
	C-19.5 Safety in Storage and Warehousing		
202.	Whether the Material Safety Data Sheet for all chemicals is available?	Material Safety Data Sheet for chemicals was available.	---
203.	Are the chemicals stored as per their hazardous properties including the incompatibility?	Chemicals stored as per their hazardous properties including the incompatibility.	---
204.	Are all containers clearly, indelibly labelled? Are all chemicals stored as per safety regulations?	The containers clearly, indelibly labelled & Identification and hazard symbol was available on container.	---
205.	Whether all racks and steel cages have sufficient load bearing capacity?	The racks and steel cages have sufficient load bearing capacity.	---
206.	Is adequate natural ventilation provided to storeroom? Is there any emergency exit?	Natural ventilation was provided to storeroom.	---
207.	Whether adequate firefighting arrangement existing in flammable chemical storage?	Fire Extinguisher provided.	---
208.	Whether methodology for handling spillages of	Procedure was not available for handling spillages of	• Procedure to be made for handling of chemical

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	hazardous chemical available along with the equipment required handling the spillage?	hazardous chemical available along with the equipment required handling the spillage.	spillage / leakage & made known to workers.
209.	Whether aisles are marked and emergency exits displayed?	Aisles were marked and emergency exits were displayed.	---
	C-19.6 Hazard Assessment for New Equipment		
210.	What is the system for effecting any change in the existing plant, equipment?	HIARO carried out.	---
211.	Is there system for evaluating hazards from new equipment?	HIARO was conducted for evaluating hazards from new equipment.	---
212.	Whether the P and I diagrams, and other related documents are updated accordingly?	Related documents are kept updated.	---
213.	Is any Job Hazard Analysis (JHA) carried out after installation of new equipment?	HIARO carried out.	---
	C-19.7 Hazards from Radiation Sources		
214.	Whether licenses have been obtained for storage /handling of radioactive material?	We came know that storage of radiation sources was not available. As & when required (For NDT testing or other work) handling of radioactive material used by third party, they had valid license for handling of radioactive material.	---
215.	Whether approved Radiological Safety Officer appointed?	As & when required (For NDT testing or other work) approved Radiological Safety Officer appointed.	---
216.	Whether appropriate PPEs are used against radiation hazards?	As & when required (For NDT testing or other work) Radiological Safety Officer used appropriate PPEs against radiation hazards.	---
217.	Is the flooring of the radioactive material handling area amenable for proper	Flooring of the radioactive material handling area was proper decontamination by third party which carried out	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	decontamination?	job.	
218.	Is the storage room of radiation source as per the licence condition?	They don't have storage of Radioactive material in the premises.	---
219.	Are all persons working in the facility have radiation safety training?	We came to know that as & when required NDT testing or other work only trained persons & qualified person handled working.	---
220.	Is the operator handling devices using radioactive materials qualified and possess the necessary certificate?	As & when required (For NDT testing or other work) only trained persons & qualified person handling of radioactive materials.	---
221.	Is the periodical radiation monitoring carried out?	As & when required (For NDT testing or other work) radiation monitoring carried out	---
222.	Are the records of inventory of radioactive material maintained in the standard format and submitted to the competent authority as per the period specified?	We came know that storage of radiation sources was not available.	---
223.	Are emergency handling tools available?	We came know that storage of radiation sources was not available.	---
224.	Are the personnel monitoring badges (TLD, Pocket dosimeter etc.) assigned and worn by each radiation worker?	We came know that storage of radiation sources was not available.	---
225.	Are the radiation symbol and red light displayed as required?	We came know that storage of radiation sources was not available.	---
	C-20 CHEMICAL HAZARD		
	C-20.1 Transportation of Hazardous Substances		
226.	What potentially hazardous materials are transported to or from the site (including wastes)	List of Hazardous material. Kindly see para 6.3 "List of Hazardous Raw Materials".	---
227.	What mode of transport are used?	Mode of transport was used • Road	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	1) Road, 2) Rail, and 3) Pipelines		
	1) Road		
228.	Does the company employ licensed vehicle of its own / outside sources?	Outside sources vehicle.	---
229.	Are the loading / unloading procedures in place and safety precautions displayed?	Loading / unloading procedures in place and safety precautions displayed.	---
230.	Is there a provision to check the healthiness of road tanker with respect to explosives rules?	Checklist available for check the healthiness of road tanker.	---
231.	Are loaded tankers or trucks parked in a specific area on-site?	Loaded tankers or trucks parked in a specific area on-site.	---
232.	Do all truck and tanker drivers carry transport emergency (TREM) card or instruction booklet?	Truck and tanker drivers carried out instruction booklet.	---
233.	Do all truck and tanker drivers get training in handling emergencies during transport?	We came to know that truck and tanker drivers' got training in handling emergencies.	---
234.	Are all the tankers marked for proper Hazchem code?	No chemical was not transported by road tanker	---
	2) Rail		
235.	What hazardous materials are transported by rail?	No Hazardous materials transported by rail	---
236.	Does the company have a direct siding on site?	No Hazardous materials transported by rail	---
237.	Are tankers or other wagons used in transportation?	No Hazardous materials transported by rail	---
	3) Pipelines		
238.	What materials are transported to and from the site by pipelines?	No Hazardous materials transported by pipeline.	---
239.	Are the pipelines underground or over ground?	No Hazardous materials transported by pipeline.	---
240.	Are corrosion protection	No Hazardous materials	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	measures employed in pipelines?	transported by pipeline.	
241.	Whether intermediate booster pumps are used?	No Hazardous materials transported by pipeline.	---
242.	What is the maximum, minimum and average transfer rates?	No Hazardous materials transported by pipeline.	---
243.	Are the pipelines extended in the public domain?	No Hazardous materials transported by pipeline.	---
244.	Are the pipelines dedicated for each type of chemicals?	No Hazardous materials transported by pipeline.	---
245.	Are the pipelines fitted with safety equipment such as leak detectors, automatic shut-off valves etc.?	No Hazardous materials transported by pipeline.	---
246.	What is the frequency and method of testing of the pipeline?	No Hazardous materials transported by pipeline.	---
247.	Is there written procedure for tackling leakages in pipeline?	No Hazardous materials transported by pipeline.	---
	C-20.2 Handling of Hazardous Substances		
248.	What are the hazardous substances handled in the factory?	List of Hazardous material. Kindly see Chapter 6, para 6.3	---
249.	Whether quantity of hazardous substances is above the threshold limit specified in the Manufacture, Storage and Handling of Hazardous Substances Rule, 1989? If yes, then required documentation is available as per the rule.	No, quantity of hazardous substances is above the threshold limit specified in the Manufacture, Storage and Handling of Hazardous Substances Rule, 1989.	---
250.	Whether written procedure for handling the hazardous substance is available and operators are trained for handling such substances including	Procedure was evident in case of leakages and spillages.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	actions required in case of leakages and spillages?		
251.	Are the employees aware of the hazards arising from hazardous substances and safety precautions to be taken during handling of these?	Employees' awareness about the hazardous substance found adequate.	---
	C-20.3 Material Safety Data Sheets (MSDS)		
252.	Are the material safety data sheets available for all the chemicals handled, used and manufactured in the factory?	Material safety data sheets (MSDS) available for the chemicals handled, used in the factory.	---
253.	Whether the latest MSDS are displayed at strategic locations?	MSDS extract were displayed at strategic locations.	---
254.	Is it available in local language?	Yes, available in local language	---
	C-20.4 Spill Control Measures		
255.	Whether spill control procedure is available?	Spill control procedure was not evident.	---
256.	Whether spill collection pit / sump is available at the workplace?	spill collection pit / sump was available.	---
257.	Whether methodology for recovery / disposal of collected material has been established?	Procedure was available.	---
	C-20.5 Storage of Hazardous Substances		
258.	Whether storage vessels are identified with the capacity as required under MSIHC, Rules 1989.	List of Hazardous material. Kindly see Chapter 6, para 6.3	---
259.	What are the storage pressure and temperature?	Kindly see para 6.3 "List of Hazardous Raw Materials". For storage pressure and temperature.	---
260.	Whether vessels are above ground / underground?	No vessels available for storage of hazardous substance.	---
261.	If any of the tanks storing	Storage Tanks for chemical	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	flammable material, whether electrical equipment and fittings are as per electrical area classification?	were not available.	
262.	Is the bunded area takes into account the total quantity of the largest tank?	Kindly see point no. 261	---
263.	Whether the bund perimeter takes into consideration of trajectory of leak from tank?	Kindly see point no. 261	---
264.	Are the vessels properly bonded and earthed and whether periodically checked and record maintained?	Kindly see point no. 261	---
265.	Are the vessels fitted with remotely controlled isolation valves?	Kindly see point no. 261	---
266.	Are vessels provided with emergency vent, relief valve, bursting disc, level indicator, pressure gauge, overflow line?	Kindly see point no. 261	---
267.	Where do such vents discharge?	Kindly see point no. 261	---
268.	Are the vessels provided with alarms for high level, high temperature and high pressure?	Kindly see point no. 261	---
269.	Are standby empty tanks or any other alternate systems provided for emptying / transfer in case of emergencies?	Kindly see point no. 261	---
270.	What are the provisions made for firefighting / tackling emergency situations around the storage vessels?	Kindly see point no. 261	---
271.	Has any consequence analysis for loss of containment been	Consequence analysis for loss of containment was not carried out.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	carried out?		
272.	Whether the vessels are tested as per statute?	Kindly see point no. 261	---
273.	Whether log sheets are filled up on daily basis for recording the parameters of these vessels?	Kindly see point no. 261	---
274.	Whether monitors for detection of leakage of flammable / toxic material installed?	Not installed.	---
275.	Whether the chemicals stored are as per their compatibility?	Chemicals stored as per their chemical compatibility chart.	---
	C-20.6 Gas Cylinders		
276.	What are the various gas cylinders used in the plant?	LPG gas cylinders	---
277.	Are valid licenses available for storing all these cylinders?	No, Quantity of gas cylinders stored & handled less than the license applicability.	---
278.	Are the cylinders stored and segregated as per their compatibility?	Cylinders stored and segregated as per their compatibility.	---
279.	What are the measures taken for combating any emergency in the cylinder's storage area?	Fire extinguishers, were available for combating any emergency in the cylinder's storage area.	---
280.	Whether integrity test certificates are obtained from the suppliers of the cylinders?	Integrity test certificates were obtained from the suppliers of the cylinders.	---
281.	Are the cylinders chained and secured properly along with the valve caps and proper identification colour code?	Most of cylinders chained and secured properly along with the valve caps.	---
282.	Are the cylinders protected from heat or sun and rain?	Yes, gas cylinders stored under shed	---
283.	Whether monitors for detection of leakage of flammable / toxic gas installed?	No detector available for gas leakage.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	C-20.7 Labelling and Colour Coding		
284.	Are all the containers, vessels and storage tanks labelled for its content and capacity?	No chemical was stored in tank.	---
285.	Whether the pipelines are colour coded as per IS 2379?	No chemical was transferred by pipeline.	---
286.	Is any plant specific colour code followed?	No chemical was transferred by pipeline.	---
287.	Whether the colour codes are displayed conspicuously in the working areas?	No chemical was transferred by pipeline.	---
	C-20.8 Hazardous Waste Management		
288.	Is identification done for various types of hazardous wastes?	Identification done for various types of hazardous wastes as per PCCD Norms.	---
289.	Are these quantities less than those specified by the Hazardous Wastes (Management & Handling) Rules, 1989?	We came to know that quantities less than those specified by the Hazardous Wastes (Management & Handling) Rules, 1989.	---
290.	What are their disposal modes?	Their disposal modes as per PCCD Norms. Waste disposal permission was evident.	---
291.	What are the systems / measures adopted for controlling air / water / land pollution?	The systems / measures adopted for controlling air / water / land pollution as per PCCD Norms.	---
292.	Whether the solid waste like combustibles, plastic, metals etc. segregated?	The solid waste like combustibles, plastic, metals etc. were segregated.	---
	C-21 Fire And Explosion Hazard		
	C-21.1 Organizational Set-up for Fire Fighting		
293.	What is the total strength of fire station and fire crew?	Daman fire station available nearby. ERT members available.	---
294.	How many fire crews are available in each shift?	ERT members available (Factory operations carried out in general shift only)	---
295.	Is there fire squad identified in each shift?	Refer point No. 294	---
296.	Standing fire order is available with latest	Standing fire order was available with safety officer.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	revision		
297.	How is the communication with fire station?	Communication with fire station by telephone / Mobile etc.	---
298.	Does fire safety inspections carry out?	Fire safety inspections carried out by safety officer.	---
299.	Does emergency procedure available for leakage or combustion of flammables?	On-site emergency plan available.	---
300.	What measures are available to control the fire load in the plant area?	Fire extinguisher, Fire Hydrant etc available to control the fire in the plant area.	---
301.	Whether technical knowledge and skills of the manager and staff responsible for overall fire safety of the plant is adequate?	Technical knowledge and skills of the manager and staff responsible for overall fire safety of the plant was adequate.	---
302.	How many major and minor incidents / fires were there in the factory during the last five years? Give department / plant wise.	Data available from HSE department.	---
303.	Have all the fires / incidents been investigated and corrective actions taken? Give break-up.	All the fires / incidents been investigated, and corrective actions taken. Data was available at HSE department.	---
304.	**Resources:** 1. Adequacy of protective clothing (coat, trouser, gloves, boots and helmets); 2. Availability of SCBA for firefighting operations and spare cylinders (at least 2 for each SCBA); 3. Adequacy of hose, nozzles, ladders, lighting equipment and pumps; and	1. Available 2. Available (2 Nos) 3. Available 4. Available	• At least 2 spare cylinders required for each SCBA set.

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	4. Communication facility at fire station, walkie talkie sets during firefighting.		
	C-21.2 Built in Safety in Civil Design and Construction		
305.	Whether the two safe means of escape available? Are they in separate directions?	Two safe means of escape available in separate directions.	---
306.	Is emergency exits provided to the building handling flammables?	Emergency exits provided to the building handling flammables.	---
307.	Whether emergency lights are provided?	Lights available with emergency power arrangement i.e., DG set	---
308.	Whether fire / smoke detectors are installed in fire prone areas?	Fire detector system was installed at fire prone areas.	---
309.	Whether fire call points are provided in different areas?	Fire call points were provided.	---
310.	Whether Fire hydrants are provided near the buildings?	Fire hydrants system available.	---
311.	Is ventilation system in plant handling flammables is adequate to prevent formation of flammable mixtures?	Storage of flammable material was not available.	---
312.	Is adequate separation is provided between combustible / flammable materials and other material to restrict the fire growth?	Adequate separation was provided between combustible / flammable materials and other material to restrict the fire growth.	---
313.	Access routes for firefighting operations is available for areas having high fire load	Access routes for firefighting operations was available for areas having high fire load.	---
314.	Whether building changes interferes with fire detection and / or fire suppression systems?	No changes made in building and No Suppression System available.	---
315.	Whether building changes cause unreasonable fire loading / openings in the	No building changes cause unreasonable fire loading / openings in the fire rated walls.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	fire rated walls?		
	C-21.3 Built in Safety in Electric Circuits and Equipment		
316.	Are the electrical equipment in areas where flammables mixture is likely to be present of flame-proof type?	Data available with electrical department.	• Electrical equipment and fittings to be ensured as per IS: 5571/IS: 5572.
317.	Are lightning arrestors are provided to the buildings / structures storing flammable materials?	Lightning arrestors were provided to the buildings.	---
318.	Whether adequate bonding and grounding of electrical equipment / pipelines provided?	No material transferred by pipeline.	---
	C-21.4 Explosive Substances		
319.	Whether necessary license / approval taken from concerned statutory bodies?	No explosive substance used in factory.	---
320.	Whether systems for explosion suppression, high speed fire detection with deluge, sprinklers, explosion venting etc. are provided?	No explosive substance used in factory.	---
321.	Whether explosion resistant walls or barricades are provided around explosive storage?	No explosive substance used in factory.	---
322.	Whether explosive substance storage areas are restricted for entry?	No explosive substance used in factory.	---
323.	Whether only trained persons are handling explosive substances?	No explosive substance used in factory.	---
324.	Whether explosive substances are stored and transported in approved containers only?	No explosive substance used in factory.	---
325.	Whether electrical fixtures in areas handling explosives are	No explosive substance used in factory.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	explosion proof type?		
326.	Whether adequate measures are taken to prevent any sources of ignition where explosive substances are handled?	No explosive substance used in factory.	---
	C-21.5 Fire Safety in Handling Flammable and Explosive materials		
327.	Whether emergency procedure is available for control of leakage?	Emergency procedure was available for control of leakage.	---
328.	Whether emergency measures are displayed locally in case of accidental spillage / leakage?	Emergency measures was not displayed in case of accidental spillage / leakage.	---
329.	Whether facility is provided for safe drainage of combustible or flammable liquids in case of leakages?	Adequate measures provided.	---
330.	Whether highly flammable liquids are stored under inert atmosphere?	No	---
331.	Whether flammable storage tanks are provided with flame arrestors?	Flammable storage tank was not evident.	---
332.	Whether suitable PPEs are provided?	PPEs were provided.	---
	C-21.6 Fire Detection and Alarm System		
333.	What type of fire detection and alarm system provided?	Fire detection & alarm system were provided.	---
334.	Whether all fire prone areas of the plant are covered with fire detection system?	All fire prone areas of the plant were covered with fire detection system.	---
335.	Whether fire detection equipment and smoke alarms in good operating condition?	Fire detection & alarm system were provided.	---
336.	Whether the number of fire call points are adequate and free from obstruction?	Fire call points were provided.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
337.	Whether regular inspection / maintenance / testing of fire detection and alarm system carried out and records maintained	Fire detection & alarm system were provided.	---
338.	Whether any atmospheric monitoring is carried out for explosive mixture of gases or vapours?	Workplace monitoring was carried out.	---
339.	Whether emergency power supplies are provided to fire detection and fire alarm system?	DG Sets available for emergency power supplies.	---
340.	Whether smoke detectors are located considering ventilation pattern?	Smoke detector provided	---
341.	Whether annunciation of fire is local or in the control room or in both places?	Fire detection system was installed.	---
342.	Whether fire panel is constantly attended?	Fire detection system was installed.	---
	C-21.7 Passive and Active Fire Protection System		
343.	What are the passive fire protection measures available? (Barriers, doors, dampers etc.)	Passive fire protection measures were available. (Fire Door)	---
344.	Are the areas requiring fire barriers identified?	No	---
345.	Whether the fire barrier provided is of adequate ratings?	No, fire barrier was not provided.	---
346.	Whether ventilation ducts in flammable areas have been provided with isolation dampers of suitable fire rating?	Ventilation ducts in flammable areas was not available	---
347.	Whether sprinklers / deluge are installed wherever necessary?	No	---
348.	Whether regular inspection / maintenance / testing of fire protection system	Regular inspection of fire protection system was carried out and records were maintained.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	carried out and records maintained?		
	C-21.8 Fixed Fire Extinguishing System		
349.	What are the sources of firewater and whether they are dedicated to the fire extinguishing system?	Fire water storage tank available. Capacity: 2 Lakh Litter.	---
350.	Whether the capacity of dedicated water reservoir is adequate to supply to hydrants for minimum 2 h?	It was informed that capacity of the dedicated water was enough to supply water to hydrants for 2 hrs.	---
351.	Whether un-interrupted power supply is provided to the firewater pumps?	Un-interrupted power supply provided to the firewater pumps through express feeder with DG supply change over provision in case of power failure also diesel driven pump to supply water.	---
352.	Whether the extinguishing medium selected is appropriate to the class of fire (water, gaseous, foam, dry powder)?	Appropriate to the class of fire following fire extinguishing media available for firefighting.	---
353.	Whether fire hydrants layout is available?	Fire hydrants layout was available	---
354.	Whether additional (over minimum requirement) fire hoses, nozzles are available?	Additional (over minimum requirement) fire hoses, nozzles was available.	---
355.	Whether the hydrants lines are kept pressurized?	Fire Hydrant system kept pressurised	---
356.	Whether regular inspection / maintenance / testing of fixed fire extinguishing systems carried out and records maintained?	Regular inspection / maintenance / testing of fixed fire extinguishing systems i.e., Fire hydrant system, Hose reel hose etc. carried out as per standards and records maintained.	---
	C-21.9 Portable Fire Extinguishing System		
357.	Whether suitable type and numbers of fire extinguishers provided?	Suitable type and numbers of fire extinguishers were provided. Total Fire Extinguisher – 39 Nos.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
358.	Whether the fire extinguishers are located at conspicuous position and easily accessible? Are they fully charged and tagged?	The fire extinguishers were located at conspicuous position and easily accessible & they fully charged and tagged.	---
359.	Whether fire extinguishers periodically inspected, tested, refilled and records maintained?	Fire extinguishers inspected, tested, refilled by third party and records maintained.	---
360.	Whether defective / unchecked fire extinguishers present at site?	Defective fire extinguishers were not present at site	---
361.	Whether additional fire extinguishers are available?	Additional fire extinguishers were available.	---
	C-21.10 Fire Fighting Equipment and Facilities		
362.	Whether fire tenders (water / foam) are available?	Fire tender was not available in company.	---
363.	Whether the fire-fighting system and equipment approved, tested and maintained as per relevant standard?	Only Fire Extinguisher was available.	---
364.	Whether the SCBA / fire suit provided to firefighting team for fire action?	Fire suit available for fire action.	---
365.	What is system for maintenance/ recharge of SCBA?	SCBA set was available. 2 Nos.	• At least 2 spare cylinders required for each SCBA set.
366.	Is proper access available for fire-fighting equipment?	Proper access available for fire-fighting equipment.	---
367.	Whether fire hose cabinets are in good condition, easily visible, and accessible?	Only Fire Extinguisher was available.	---
368.	Whether drill tower is available? Are fire personnel carrying out regular fire drill?	Fire drill was carried out at regular interval.	---
369.	What is the	Communication facility at fire	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	communication facility at fire station? Is it adequate?	station: Mobile, telephone etc.	
	C-21.11 Fire Drill		
370.	Whether mock fire drills are conducted? What is the frequency of drills?	Mock fire drills were conducted. Frequency: - Quarterly Date: 19/02/2025	---
371.	Whether fire drills are also performed in night Shift?	Fire drills was performed in night shift.	---
372.	Whether feedback of fire drill is documented?	Feedback of fire drill documented, and action taken accordingly	---
373.	What is the system of mutual-aid scheme?	Mutual aid agreements with nearby fire stations.	---
	C-21.12 Fire Fighting Training		
374.	Whether there is a system of providing fire-fighting training to plant personnel?	Yes, system of providing firefighting training to plant personnel was available.	---
375.	What is the frequency and duration of such training? Whether training records are maintained?	At regular frequency (As per HSE training planning) firefighting training was provided and its record maintained.	---
376.	Whether fire squads are identified for different areas for first-aid firefighting and rescue, and suitably trained?	Fire squads were identified (by sticker on helmet) for different areas & first-aid firefighting and rescue, and suitably trained.	---
377.	Are all personnel conversant with the fire prevention and protection measures?	Personnel conversant with the fire prevention and protection measures.	---
378.	Whether the fire staff are sent for refresher / advanced training courses?	Firefighting training was given internally.	• Firefighting training should be Carried out by Third Party
	C-21.13 Static Electricity and Lightning		
379.	Whether all vessels and pipes are provided with suitable bonding and grounding?	Flammable material was not transferred by pipeline.	---
380.	Whether arrangement has been made for grounding the tanker	Flammable material was not transferred by pipeline.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	containing flammable liquid during loading / unloading?		
381.	Whether spark resistant tools are provided?	Spark resistant tools were not provided.	• Spark resistant tools to be provided as & when required.
382.	Whether lightning protection is provided and is adequate?	02 Nos. of Lightning protection was provided.	• Lightning arrestor survey to be carried out.
383.	Whether antistatic clothing, hand gloves and footwear are provided?	Suitable PPEs were provided as and when required.	---
	C-21.14 Pressure Relief System		
384.	Whether the listing of all 'pressure plants' [as defined under Factories Act] has been done?	Pressure plant area identified, and pressure plant list maintained.	---
	C-22 INDUSTRIAL HYGIENE / OCCUPATIONAL HEALTH		
	C-22.1 Ventilation, Illumination, Noise, Vibration, Heat stress and Non-ionizing Radiations		
	C-22.1.1 Ventilation		
385.	Whether any ventilation study has been carried out?	Ventilation study was carried out by third party.	---
386.	Whether natural ventilation is adequate or not?	Natural ventilation was adequate in plant.	---
387.	Whether dust / fumes / hot air is generated in the process?	Dust were generated in the process.	---
388.	Is there any exhaust ventilation system in any section of the plant?	Natural ventilation system in plant.	---
389.	Is periodic / preventive maintenance of ventilation system carried out and record is maintained?	As natural ventilation so, no such records was evident.	---
390.	Does any ventilation system re-circulate the exhausted air in work areas?	Natural ventilation system in plant.	---
391.	Is the work environment assessed and monitored for chemical and physical hazards?	The work environment assessed and monitored for chemical and physical hazards.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
392.	Whether PPE are provided to workers exposed to dust / fumes and gases?	Adequate PPEs provided to workers	---
	C-22.1.2 Illumination		
393.	Whether illumination study has been carried out for the assessment of illumination level?	Illumination study was carried out by third party and records maintained.	---
394.	Is there any system of periodical cleaning and replacing the light fittings / lamps in order to ensure that they give the intended illumination levels?	PM System available for periodical cleaning and replacement of the light fittings / lamps in order to ensure that they give the intended illumination levels.	---
395.	Are the workers subject to periodic optometry tests and records maintained?	Periodic optometry test was carried out for the workers.	---
396.	Are emergency lighting available at first aid centre?	Emergency light was Available.	---
	C-22.1.3 Noise		
397.	Whether any noise study conducted?	Noise study conducted externally by third party.	---
398.	Are there any machines / processes generating high-noise?	High noise area i.e., DG Set	---
399.	Whether engineering and administrative controls been implemented to reduce noise exposure below the permissible limits?	Engineering and administrative controls been implemented to reduce noise exposure below the permissible limits	---
400.	Is there a system of subjecting all those employees to periodic audiometric test who work in high- level noise areas?	Periodic Audiometric test was carried out for high level noise area.	---
401.	Whether the workers are made aware of the ill effects of high noise?	Workers were aware of ill effects of high noise.	---
402.	Whether earmuffs / plugs are provided and used?	Earmuffs / plugs were provided and used.	---
	C-22.1.4 Vibration		

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
403.	Are there equipment which contributes excess level of vibrations and whether they are identified?	No such equipment was found during audit period.	---
404.	Whether any vibration study has been carried out?	Vibrations study was not carried out.	---
405.	Are the measures taken to combat vibration to acceptable levels?	Adequate measures provided to combat vibration to acceptable level.	---
406.	What is the frequency for measurements of vibration?	Vibrations study was not carried out.	---
407.	Are the records of measurements and maintenance of equipment / system maintained?	Records of equipment / system maintenance was maintained.	---
	C-22.1.5 Heat Stress / Cold stress (Extremes of Temperature)		
408.	Are there sources from equipment increasing the heat load in workplaces?	No such source available	---
409.	Whether evaluation of heat stress is carried out?	Heat stress evaluation was not carried out	---
410.	Whether natural ventilation is adequate to minimize the heat stress in work environment?	Natural ventilation was adequate to minimize the heat stress in work environment. Ventilation system provided.	---
411.	Are resources available to deal with very hot or very cold conditions (drinking water, lined gloves, insulated boots)?	Appropriate PPEs, cold drinking water were provided. Proper engineering control & Administrative control made available	---
412.	Do workers know the symptoms of heat cramps / heatstroke or frost bite / hypothermia?	Workers know the symptoms of heat cramps / heatstroke.	---
413.	Are the personal protective equipment suitable for reducing the effects of heat stress available?	We came to know that the personal protective equipment suitable for reducing the effects of heat stress provided as & when required.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	C-22.1.6 Non-ionizing Radiations		
414.	Does the work involve likely exposure to non-ionising radiations (ultraviolet, infrared, radiofrequency, microwaves, lasers, etc.)	We came to know that non-ionizing radiations material was not stored /used in premises.	---
415.	Whether risk assessment have been done for all work areas involving presence of non-ionising radiations?	Not Applicable	---
416.	Are the work areas displayed with relevant safety signs?	Not Applicable	---
417.	Are the employees aware about the hazards of non-ionising radiations?	Not Applicable	---
418.	Do written procedures exists for working in non-ionising radiations?	Not Applicable	---
419.	Is the work environment monitored periodically for physical hazards and control measures initiated whenever deviation from permissible values is observed?	Not Applicable	---
420.	Whether suitable personal protective equipment are provided to workers exposed to non-ionising radiations?	Not Applicable	---
	C-22.2 Workplace Monitoring for Hazardous Chemicals		
421.	Whether the dust, fumes, smoke, aerosols and mist are monitored as per statute and records maintained?	Workplace monitoring was carried out and records were maintained.	---
422.	What are the types of detectors used for monitoring concentration of hazardous chemicals?	Detectors were available for monitoring concentration of hazardous chemicals.	---
423.	Is any alarm system installed for any leakage	Alarm system available in case of leakage	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	of hazardous chemicals?		
424.	Are antidotes available for toxic chemicals?	Toxic material was not used.	---
425.	Are control measures initiated whenever deviation from permissible values is observed?	Adequate control measures provided whenever deviation from permissible values is observed.	---
	C-22.3 First Aid Facilities and Occupational Health Centre (OHC)		
426.	Are adequate numbers of first aid boxes provided? Give location details?	First Aid Box: 4 Nos. List available with concern department.	---
427.	Are qualified / trained first aiders available in each shift?	Total First Aider: 5 Nos. Qualified & trained first aiders available in each shift.	---
428.	How many qualified / trained first aiders are available at each plant / department?	Total 5 nos. of qualified & trained first aiders available.	• First Aider Training should be Carried out in regular interval.
429.	How many persons are trained / given refreshers training in first aid in a year?	5 nos. persons were trained in first aid.	---
430.	Whether occupational health centre is provided?	Occupational health centre provided at factory	---
431.	Does OHC conform to the provisions of the existing statutes?	Occupational health centre provided at factory	---
432.	Are the Medical Attendants / Doctors available in each shift?	Full time FMO available. Trained First aider available – round the clock.	---
433.	What facilities are available for transportation of the injured to hospital?	Dedicated vehicle was available for Emergency.	---
434.	Are the names of the trained first aiders displayed?	List of first aider was displayed.	---
435.	Are the name of nearest hospitals and its telephone number available in OHC?	Name of nearest hospitals and its telephone number available with HSE and Reception and Security.	---
436.	Does the plant have any special preventive medicine program?	Plant have not conducted special preventive medicine program	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
437.	Is ambulance posted in proper place and is it available whenever required?	Ambulance was available in the factory premises Emergency vehicle posted in proper place and is it available whenever required.	---
438.	Are sufficient numbers of anti-dotes available in case of any emergency?	Sufficient numbers of anti-dotes was not available in case of any emergency. (No chemical storage)	---
439.	Are fire safety measures provided in first aid centre?	Fire Extinguisher was provided in first aid centre.	---
440.	Are emergency lighting arrangements available at first aid centre?	Emergency light was available at first aid centre.	---
	C-22.4 Periodic Medical Examination		
441.	Whether the periodical medical examination of employees, required under relevant statute is carried out?	The periodical medical examination (Form No. 32) of employees, required under relevant statute was carried out.	---
442.	Whether it is ensured that contractors employee are medically examined during pre-employment as well as during the course of employment?	It was found that contractor's employee was medically examined during pre-employment as well as during the course of employment.	---
443.	During the periodical medical examination of the workers, are they examined as per the hazardous process in which they work? (First schedule of The Factories Act, 1948)	During the periodical medical examination of the workers, were they examined as per the hazardous process in which they work. (First schedule of The Factories Act, 1948).	---
444.	Are the records of all such examination maintained?	Records of all such examination was maintained	---
	C-22.5 Personal Protective Equipment and Emergency Equipment		
445.	Whether list of required PPEs for each hazardous activity is available?	PPE matrix available for each plant.	---
446.	Whether feedback from workers obtained during selection of PPE?	Feedback of workers was obtained during selection of PPE.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
447.	Have the workers been trained in proper use of PPE including BA sets?	Training on use of PPE was imparted to workers and records were maintained.	---
448.	What is the system of procurement, inspection, issue, maintenance and replacement of PPE?	SOP was available for system of procurement, inspection, issue, maintenance and replacement of PPE.	---
449.	Whether qualitative and quantitative fit-check for respirators is ensured prior to use?	Qualitative and quantitative fit-check for respirators was ensured prior to use.	---
450.	What are the arrangements for safe custody and storage of PPE?	Locker provided for safe custody and storage of PPE.	---
451.	Are the contractor's workers provided with the required PPE?	Contractor's workers provided with the required PPE.	---
452.	Do the PPE conform to any standard?	PPE conform by IS standard.	---
453.	Are sufficient eye wash fountains and safety showers available?	Eye wash fountains and safety showers were available.	---
454.	Whether appropriate respiratory protective devices are available in accordance to the hazard potential?	Appropriate respiratory protective devices Air lines were available in accordance with the hazard potential.	---
455.	Are the staff members trained in the right uses of respiratory protective devices?	Staff members trained in the right uses of respiratory protective devices.	---
	C-22.6 Occupational Diseases		
456.	Whether pre-employment medical check-up data available?	Pre-employment medical check-up data available. (Form No. 33 available)	---
457.	During the medical check-up, is any person found having occupational diseases mentioned in 3rd schedule of The Factories Act, 1948?	During the medical check-up, any person not found having occupational diseases mentioned in 3rd schedule of The Factories Act, 1948	---
458.	Whether the medical practitioner informed the Chief Inspector of	NAD (No abnormality detected) during periodic medical examination of	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	Factories about the occurrence of the occupational disease?	workers.	
	C-23 Accident / Incident Reporting, Investigation and Analysis		
	C-23.1 Accident Reporting and Database Management		
459.	What is the procedure for accident / incident /dangerous occurrence reporting?	Procedure available for accident / incident /dangerous occurrence reporting.	---
460.	Whether the accident data for the last five years for reportable and non-reportable accidents are available?	Accident data for the last ten years for reportable and non-reportable were available at HSE department.	---
	C-23.2 Accident Investigation		
461.	Are all the accidents investigated?	All reportable and non-reportable accident were investigated.	---
462.	Whether accident investigation procedure is documented?	Accident investigation procedure was available.	---
463.	Whether accident investigation reports are submitted to top management?	Accident investigation reports was submitted to top management.	---
464.	How are the findings from accident investigation reports communicated to workers?	HSE Notice board was available for findings from accident investigation reports communicated to workers.	---
	C-23.3 Analysis of Accidents		
465.	Whether accident analysis is done as per IS 3786?	Accident analysis was evident.	---
466.	Whether root causes of accidents are analysed?	Root causes of accidents were analysed	---
467.	Is the accident statistics effectively utilized? If yes, how?	The accident statistics was effectively utilized	---
468.	What nature of injuries occurred during the last five years?	Data available with HSE department.	---
	C-23.4 Implementation of Recommendations		
469.	How does the management ensure implementation of the recommendations to avoid recurrence of	Recommendation reviewed in the monthly review meetings and also tracking through system.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	accidents and incidents?		
	C-23.5 Reporting and Investigation of Near miss Incidents		
470.	Are all near-miss incidents reported and investigated?	Near-miss reporting system was available. (Online system – company incident portal available)	---
471.	Is there any system of classifying and analysing the near-miss incidents?	Online system – company incident portal available for classifying and analysing the near-miss incidents.	---
	C-24 EMERGENCY PREPAREDNESS		
	C-24.1 Site Specific Details		
472.	Are the site area maps (including layout, access roads and assembly points) available in control room / emergency control centre?	The site area maps (including layout, access roads and assembly points) was available. Plant layout displayed in factory.	---
	C-24.2 Duties and Responsibilities of Key Personnel		
473.	Is the hierarchy of emergency response personnel right from site emergency controller downward, and alternative officials identified?	The hierarchy of emergency response personnel right from site emergency controller downward, and alternative officials was identified. (Ref.: - On-site emergency plan)	---
474.	Are the duties and responsibilities assigned to the designated officials during emergency, both during and outside normal working hours clearly identified and understood by them?	Duties and responsibilities assigned to the designated officials during emergency, both during and outside normal working hours clearly identified and understood by them. (Ref.: On-site emergency plan)	---
	C-24.3 Identification of Emergencies and Accident Scenario		
475.	Are the possible accident scenarios leading to emergency identified and known to the operating personnel?	All possible accident scenarios leading to emergency identified and known to the operating personnel. (Ref.: - On-site emergency plan)	---
476.	Are approved emergency preparedness plans (on-site and off-site) in	Approved emergency preparedness plans (on- site emergency plan) was available.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	place?		
	C-24.4 Declaration and Termination of Emergency		
477.	Is the list of designated officials who are to be communicated about declaration and termination of emergency available in the control room / emergency control centre?	The list of designated officials who are to be communicated about declaration and termination of emergency available in the control room / emergency control centre. (Ref.: On-site emergency plan)	---
478.	Are the methods of communication (siren, public address system etc.) for declaration and termination of an emergency known to all the workers?	Siren, was available for declaration and termination of an emergency known to all the workers.	---
	C-24.5 Resources-evacuation / Transport		
479.	Are the following resources (equipment, personnel and procedures) required to handle emergency available? 1. Communications, 2. Public announcement systems 3. Monitoring of hazardous releases into the environment, 4. Emergency shelters at the facility, 5. Emergency exits with proper illumination, with uninterrupted power supply, 6. Direction for emergency exit / escape route marked in haulage / Alleyways, 7. Transport for evacuation of plant personnel,	Following resources are available to handle emergency available: - 1. Available 2. Not Available 3. Not Available 4. Available 5. Available 6. Available 7. Available 8. Available 9. Available	• Necessary all resources to be made available to handle emergency.

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	8. Medical care including administration of antidotes, and 9. Security / maintenance of law and order.		
	C-24.6 Communication Facilities		
480.	Does the emergency control centre have direct communication links with the fire station and the plant control room?	Following communication system was available. Mobile Phone, etc.	---
481.	Are there adequate alarm points from which an emergency alarm can be raised?	Only siren available	---
482.	Is there infrastructure available for ensuring backup electric power supply for communication links where required	DG set available for ensuring backup electric power supply for communication links where required.	---
	C-24.7 Medical Care		
483.	Is the procedure for emergency medical care available?	Emergency medical care (OHC) available at factory Unit-5. & Mutual aid with Haria Hospital, Vapi	---
484.	Whether the system has been tested at regular frequency through mock drill / exercises for its adequacy?	Fire mock drill was carried out every month. Every 3 monthly – Fire Drill	---
485.	Does the system of periodic replacement of antidotes and medicines required in emergency exist?	System of periodic replacement of medicines required in emergency was available.	---
	C-24.8 Updation of Emergency Plan		
486.	Is the emergency plan updated based on the feedback from the periodic drills / exercises?	Emergency plan (On-site emergency plan) available and updated based on the feedback from the periodic drills. Last updated – 11/11/2024	---
487.	Are the contact details of	Most of all contact details of	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	all concerned officials kept updated in the emergency plan?	all concerned officials kept updated in the emergency plan	
	C-24.9 Periodic Drills / Exercises		
488.	Are mock exercises conducted at stipulated intervals?	Mock-exercises conducted at month interval.	---
489.	Are the scenarios varied in the mock-exercises to ensure that all possible factors including meteorological conditions, affected plant personnel covered?	Scenarios varied in the mock-exercises done that all possible factors including meteorological conditions, affected plant personnel covered. Ref.: On-site Emergency plan	---
490.	Whether emergency preparedness Plans have been tested and reviewed at regular frequency through mock drill for its adequacy	Emergency preparedness Plans have been tested and reviewed at regular frequency through mock drill. Last Updated: - 19/12/2025	---
	C-24.10 Training of Plant Personnel		
491.	Are the plant personnel trained in handling emergency equipment?	Most of plant personnel trained in handling emergency equipment	---
	C-24.11 Public Awareness Programme		
492.	Are public awareness programs conducted for the people around the site regarding the actions to be taken in case of off-site emergency?	We came to know public awareness programs conducted for the people around the site regarding the actions to be taken in case of off-site emergency.	---
	C-24.12 Mutual-aid Program		
493.	Are the types of accidents where external organizations would be involved in remedial actions identified? Are their responsibilities defined?	We came to know that all types of accidents where external organizations would be involved in remedial actions identified. Their responsibilities were also defined in emergency plan.	---
494.	Is the plant responsible for rendering mutual aid assistance to any other external organizations? Does this assistance effect the plant's emergency	Plant responsible for rendering mutual aid assistance to any other external organizations. This assistance did not affect the plant's emergency preparedness	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	preparedness?		
495.	Whether the communication channels for mutual assistance identified and known with and between two organizations?	The communication channels (Telephone / Mobile) for mutual assistance identified and known with and between two organizations	---
	C-24.13 Emergency Control Centre		
496.	Is the emergency control centre located beyond the effective distances of identified emergency scenarios?	Emergency control centre was located beyond the effective distances of identified emergency scenarios.	---
497.	If the emergency control centre is located within the effect distance, is it suitably protected that it will be available in case of emergency?	The emergency control centre was located within the effect distance, it is suitably protected that it will be available in case of emergency.	---
	C-25 Safety Inspection		
	C-25.1 Inspection Programme		
498.	Are checklists available for inspections? For example, availability of checklists like: a. Handling, Storage and Transportation of hazardous chemicals; b. Electrical hazards; c. Fire safety; d. Hand and portable power tools; e. Machine hazards; f. Lifting equipment; g. Ladders and scaffolding; h. Environmental Monitoring; i. Civil structure; j. Housekeeping; k. Emergency equipment; and l. Gas cylinder and other pressure vessels used /available in the organization.	We came to know that most of said Checklist was available.	• Ensure that all said checklist available and maintained.
	C-25.2 Safety Related Deficiency (SRD) Report		
499.	Are SRDs generated based on the area wise	Safety related deficiency was generated informally.	---

Sr. No.	Checkpoints	Current Status / Observation	Recommendations
	checklists?		
500.	What is the procedure for resolving the SRDs?	Informal procedure was available.	---
501.	Whether the procedure exists for notification and root cause analysis of non-conformities and action taken on them?	Root cause analysis of non-conformities was carried out and action taken on them.	---
	C-25.3 Safety Inspection Records		
502.	Are the safety inspection records maintained?	Safety inspection records were evident.	---
	C-25.4 Methodology and Inspection Team		
503.	Is there written procedure for safety inspection?	Informal procedure available. Checklist was also available for inspection.	---
504.	Whether safety inspection is carried out by a designated team?	Safety inspection is carried out daily by a Safety team	---
505.	What is the frequency of safety inspections?	Safety inspection carried out at regular frequency (Daily).	---
506.	Whether an inspection report is generated?	An inspection report was generated	---
	C-25.5 Compliance of Recommendations		
507.	To whom the recommendations are submitted	Recommendations were submitted to all HOD, Unit Head, Corporate Head (HSE) & Concern person.	---
508.	Are recommendations of safety inspections complied in time?	Recommendations of safety inspections complied in time bound manner.	---
509.	Is compliance of recommendations sent to top management?	Compliance of recommendation sent to top management.	---
510.	Is compliance of recommendations reviewed by safety committee?	Compliance of recommendations reviewed by safety committee	---
511.	Does top management follows-up the compliance?	Top management follows-up the compliance	---
512.	Is compliance of recommendations sent to top management?	Compliance of recommendation sent to top management.	---

END OF REPORT