

South/South-West Coast Website Generated Results

Room cases: 50 to 500 rooms. Assumptions follow the Excel-aligned website calculation: 92% occupancy, 50 kWh/room/day, laundry Yes, Gliricidia 12 LKR/kg, 2026 export tariff schedule, 20-year NPV/IRR metric range.

Rooms	IRR (%)	NPV (LKR M)	Turbine (kW)	Chiller (RT)	Payback (y)
50	13.50	29.39 M	250	200	10.25
100	6.78	-128.61 M	350	300	19.16
150	5.84	-207.71 M	500	400	21.33
200	2.24	-365.71 M	600	500	34.28
250	4.58	-390.57 M	800	650	24.89
300	6.14	-390.77 M	1,000	750	20.63
350	8.08	-336.72 M	1,250	900	16.69
400	3.89	-652.52 M	1,250	1,000	27.21
450	5.65	-647.80 M	1,500	1,250	21.81
500	2.24	-914.28 M	1,500	1,250	34.28

Generated from local webapp calculation engine. No application code was changed to create this PDF.