Machine Inspection Report: Turbine Generator A

Date: 2026-10-10 20:58:22

Metric	Value
Status	completed
Anomaly Flag	Warning
Dominant Frequency	48.20 Hz
Amplitude (px)	14.50
RMS (px)	8.90

Recommendation & Next Steps:

URGENT: Anomaly detected. Schedule maintenance immediately to inspect for wear and tear or misalignments.