

**To,**

**M/s Mangalam Techno Air Equipments Pvt Ltd**

Please clarify following:

| Sr. No | Specs reference | Clarification required  | Response from bidder<br>(responses like “confirm”, “Yes”, “Agree” etc. are not acceptable) |
|--------|-----------------|---|--|
| 1      | B (i)           | <p>The bidder/ manufacturer should have a proven record of manufacturing &amp; supply of chiller of similar capacity. The supplier should enclose a list of clients in India where chillers of similar capacity have been supplied in last three years.</p> <p>Bidder to reply to the above and attach purchase order proving their experience in manufacturing “Air cooled chiller unit of 100 TR capacity or more”</p> <p><i>Experience of Cooling towers shall not be considered</i></p> | PO.no BTE/2025/26-141,<br>document attached  |
| 2      | B (iv)          | <p>The manufacturer should have testing facility at their works which should be AHRI certified and electrical power and thermal load availability for testing of the chiller to full capacity should be available. The same should be clearly confirmed in the bid.</p> <p>Bidder to reply to the above mentioning the specification of the test facility</p>   | Request letter attached  |
| 3      | C               | <p>List of documents to be submitted with offer</p> <p>Bidder to reply to the above attaching documents requested in C.(i) to C.(iv)</p>  | Document attached  |
| 4      | Annexure-A      | <p>Bidder to re-send the compliance table with values as requested instead of “Confirm” and “Comply”</p>  | Document attached  |