Burners

When the level inside the tank reach to level switch low and temperature transmitter interface is not activated then burner ready to start working, as same in level switch low and other tanks treating.

Case	Cause	Effect
1	1. Low /Low level Is ON. 2. Temperature < 70 C°.	• Burner will be Switched ON. • Burner is controlled from PLC.
2	1. Low /Low level is ON. 2. Temperature >= 70 C°.	• Burners in the corresponding tank will be Switched Off. • Burner is controlled from PLC.
3	1. Low or Low level is off. 2. Temperature < 70 C°.	• Corresponding Burner will be Switched Off. • Burner is controlled from PLC.
6	1. Low or Low level is off. 2. Temperature < 70 C°.	• Corresponding Burner will be Switched Off. • Burner is controlled from PLC.

Note:

You can change the temperature setpoint from SCADA to another specific value.



CamScanner