



دار العمران
DAR AL OMRAN
RASEM BADRAN



مؤسسة الملك فيصل
KING FAISAL FOUNDATION



UNITED
ENGINEERING
CONSTRUCTION
EST. 1976
الهندسة
الإنشائية

ORIGINAL

PROJECT: King Faisal Palace Renovation Project

CONTRACTOR: United Engineering Construction

TRANSMITTAL FORM

To: Dar Al-Omran				From: UNEC	
AR		ME		Submittal No. KFPRP-UNC-MAR-ELE-0066	
ST		ELE	✓	☒ New submittal	
CE		GEN		☐ Re-submittal	
Contract Drawing No.				Date: - 25-03-2025	

Certificates	☒	Operations & Maintenance Manual	☐	Test Results	☐
Technical Brochure	☒	Spare Parts List	☐	Calculations	☐
Manufacture's Data & Specs.	☒	As Built Drawing	☐	Proposals	☐
Samples	☐	Warranty	☐	Others	☒

Description:

Material Submittal for Fire Alarm System.

Supplier – EJTech.

Manufacturer- ESSER by Honeywell.

Contractors Remarks:

(STAMP)

Electrical Engineer
Khaled albayoumi

Signature:

Date:

For approval.

Consultant Comments:

See attachment

(STAMP)

Project Manager
Signature

Date:

Approval Code:

A = Approved

B = Approved as noted

C = Approved as noted-resubmit

D = Disapproved

E = No action taken



C.R.1010423886

Project: King Faisal Palace Renovation

6:00 RECEIVED: 25 / 03 / 2025

11:30 DELIVERED: 27 / 03 / 2025



دار العمارة
DAR AL OMRAN
RASEM BADRAN



مؤسسة الملك فيصل الخيرية
KING FAISAL FOUNDATION



UNITED
ENGINEERING
CONSTRUCTION
EST. 1976
الاتحاد
الهندسة
الإنشائية

PROJECT: King Faisal Palace Renovation Project

CONTRACTOR: United Engineering Construction

ATTACHMENT TO SUBMITTAL

Submittal No. KFPRP-UNC-MAR-ELE-0066

Submittal Date: 25-03-2025

Consultant's Comments:

- ⊗ All material list shall comply w/proj. BOD description
- ⊗ Cont. shall fully comply w/proj. (specs & Reg.)
- ⊗ All material shall be certified by Saudi civil defense
- ⊗ Riser diagrams shall be appd separately
- ⊗ provide Confirmation that ESSER devices comply w/LPC (UL)
- ~~⊗ All material shall be as per appd in sub. spec.~~

Date: 27/03/2025

Signed by:

Client's Comments (If any):

Date:

Client's Representative: