

**SECTION 1: BUILDING DESCRIPTION****1.2 BUILDING NO. 01****MEZZANINE FLOORS****1.2.1 BUILDING NO. 01****AREA NO. 01****MEZZANINES****A. Maimaar standard mezzanine:**

Supply normally includes support **columns**, primary **beams**, secondary **joists** and a **0.7mm galvanized steel deck** that supports a **reinforced** concrete slab (slab by others). The steel deck acts as a shuttering that carries the weight of the slab during construction only. The concrete slab must contain steel reinforcements and must be designed by a structural engineer to support all the applied loads on the mezzanine. Please refer to Maimaar's "MEZZANINES" brochure for more details of standard Mezzanine.

B. Mezzanine with Precast slab or hollow core slab supplied by others:

No deck is supplied in this option. Steel columns, primary beams and some connecting joists are supplied.

- Exterior Mezzanine joists and beams in this area are designed to support blockwall loads:

No

- Interior Mezzanine joists and beams in this area are designed to support blockwall loads:

No

- 1.10 m high industrial handrail is provided at free ends of mezzanine:

No**Spacing of Mezzanine columns:**

Sr. No.	Mezzanine Loads (kN/m ²)				Area (m ²)	Type of Floor & Thk. (mm)	Minimum Clear Heights (m)		
	Dead*	Live	Collateral	Other			From FFL to Bottom of Mezz. Beam	From Top of Concrete Slab to bottom of Rafter / Beam	From FFL to Top of Concrete Slab
1	As per design	5.00	0.00	0.00	136	A (100)	4.876	-	-
2	As per design	5.00	0.00	0.00	540	A (100)	4.876	-	-

* - Dead Load includes the Self Weight of (Floor + Floor Finish + Steel Deck Panel, if applicable + Joist)

SECTION 2: PANEL DESCRIPTION**2.1 BUILDING NO. 01****2.1.1 BUILDING NO. 01****AREA NO. 01****ROOF AND WALL PANELS** (For buildings, lean-to's, roof extensions, canopies & roof monitors)

Single Skin	Profile	Standard
	Material	0.5mm PPGI Panels + 50mm Fiberglass Insulation + 0.5mm PPGI Liner Panels
	Finish	Polyester Pre-Painted
	Color	Maimaar Standard

Note: Liner panels are provided only in the workshop area (GL 1-5). There is no liner panel in the showroom area i.e. Between GL 5-10