



DISABLE TOILET GENERAL NOTES

DISABLE TOILET TO HAVE A BACKSEAT 355mm x 190mm INSTALLED 150mm FROM TOP OF SEAT AS PER AS 1428.1 - 2009 SECTION 15.2.4

DISABLE TOILET TO HAVE A FOLD DOWN SEAT TO ALLOW SHOWERS 1000mm x 400mm. SEAT TO BE 40mm FROM BRICKWORK AND TO BE INSTALLED AS PER AS 1428.1 - 2009 15.5.9

THE CROSS SECTION OF HANDRAILS SHALL BE CIRCULAR, NOT LESS THAN 30mm NO MORE THAN 50mm DIA.

2000mm x 2000mm NON-SLIP TILES TO BE USED

THE HOT WATER SYSTEM INSTALLED ABOVE THE CEILING FIXED TO CONCRETE PANEL

THE CEILING HEIGHT IS TO BE 2700mm HIGH

THE EXHAUST FAN WILL BE INSTALLED IN A LOCATION THAT WILL ALLOW ACCESS FOR THE PLUMBER TO INSTALL THE EXHAUST STACK.

90mm STUD WALL LINED WITH 10mm AQUACHEK INTERNALLY AND STD. GYPROCK EXTERNALLY. DISABLED WC TO COMPLY WITH A.S 1428.1 TILED FLOOR WITH FALL TO WASTE CATCH.

