

LECO BULK METER TEST REPORT

Report No: VERT-2025-001	Date of Test: 2025-01-15	Branch: GAL	CSC: TEST	Location: True Vertical Layout																																																																					
A/C No: 12345	Reason: routine	Contract Demand: 1000	Request ID: REQ001	Substation No: SUB001																																																																					
<div>Current Transformer</div> <div>Make: Test CT Manufacturer</div> <div>Ratio: 100/5</div> <div>Static Meter</div> <div>Make: Test Meter Manufacturer</div> <div>Serial No: SN123456789</div> <div>Meter Constant: 1000</div> <div>Class: 1.0</div> <div>Meter Current: 5A</div> <div>Meter Voltage: 230V</div> <div>Tester Make: Test Tester Manufacturer</div> <div>Tester Serial No: TSN789012345</div> <div>Check</div> <div>Physical Condition of the Meter: Good</div> <div>CT Ratio: 100/5</div> <div>Meter Ratio: 100/5</div> <div>Multiplying Factor: 1</div> <div>Connection of Meter Elements: 3ph4w</div> <div>Phase Sequence: Correct</div> <div>CT Earthing: Yes</div> <div>%Error as Found: 0.5</div> <div>%Error as Left: 0.2</div> <div>Phases</div> <table><tr><td>Phases</td><td>R</td><td>Y</td><td>B</td></tr><tr><td>Voltage(V)</td><td>230.5</td><td>231.2</td><td>229.8</td></tr><tr><td>Current(A) Primary</td><td>100.5</td><td>95.2</td><td>105.8</td></tr><tr><td>Current(A) Secondary</td><td>5.025</td><td>4.76</td><td>5.29</td></tr></table> <div>Measureings</div> <table><tr><td rowspan="2">Measuring Points</td><td colspan="2">Total</td><td colspan="2">Rate A</td><td colspan="2">Rate B</td><td colspan="2">Rate C</td></tr><tr><td>Import</td><td>Export</td><td>Import</td><td>Export</td><td>Import</td><td>Export</td><td>Import</td><td>Export</td></tr><tr><td>Energy kWh</td><td>1000.123</td><td>50.456</td><td>300.789</td><td>10.123</td><td>350.456</td><td>15.789</td><td>350.123</td><td>25.456</td></tr><tr><td>Demand kVA</td><td>500.123</td><td>25.456</td><td>150.789</td><td>5.123</td><td>175.456</td><td>8.789</td><td>175.123</td><td>12.456</td></tr><tr><td>R.Energy kVArh</td><td>200.123</td><td>10.456</td><td>60.789</td><td>2.123</td><td>70.456</td><td>3.789</td><td>70.123</td><td>5.456</td></tr><tr><td>Average Power Factor</td><td>0.950</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr></table> <div>Comments</div> <div>Comments: This is a comprehensive test report for the true vertical PDF layout. The layout should now flow vertically down the page, utilizing the full height of the A4 sheet with proper spacing and professional appearance. All sections should be clearly separated and easy to read.</div>					Phases	R	Y	B	Voltage(V)	230.5	231.2	229.8	Current(A) Primary	100.5	95.2	105.8	Current(A) Secondary	5.025	4.76	5.29	Measuring Points	Total		Rate A		Rate B		Rate C		Import	Export	Import	Export	Import	Export	Import	Export	Energy kWh	1000.123	50.456	300.789	10.123	350.456	15.789	350.123	25.456	Demand kVA	500.123	25.456	150.789	5.123	175.456	8.789	175.123	12.456	R.Energy kVArh	200.123	10.456	60.789	2.123	70.456	3.789	70.123	5.456	Average Power Factor	0.950							
Phases	R	Y	B																																																																						
Voltage(V)	230.5	231.2	229.8																																																																						
Current(A) Primary	100.5	95.2	105.8																																																																						
Current(A) Secondary	5.025	4.76	5.29																																																																						
Measuring Points	Total		Rate A		Rate B		Rate C																																																																		
	Import	Export	Import	Export	Import	Export	Import	Export																																																																	
Energy kWh	1000.123	50.456	300.789	10.123	350.456	15.789	350.123	25.456																																																																	
Demand kVA	500.123	25.456	150.789	5.123	175.456	8.789	175.123	12.456																																																																	
R.Energy kVArh	200.123	10.456	60.789	2.123	70.456	3.789	70.123	5.456																																																																	
Average Power Factor	0.950																																																																								

Signatures

Technical Officer

Chief Engineer-SGS

