

LECO BULK METER TEST REPORT - PROFESSIONAL

Report No:	Branch:	Location:	A/C No:	Contract Demand:																				
Date of Tested:	CSC:	Substation No:	Reason:	Request ID:																				
SAMPLE-202509-0001	gal	Sample Location	ACC-001	1000 kVA																				
Current Transformer Make: ABB Ratio: 100/5		Static Meter Make: Schneider Electric Serial No: SE-123456 Meter Constant: 3200 Class: 1.0 Meter Current: 5A Meter Voltage: 230V																						
Check Physical Condition of the Meter: Good CT Ratio: 100/5 Meter Ratio: 100/5 Multiplying Factor: 1 Connection of Meter Elements: 3ph4w Phase Sequence: Correct CT Earthing: Yes % Error as Found: 0.5 % Error as Left: 0.2		Measureings <table><tr><td></td><td>Total</td><td>Rate A</td><td>Rate B</td></tr><tr><td></td><td>Import</td><td>Export</td><td>Import</td></tr><tr><td>Energy kWh</td><td>1250.5</td><td>400.2</td><td>425.1</td></tr><tr><td>Demand kVA</td><td>850.3</td><td>280.1</td><td>285</td></tr><tr><td>R.Energy kVArh</td><td>150.8</td><td>50.2</td><td>50.3</td></tr></table>				Total	Rate A	Rate B		Import	Export	Import	Energy kWh	1250.5	400.2	425.1	Demand kVA	850.3	280.1	285	R.Energy kVArh	150.8	50.2	50.3
	Total	Rate A	Rate B																					
	Import	Export	Import																					
Energy kWh	1250.5	400.2	425.1																					
Demand kVA	850.3	280.1	285																					
R.Energy kVArh	150.8	50.2	50.3																					
Phases <table><tr><td>Phases</td><td>R</td><td>Y</td><td>B</td></tr><tr><td>Voltage (V)</td><td>230.5</td><td>229.8</td><td>230.2</td></tr><tr><td>Current (A) Primary</td><td>45.2</td><td>44.8</td><td>45.1</td></tr><tr><td>Current (A) Secondary</td><td>2.26</td><td>2.24</td><td>2.255</td></tr></table>					Phases	R	Y	B	Voltage (V)	230.5	229.8	230.2	Current (A) Primary	45.2	44.8	45.1	Current (A) Secondary	2.26	2.24	2.255				
Phases	R	Y	B																					
Voltage (V)	230.5	229.8	230.2																					
Current (A) Primary	45.2	44.8	45.1																					
Current (A) Secondary	2.26	2.24	2.255																					
Comments: Sample test report generated for demonstration purposes. All measurements are within acceptable limits.																								
Technical Officer		Chief Engineer-SGS																						

Rate C
Export
425.2
285.2
50.3