

LECO BULK METER TEST REPORT

Report No:	S A	Branch:	g al	Location:	S a	A/C No:	A C	Contract Demand:	10
Date of Tested:	M 20 12	CSC:	C S	Substation No:	S 01	Reason:	C-00	Request ID:	00000000
Current Transformer		0		Static Meter		1		V	
Make:	ABB	0		Make:	Schneider Electric	A		1	
Ratio:	100/5	1		Serial No:	SE-123456	T e		1	
				Meter Constant:	3200	s t			
				Class:	1.0	i n			
				Meter Current:	5A	g			
				Meter Voltage:	230V				
				Tester	Make: Fluke	Serial No:			
Check				Measureings		FL-789012			
Physical Condition of the Meter	Good			Mea	Total	Rate A	Rate B	Rate C	
CT Ratio:	100/5			sur	Import	Export	Import	Export	Import
Meter Ratio:	100/5			ings	5	0	400.2	0	425.1
Multiplying Factor:	1			Energy	1250.	0	425.1	0	425.2
Connection of Meter	3ph4w			Dema	850.3	0	280.1	0	285
Elements:				nd	150.8	0	50.2	0	50.3
Phase Sequence:	Correct			R En	0.950				
CT Earthing:	Yes			ergy					
%Error as Found:	0.5			Avera					
%Error as Left:	0.2			ge Po					
				wer F					
				actor					
Phases		R		Y		B			
Voltage(V)		230.5		229.8		230.2			
Current(A) Primary		45.2		44.8		45.1			
Current(A) Secondary		2.26		2.24		2.255			
Comments: Sample test report generated for demonstration purposes. All measurements are within acceptable limits.									
----- Technical Officer					----- Chief Engineer-SGS				

This is a computer-generated document.