Form No. TDF-0 LECO BULK METER TEST REPORT														
	eport No: ROT-2025-001 Branch: GAL Location						ed Layout Tes	Test A/C N		12345		Contract Defrand:		
Date of Test 2025	5-01-15	CSC:	TEST	Sı	ubstation	NBOARD	kigen	Rea	son:	routine		Request ID: R	EQ001	
Current Transformer Static Meter														
Make: T	est CT Manufactu	rer					Make:	Test M	eter N	anufacturer				
Ratio: 100/5								Serial No: SN123456789						
							Meter Constar	nt:1000						
							Class:	1.0						
	Meter Current: 5A													
	Meter Voltage: 230V													
Check								阿格德 Make: Test Tester Manufacture						
Physical Condition of the Meter: Good							Phases		R			Υ	В	
CT Ratio: 100/5							Voltage(\		230.5			231.2	229.8	
Meter Ratio: 100/5							Current(A) Pr		100.5 5.025			95.2 4.76	105.8 5.29	
Multiplying Factor: 1							Current(A) Secondar		5.025			4.70	5.29	
Connection of Me	eter Elements:	3	ph4w											
Phase Sequence	9:	С	orrect											
CT Earthing:		Y	es											
%Error as Found														
%Error as Found: 0.5 %Error as Left: 0.2														
Measurings	Total				Rate A				Rate B			Rate C		
	Import		Export	Import			oort	Import		Export		Import	Export	
Energy kWh Demand kVA	1000.123		50.456	300.789			123	350.456 175.456		15.789		350.123	25.456	
R.Energy kVArh	500.123 200.123		25.456 10.456	150.789 60.789			123	70.456		8.789 3.789		175.123 70.123	12.456 5.456	
Average Power Factor	0.950		10.430	00.769		2.1	123	70.430		3.703		70.123	3.400	
	is is a comprehensi	ve test reno	rt for the 90-	degree rotated P	DE Jayou	ıt The I	avout should no	w he on	timizo	d for vertical A4 orig	antation	with maximize	nd space utilization	
	nimized gaps, and e													
	ele spanning the full			y. 7 til tablee eriea	a 50 pro	porty po	Johnston William	10 1 11400	o table	on the right elde t		THOOK GOOLIGIT GI		
Technical Officer Chief Engineer-SGS														

This is a computer-generated document.