



Metallurgica Bresciana S.P.A. Viale G. Marconi n.31 Dello		DICHIARAZIONE DI CONFORMITA' DECLARATION OF CONFORMITY		No 5170004080 DATA 18.06.2026 Date PAGINA 1 of 1 Page	
DESTINATARIO PURCHASER PanLink Sp. z o.o. Skarszewska Rokitki, Poland 83-112 124329			COMMESSA N P23423 04.12.2025 CONTRACT N		
			ORDINE INTERNO N 4620001843 WORK ORDER		
			DESTINAZIONE MATERIALE SHIPPED TO PanLink Sp. z o.o. Skarszewska Rokitki, Poland 83-112 Poland		
DOC. INVIATI A: ASSICURAZ. QUALITA' DOCUMENT SENT: INSURANCE QUALITY			NUMERO COLLI 00001 PACKAGE N		
DOCUMENTO DI TRASPORTO N SHIPPING NOTICE N					
POSIZ ITEM	CODICE PART NUMBER	DESCRIZIONE DESCRIPTION	QUANTITY (Qty)	LOTTO - LOT ODP - P.O.	
000020	F580F7143 DTR0000088838	4x0,50 mmq MVB 120 ohm (143F7580) bk matr. DZ49518 0511250003	1.170,000	90053895	
Questa Societa dichiara, sotto la propria ed esclusiva responsabilit�, che la fornitura in oggetto, se non altrimenti dichiarato, � stata fabbricata, provata e ispezionata in accordo con i termini di contratto/ordine ad essa relativi e completamente conforme alle Norme o Specifiche in descrizione. Dichiara inoltre che le procedure adottate sono in accordo alle prescrizioni dello standard UNI EN ISO 9001, con certificazione CSQ n 9125 MET7. In accordo con la norma ISO/IEC 17050-1 This company declares under his own responsibility, that the above mentioned supply, unless otherwise stated, has been manufactured, tested and inspected in accordance with the terms of the contract/order applicable thereto and fully compliant to the standards/specifications in description. Declares also that the adopted procedures are in accordance with the conditions of UNI EN ISO 9001 - Registration CSQ N. 9125 MET7 In accordance with ISO/IEC 17050-1					
Dello,		DATA 18.06.2026 Date	IL RESPONSABILE ASSICURAZIONE QUALITA' Ing. Adigrat Antonio 		



CERTIFICATO DI COLLAUDO / Test Certificate

N°: 90053895
Ordine Cliente: P23423 - 4620001843
data 18-06-2026
Purchase Order

Cliente: PanLink Sp. z o.o.
Customer
Destinazione: POLAND
Delivery Point

Oggetto: FIRE RESISTANT MULTICORE CABLE 4x0.50 mm² MVB
Object
Normativa/ Specifiche: Sp. MB 262.F7.580 / EN50200
Specification

TIPOLOGIA Control Type	CARATTERISTICA Test	Udm Um	RICHIESTO MIN Required Min	RICHIESTO MAX Required Max	RILEVATO Measurement	NOTE Remarks
Prove dimensionali - Dimensional test						
NASTRO 2 / TAPE 2			OK	OK	OK	- SEPARATOR
NASTRO 4 / TAPE 4			OK	OK	OK	- AL/POL/AL UNDER BRAID
FILO CONTINUITÀ / DRAIN WIRE		mm	OK	OK	OK	
GUAINA / OUTER SHEATH			OK	OK	OK	EM104
COLORE GUAINA / SHEATH COLOUR			OK	OK	OK	NERO
DIAMETRO GUAINA MEDIO / EXTERNAL DIAMETER		mm	7	7.4	7.35	
SPESSORE GUAINA MEDIO / OUTER SHEATH AVERAGE THICKNESS		mm	0.42	n.a.	0.665	
SPESSORE GUAINA MIN / OUTER SHEATH MINIMUM THICKNESS		mm	0	n.a.	0.607	
MARCATURA / CABLE SURFACE MARKING			OK	OK	04/2026	"METALLURGICA BRESCIANA - 4X0.50 MM2 MVB - 120 OHM - M - settimana/anno" - WEEK/YEAR
Prove elettriche - Electrical test						
CONTINUITÀ ELETTRICA / CONTINUITY TEST			OK	OK	OK	
TENSIONE CONDUTTORE/CONDUTTORE / VOLTAGE TEST COND/COND		kV	2 AC	2 AC	2 AC	- x 5 MIN
TENSIONE CONDUTTORE/ISCHERMO / VOLTAGE TEST COND/SCREEN		kV	2 AC	2 AC	2 AC	- x 5 MIN
RESISTENZA ISOLAMENTO / INSULATION RESISTANCE		Mohm*km	3500	n.a.	100000	
SQUILIBRIO CAPACITÀ (COND/SC) / CAPACITANCE UNBALANCE (COND/SCREEN)		pF/m	0	1.5	1.4	
RESISTENZA AL FUOCO EN 50200 / FIRE RESISTANCE EN 50200		kV	OK	OK	OK	- PH 15
Prove fisiche - Physical test						
DUREVOLEZZA MARCATURA / DURABILITY OF IDENTIFICATION			OK	OK	OK	
DUREVOLEZZA MARCATURA / DURABILITY OF IDENTIFICATION			OK	OK	OK	
NON PROPAGAZIONE DELLA FIAMMA / VERTICAL BURNING TEST (SINGLE CABLE)			OK	OK	OK	- EN 60332-1-2
ALLUNGAMENTO A CALDO GUAINA / SHEATH HOT SET TEST ELONGATION		%	0	100	41	- 15 MIN at 200°C 20N/cm²
ALLUNGAMENTO A CALDO GUAINA RESIDUO / SHEATH HOT SET TEST ELONG. AFTER COOLING		%	0	25	0	
EMISSIONE HCL / AMOUNT OF HALOGEN ACID GAS DURING COMB. HCI		%	0	0.5	0.1	- <0.1 - EN50267-2-1
ASSENZA DI ALOGENI CONDUTTIVITÀ / ABSENCE OF HALOGENS CONDUCTIVITY		µS/mm	0	10	2	- <=2 - EN50267-2-2

TIPOLOGIA Control Type	CARATTERISTICA Test	UdM Um	RICHIESTO MIN Required Min	RICHIESTO MAX Required Max	RILEVATO Measurement	NOTE Remarks
ASSENZA DI ALOGENI PH / ABSENCE OF HALOGENS PH		pH	4.3	n.a.	5	->=5 - EN50267-2-2
DEFORMAZIONE A CALDO ISOLANTE / PRESSURE TEST AT HIGH TEMPERATURE		kV	OK	OK	OK	- 4h at 125°C

MEGALLURGICA BIESCIANA S.p.A.
CONTROLLO QUALITA'
"Il Responsabile"

MB

N°: 90053895

Metallurgica Bresciana S.p.A.

PACKING LIST N. 4620001843/2
LISTA DEI COLLI

To.
PanLink Sp. z o.o.
ul. Skarszewska 15
83-112 Rokitki, Tczew,
Poland

Your P. Order N. P23423

METALLURGICA BRESCIANA S.p.A.
CONTROLLO QUALITA'
il Responsabile

N.	PACKAGE	SIZE CM.	VOLUME M3	MTS.	DESCRIPTION	YOUR CODE	WEIGHT KG GROSS NET
1	PALLET DZ49518	80X80X65 70X50X70	0,416	1170	CONTAINING: 4x0,50 mmq MVB 120 ohm (143F7580) bk	DTR0000088838	15 105 89
1 PALLET			0,416				120 89