Cabinet Diagram

Notes:

- 1. Cabinet 11 and 13, IP21 with perforated front and rear doors
- 2. Cabinet 12, 14, 15, 16, 17, IP67 dust tight, vacuum seal, protected against immersion for 30 mins at depths 150mm-1000mm.
- 3.Cabinet 18, IP68, dust tight, protect against complete, continuous submersion in water.

20U,	600d,	600w
------	-------	------

Switch17 (1U)

Structure Cabling (10U)

UPS171 500VA (2U)

Cabinet 17
Substation

20U, 600d, 600w

Switch15 (1U)

Structure Cabling (10U)

UPS151 500VA (2U)

Cabinet 15
Battery Building 1

47U, 1000d , 800w

Switch13 (1U)

PDU A (1U) PDU B (1U)

Structure Cabling (10U)

KVM13 (1U)

Server13 (3U)

UPS131 1500VA (2U)

UPS132 1500VA (2U)

Cabinet13
Test and Service Upstairs

47U, 1000d, 800w

Switch11 (1U)

PDU A (1U) PDU B (1U)

Structure Cabling (10U)

KVM11 (1U)

Server11 (3U)

UPS111 1500VA (2U)

UPS112 1500VA (2U)

Cabinet11 Forecourt Upstairs

10U, 400d, 600w

Switch18 (1U)

Structure Cabling (6U)

UPS181 500VA (2U)

Cabinet 18 Car Wash 20U, 600d, 600w

Switch16 (1U)

Structure Cabling (10U)

UPS161 500VA (2U)

Cabinet 16
Battery Building 2

20U, 600d, 600w

Switch14 (1U)

Structure Cabling (10U)

UPS141 500VA (2U)

Cabinet 14
Forecourt Ground Floor

20U, 600d, 600w

Switch12 (1U)

Structure Cabling (10U)

UPS121 500VA (2U)

Cabinet 12
Forecourt Ground Floor