

DELHI JAL BOARD: GOVT. OF NCT DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)-I
ROOM NO-208, VARUNALAYA PH-I,
JHANDEWALAN NEW DELHI-110005

No.DJB/EE (RWH/GWC)-I/2022/ 748

Dated:- 31/10/2022

To,

The Vice Principal
Vidya Jain Convent School,
Khasra No. 142, Plot-289,
Kanjhawala, Delhi.

Subject: Exemption from Rain Water Harvesting .

Reference:- Your letter No. Nil dated 27.10.2022.

Dear sir,

Your request for exemption of Rain Water Harvesting vide above mentioned letter from *Vidya Jain Convent School, Khasra No. 142, Plot-289, Kanjhawala, Delhi.* has been received in this office.

The site has been inspected on 28.10.2022 and it has been observed that static ground water level in existing bore well has been found to be 2.25 m from the existing ground level.

As per DJB guidelines, the Rain Water Harvesting system is not recommended where post monsoon ground water level is shallower than 5.0m. Hence, as per the findings, the Rain Water Harvesting system is exempted from installation at above said premises.

It is also to inform you that in case ground water level is deeper than 5.0m in future, the Rain Water Harvesting System shall have to be installed mandatorily at the above said site as per DJB guidelines.


EE(RWH/GWC)-I
EE (RWH-I)
DELHI JAL BOARD
VARUNALAYA BHAWAN
JHANDEWALAN, N.D.


Vice Principal
Vidya Jain Convent School


VIDYA JAIN CONVENT SCHOOL
Manager