



SAVE WATER, SAVE LIFE



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT BAWANA,
DELHI-110039.



Water samples collected From Vidya Jain Convent School, Kanjhawala, Khasra No. 142, Plot-289,
Delhi-110081 vide Challan No.70 Dated 13.06.2025

S1: DJB Supply

S2: Drinking Point in the school premises

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1	S2
			Acceptable	Permissible		
1.	Date of collection	--	---	---	20.06.2025	20.06.2025
2.	Date of Analysis	--	---	---	21.06.2025	21.06.2025
3.	Colour	C.U.	5	15	Clear	Clear
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.96	1.88
6.	p ^H value	--	6.5 to 8.5	N.R.	7.6	7.6
7.	Electrical Conductivity	µmhos/cm	---	---	251.0	247.0
8.	Total Dissolved Solid	(mg/l)	500	2000	163.15	160.55
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	58.0	58.0
11.	Total Hardness	(mg/l)	200	600	96.0	97.0
12.	Calcium Hardness	(mg/l)	200	600	64.0	62.0
13.	Magnesium Hardness	(mg/l)	200	600	32.0	35.0
14.	Calcium as Ca	(mg/l)	75	200	25.6	24.8
15.	Magnesium as mg	(mg/l)	30	100	7.68	8.4
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	2.93	2.84
19.	Sulphate (SO ₄)	(mg/l)	200	400	29.38	30.43
20.	Chloride (Cl)	(mg/l)	250	1000	15.0	14.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.03	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.27	0.28
23.	Cyanides (C N)	(mg/l)	0.05	N.R.	Absent	Absent
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.24	0.21
BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0	0

Remarks: As per above tested parameters, Both Samples S1 and S2 found satisfactory and can be used for drinking purpose.

Dikey
Asst. Chemist/ Asst.Bacteriologist

Pranav
Chemist/Bacteriologist

Shilpa
A.C.W.A. (Bawana)



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
NARELA ZONE

No. DHO/NRZ/2025/D-271

Dated: 23/6/2025

SCHOOL HEALTH CERTIFICATE

Date of Inspection : 20.06.2025
1. Name of School : VIDYA JAIN CONVENT SCHOOL
2. Address : KHASRA NO.142, PLOT-289, KANJHAWALA
DELHI-110081
3. No. of Shifts : One Timing 08:00 AM to 02:00 PM

Accommodation Provided

THE FLOOR AREA IN THE CLASSROOM IS SUFFICIENT.
THE CLASSES ARE WELL LIGHTED.
THE CLASSROOMS ARE WELL VENTILATED.
THE CLASSROOMS ARE KEPT NEAT AND CLEAN.
THE DRINKING WATER IS WATER TEST REPORT APPROVRD BY APEX LAB..
THE TOILET ARRANGEMENT IS SANITARY & HYGENIC AND SUFFICIENT IN
NUMBER.

Remarks :

THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT
OF VIEW.

The certificate is valid for one year from the date of issue.


Dy. Health Officer
Narela Zone

The MANAGER

VIDYA JAIN CONVENT SCHOOL
KHASRA NO.142, PLOT-289, KANJHAWALA,
DELHI-110081

DELHI JAL BOARD: GOVT. OF NCT DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)-I
ROOM NO-208, VARUNALAYA PH-I,
JHANDEWALAN NEW DELHI-110005

No.DJB/EE (RWH/GWC)-I/2022/ 748

Dated:- 31/10/2022

To,

The Vice Principal
Vidya Jain Convent School,
Khasra No. 142, Plot-289,
Kanjhawala, Delhi.

Subject: Exemption from Rain Water Harvesting .

Reference:- Your letter No. Nil dated 27.10.2022.

Dear sir,

Your request for exemption of Rain Water Harvesting vide above mentioned letter from *Vidya Jain Convent School, Khasra No. 142, Plot-289, Kanjhawala, Delhi.* has been received in this office.

The site has been inspected on 28.10.2022 and it has been observed that static ground water level in existing bore well has been found to be 2.25 m from the existing ground level.

As per DJB guidelines, the Rain Water Harvesting system is not recommended where post monsoon ground water level is shallower than 5.0m. Hence, as per the findings, the Rain Water Harvesting system is exempted from installation at above said premises.

It is also to inform you that in case ground water level is deeper than 5.0m in future, the Rain Water Harvesting System shall have to be installed mandatorily at the above said site as per DJB guidelines.


EE(RWH/GWC)-I
EE (RWH-I)
DELHI JAL BOARD
VARUNALAYA BHAWAN
JHANDEWALAN, N.D.


Vice Principal
Vidya Jain Convent School


VIDYA JAIN CONVENT SCHOOL
Manager