



SAVE WATER, SAVE LIFE



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT BAWANA,
DELHI-110039.



Water samples collected From Vidya Jain Convent School, Kanjhawala, Khasra No. 142, Plot-289,
Delhi-110081 vide Challan No.70 Dated 13.06.2025

S1: DJB Supply

S2: Drinking Point in the school premises

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1	S2
			Acceptable	Permissible		
1.	Date of collection	--	---	---	20.06.2025	20.06.2025
2.	Date of Analysis	--	---	---	21.06.2025	21.06.2025
3.	Colour	C.U.	5	15	Clear	Clear
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.96	1.88
6.	p ^H value	--	6.5 to 8.5	N.R.	7.6	7.6
7.	Electrical Conductivity	µmhos/cm	---	---	251.0	247.0
8.	Total Dissolved Solid	(mg/l)	500	2000	163.15	160.55
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	58.0	58.0
11.	Total Hardness	(mg/l)	200	600	96.0	97.0
12.	Calcium Hardness	(mg/l)	200	600	64.0	62.0
13.	Magnesium Hardness	(mg/l)	200	600	32.0	35.0
14.	Calcium as Ca	(mg/l)	75	200	25.6	24.8
15.	Magnesium as mg	(mg/l)	30	100	7.68	8.4
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	2.93	2.84
19.	Sulphate (SO ₄)	(mg/l)	200	400	29.38	30.43
20.	Chloride (Cl)	(mg/l)	250	1000	15.0	14.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.03	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.27	0.28
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	Absent	Absent
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.24	0.21
BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0	0

Remarks: As per above tested parameters, Both Samples S1 and S2 found satisfactory and can be used for drinking purpose.

Dikey
Asst. Chemist/ Asst.Bacteriologist

Pranav
Chemist/Bacteriologist

Shilpa
A.C.W.A. (Bawana)