National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, क़ुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 01.11.2026

To,

1. कार्यकारी निदेशक, पू.क्षे .भा .प्रे .के.,14 , गोल्फ क्लब रोड , कोलकाता - 700033
   Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
2. कार्यकारी निदेशक, ऊ. क्षे. भा. प्रे. के., 18/ ए , शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
   Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016
3. कार्यकारी निदेशक, प .क्षे .भा .प्रे .के., एफ3-, एम आई डी सी क्षेत्र , अंधेरी, मुंबई –400093
   Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
4. कार्यकारी निदेशक, ऊ. पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह , लापलंग, शिलोंग – 793006
   Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
5. कार्यकारी निदेशक , द .क्षे .भा .प्रे .के.,29 , रेस कोर्स क्रॉस रोड, बंगलुरु –560009
   Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 31.10.2026.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 31-अक्टूबर-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उप्लब्ध है |

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 31.10.2026, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

Report for previous day **Date of Reporting: 01-Nov-2026**

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met (MW) during Evening Peak hr (19:00hrs)[1]	60931	68988	53863	26249	3265	213296
Shoratge (MW) during Evening Peak hr (19:00hrs)[1]	155	0	0	0	260	415
Energy Met (MU)	1195	1647	1328	540	65	4775
Hydro Gen (MU)	139	45	64	52	28	328
Wind Gen (MU)	11	81	33	-	-	125
Solar Gen (MU)*	240.91	216.56	182.12	3.20	1.09	644
Energy Shortage (MU)	1.80	0.00	0.00	0.15	0.60	2.55
Maximum Demand Met During the Day (MW) (From NLDC SCADA-1 min Instantaneous data)	62437	82958	63603	26573	3575	225285
Time of Maximum Demand Met	18:31	15:47	09:45	18:11	17:16	09:45

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.181	6.02	1.90	7.34	15.25	76.14	8.61

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)[1]	Shortage at Maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD(+)/ UD(-) (MW)	Energy Shortage (MU)
NR	Punjab	8510	0	170.2	88.0	-4.0	971/ -721	0.26
	Haryana	8560	0	167.7	117.1	-2.9	481/ -547	0.00
	Rajasthan	15728	0	293.4	85.3	-6.0	619/ -1758	0.00
	Delhi	4242	0	81.6	75.3	-1.8	85/ -203	0.00
	UP	18970	0	343.5	83.1	-1.6	1146/ -1454	0.00
	Uttarakhand	2228	0	41.8	27.4	0.2	192/ -141	0.00
	HP	2035	0	36.7	21.8	-0.5	177/ -485	0.28
	J&K(UT) & Ladakh(UT)	2627	0	49.4	43.0	-0.2	502/ -285	1.26
	Chandigarh	220	0	3.9	4.0	-0.1	10/ -30	0.00
	Bulk Consumer_NR ISTS	336	0	6.6	6.1	0.5	67/ -75	0.00
WR	Chhattisgarh	4920	0	94.7	40.0	-1.2	417/ -656	0.00
	Gujarat	27291	0	510.1	229.7	-7.7	1455/ -1270	0.00
	MP	16991	0	319.1	192.5	-0.5	995/ -891	0.00
	Maharashtra	30914	0	638.4	247.1	-3.6	1477/ -1117	0.00
	Goa	795	0	15.7	16.1	-0.4	31/ -72	0.00
	DNHDDPDCL	1373	0	31.4	31.2	0.2	112/ -35	0.00
	Bulk Consumer_WR ISTS	1630	0	37.5	38.4	-0.9	326/ -409	0.00
SR	Andhra Pradesh	10850	0	231.1	77.4	0.1	709/ -536	0.00
	Telangana	14767	0	276.7	140.3	-0.1	898/ -841	0.00
	Karnataka	17720	0	333.9	156.6	3.0	913/ -1005	0.00
	Kerala	4914	0	90.5	79.3	0.0	435/ -300	0.00
	Tamil Nadu	18778	0	386.0	233.6	-0.1	884/ -819	0.00
	Puducherry	496	0	10.2	10.3	-0.1	27/ -50	0.00
	Bulk Consumer_SR ISTS	0	0	0.0	0.0	0.0	0/ -0	0.00
ER	Bihar	6055	0	107.2	86.7	-3.5	348/ -664	0.00
	DVC	3076	0	68.7	-42.8	0.6	292/ -296	0.15
	Jharkhand	2237	0	42.3	31.7	1.5	332/ -201	0.00
	Odisha	5778	0	117.0	13.3	-1.5	349/ -551	0.00
	West Bengal	9934	0	203.2	58.4	-2.3	387/ -455	0.00
	Sikkim	83	0	1.1	1.4	-0.3	17/ -54	0.00
	Bulk Consumer_ER ISTS	19	0	0.2	0.2	0.0	4/ -19	0.00
NER	Arunachal Pradesh	194	0	3.4	3.2	0.0	30/ -29	0.00
	Assam	2141	0	40.2	34.2	0.1	182/ -171	0.54
	Manipur	217	21	3.5	3.6	-0.2	21/ -36	0.06
	Meghalaya	344	0	6.1	4.1	0.0	69/ -63	0.00
	Mizoram	153	0	2.4	1.3	-0.1	31/ -47	0.00
	Nagaland	185	0	3.1	2.9	-0.1	19/ -34	0.00
	Tripura	302	0	6.3	6.7	0.0	44/ -80	0.00
	Bulk Consumer_NER ISTS	0	0	0.0	0.0	0.0	0/ -0	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	9.2	18.3	-24.0	-22.0
Day Peak (MW)	485.7	1114.6	-1019.8	-947.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	85.0	-169.2	256.5	-180.9	8.6	0.0
Actual(MU)	71.2	-157.0	257.3	-197.4	7.3	-18.5
O/D/U/D(MU)	-13.8	12.2	0.8	-16.5	-1.3	-18.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4747	9837	4808	5590	80	25062	51
State Sector	9606	7340	5391	1748	273	24358	49
Total	14353	17177	10199	7338	353	49419	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	732	1514	742	733	14	3734	72
Lignite	25	21	52	0	0	98	2
Hydro	139	45	64	52	28	328	6
Nuclear	52	71	69	0	0	192	4
Gas, Naptha & Diesel	9	11	5	0	20	45	1
RES (Wind, Solar, Biomass & Others)	257	301	234	7	1	800	15
Total	1214	1961	1166	792	63	5196	100

Share of RES in total generation (%)	21.21	15.34	20.07	0.82	1.74	15.39
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.99	21.23	31.49	7.42	46.01	25.41

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.061
Based on State Max Demands	1.101

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	225285	9:45	0
Non-Solar hr	216037	19:00	415

J. Power Supply Position of ISTS Bulk Consumer Entities

Region	States	Max.Demand Met during the day (MW)[1]	Shortage during Maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD(+)/ UD(-) (MW)	Energy Shortage (MU)
NR	Railways_NR ISTS	223	0	4.8	4.3	0.5	45/ -46	0.00
	Hindustan Zinc Ltd. Daripa	114	0	1.8	1.8	0.0	23/ -51	0.00
WR	AMNSIL	861	0	9.2	9.4	-0.2	172/ -320	0.00
	BALCO	869	0	20.7	21.2	-0.5	160/ -81	0.00
	RIL Jamnagar	294	0	6.9	7.1	-0.2	9/ -180	0.00
	Welspun	79	0	0.7	0.7	0.0	4/ -4	0.00
ER	Railways_ER ISTS	19	0	0.2	0.2	0.0	4/ -19	0.00

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours (Except winters when Solar Hours -> 07:00 Hrs to 17:00 Hrs)

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

[1]Based on demand and shortage data from the states/utilities

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 01-Nov-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	699	1492	0.0	16.4	-16.4
4	765 kV	SASARAM-FATEHPUR	1	215	733	0.0	9.6	-9.6
5	765 kV	GAYA-BALIA	1	313	659	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	0	136	0.0	1.8	-1.8
7	400 kV	PUSAULI -ALLAHABAD	1	40	75	0.0	0.5	-0.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	349	768	0.0	9.7	-9.7
9	400 kV	PATNA-BALIA	2	188	584	0.0	7.7	-7.7
10	400 kV	NAUBATPUR-BALIA	2	191	591	0.0	8.2	-8.2
11	400 kV	BIHARSHARIFF-BALIA	2	622	485	0.0	1.9	-1.9
12	400 kV	MOTIHARI-GORAKHPUR	2	349	224	0.0	0.1	-0.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	298	581	0.0	5.6	-5.6
14	220 kV	SAHUPURI-KARAMNASA	1	0	85	0.0	1.3	-1.3
15	132 kV	NAGAR UNTARI-RIHAND	1	4	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.5	0.0	0.5
17	132 kV	KARMANASA-CHANDAULI	1	1	0	0.0	0.0	0.0
					ER-NR	0.5	73.5	-73.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1497	0	14.9	0.0	14.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	557	681	0.0	3.6	-3.6
3	765 kV	JHARSUGUDA-DURG	2	0	1878	0.0	32.7	-32.7
4	400 kV	JHARSUGUDA-RAIGARH	4	122	633	0.0	8.2	-8.2
5	400 kV	RANCHI-SIPAT	2	152	475	0.0	5.0	-5.0
6	400 kV	JEYPORE-JAGDALPUR	2	527	78	3.8	0.0	3.8
7	220 kV	BUDHIPADAR-RAIGARH	1	0	135	0.0	2.0	-2.0
8	220 kV	BUDHIPADAR-KORBA	2	79	139	0.0	1.3	-1.3
					ER-WR	18.7	52.7	-34.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	716	0.0	17.1	-17.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1604	0.0	39.9	-39.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	3196	0.0	56.8	-56.8
4	400 kV	TALCHER-I/C	2	1570	0	0.4	0.0	0.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
					ER-SR	0.0	113.7	-113.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	195	628	0.0	7.7	-7.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	399	913	0.0	10.7	-10.7
3	220 kV	ALIPURDUAR-SALAKATI	2	38	182	0.0	2.5	-2.5
					ER-NER	0.0	20.9	-20.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	505	0.0	12.1	-12.1
					NER-NR	0.0	12.1	-12.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1006	0.0	23.7	-23.7
2	HVDC	VINDHYACHAL B/B	-	242	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1456	0.0	31.7	-31.7
4	765 kV	GWALIOR-AGRA	2	1192	751	1.6	0.0	1.6
5	765 kV	GWALIOR-PHAGI	2	2438	1678	12.1	18.7	-6.6
6	765 kV	JABALPUR-ORAI	2	724	509	0.0	7.7	-7.7
7	765 kV	GWALIOR-ORAI	1	825	184	11.7	0.5	11.3
8	765 kV	SATNA-ORAI	1	122	811	0.1	12.9	-12.8
9	765 kV	BANASKANTHA-CHITTORGARH	2	2254	9	35.3	0.0	35.3
10	765 kV	VINDHYACHAL-VARANASI	2	765	869	0.0	0.4	-0.4
11	400 kV	ZERDA-KANKROLI	1	398	31	6.1	0.0	6.1
12	400 kV	ZERDA -BHINMAL	1	276	22	4.2	0.0	4.2
13	400 kV	VINDHYACHAL -RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	1428	0	14.8	0.0	14.8
15	400 kV	NEEMUCH-Chittorgarh	2	1379	96	9.8	0.0	9.8
16	220 kV	BHANPURA-RANPUR	1	0	120	0.0	1.3	-1.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	124	0	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	96	0	1.1	0.0	1.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
					WR-NR	104.6	99.0	5.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	944	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	5633	0.0	89.6	-89.6
3	765 kV	SOLAPUR-RAICHUR	2	364	1716	0.4	15.5	-15.1
4	765 kV	WARDHA-NIZAMABAD	2	0	3159	0.0	43.0	-43.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3021	0.0	47.5	-47.5
6	400 kV	KOLHAPUR-KUDGI	2	1346	0	20.3	0.0	20.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	126	2.4	0.0	2.4
					WR-SR	23.1	219.6	-196.5

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV JIGMELING-ALIPURDUAR 1,2, 400kV PUNATSANGCHHU - ALIPURDUAR 1,2 i.e. ALIPURDUAR RECEIPT (from MANGDECHU	0	0	0	-0.52
	ER	400kV TALA-BINAGURI 1,2 ,400kV MALBASE - BINAGURI & 400kV NORBUGANG - BINAGURI i.e. BINAGURI RECEIPT (from TALA HEP	0	0	0	11.22
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	0	0	0	-0.06
	NER	132kV GELEPHU-SALAKATI	-76	0	-53	-1.28
	NER	132kV MOTANGA-RANGIA	-17	0	-8	-0.18
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	62	1.49
	ER	NEPAL IMPORT (FROM BIHAR)	254	137	195	4.69
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	574	386	507	12.17
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-947	-923	-933	-22.40
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-947	-888	-915	-21.95
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-78	0	-68	-1.62

CROSS BORDER EXCHANGE SCHEDULE **Date of Reporting: 01-Nov-2026**

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.12	0.17	0.00	0.00	0.00	0.00	0.00	0.00	23.29
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.12	0.17	0.00	0.00	0.00	0.00	0.00	0.00	23.29

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	8.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.86
Nepal	14.93	0.16	0.00	0.00	0.00	4.03	0.00	0.00	19.12
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	23.79	0.16	0.00	0.00	0.00	4.03	0.00	0.00	27.98

Net from India(in MU) **-ve : Export / +ve : Import**

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	8.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.86
Nepal	14.93	0.16	0.00	0.00	0.00	4.03	0.00	0.00	19.12
Bangladesh	-23.12	-0.17	0.00	0.00	0.00	0.00	0.00	0.00	-23.29
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	0.67	-0.01	0.00	0.00	0.00	4.03	0.00	0.00	4.69

Date of Reporting: 01-Nov-2026

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)

TIME	FREQUENCY (Hz)	DEMAND MET[1] (MW)	STORAGE DEMAND (PSP&BESS) (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO[2] (MW)	GAS (MW)	THERMAL (MW)	STORAGE (PSP&BESS) (MW)	OTHERS[3] (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) +ve Imp,-ve Exp
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I)	(J)	(K)=A-D-E	(L)= ∑(C:J)	(M)
0:00	50.05	179756	38	7379	6724	0	11070	1936	150534	1482	2919	173032	182044	308
0:15	49.96	179460	35	7368	6438	0	10666	1650	151825	1234	2917	173022	182098	319
0:30	49.97	178120	46	7370	6163	0	10289	1654	151058	1158	2957	171957	180649	310
0:45	49.98	176970	45	7368	5920	0	9860	1657	150694	1192	2928	171050	179619	342
1:00	49.95	175825	46	7364	5717	0	9454	1645	150490	887	2952	170108	178509	333
1:15	49.98	174427	46	7381	5522	0	9069	1653	149831	732	2964	168905	177152	346
1:30	50.00	173550	45	7377	5403	0	8892	1659	149616	458	2956	168147	176361	348
1:45	50.00	172363	45	7386	5375	0	8795	1650	148744	453	3012	166988	175415	366
2:00	49.98	170765	44	7374	5293	0	8744	1654	147640	246	3030	165472	173981	265
2:15	49.98	170725	224	7365	5256	0	8867	1657	147442	428	2952	165469	173967	254
2:30	50.04	170245	235	7377	5124	0	8922	1653	146796	425	2976	165121	173273	298
2:45	49.93	169953	492	7384	5083	0	8878	1653	146742	119	2973	164870	172832	270
3:00	50.00	169426	513	7391	4916	0	8829	1656	146074	112	3049	164510	172027	264
3:15	49.95	170686	1367	7387	4933	0	8909	1677	147644	137	2967	165753	173654	284
3:30	49.96	171101	1437	7388	4957	0	8925	1698	147805	130	2981	166144	173884	286
3:45	50.04	170482	979	7391	4887	0	8792	1699	147505	126	2941	165595	173341	281
4:00	50.02	169791	1054	7389	4787	0	8310	1686	147480	112	2975	165004	172739	244
4:15	50.01	170568	721	7380	4744	0	8104	1683	148577	136	2980	165824	173604	246
4:30	49.96	172513	817	7391	4774	0	8168	1683	150467	259	2933	167739	175675	240
4:45	49.97	173537	327	7392	4814	0	8160	1687	151204	457	2987	168723	176701	224
5:00	50.03	175659	54	7389	4852	136	8594	1701	152989	427	2989	170671	179077	181
5:15	49.99	179573	44	7389	4928	155	9588	1705	155658	834	2929	174490	183186	169
5:30	50.00	183788	90	7401	4864	145	10623	1719	158004	1823	2977	178779	187556	147
5:45	50.01	187515	95	7389	4790	144	11915	1686	160338	2175	2959	182581	191396	135
6:00	50.00	189777	101	7394	4734	148	13080	1677	161347	2082	2973	184895	193435	120
6:15	49.96	194369	107	7387	4791	1041	15333	1718	163251	2305	2971	188537	198797	112
6:30	49.93	199485	113	7384	4925	1341	17317	1737	165066	2747	2929	193219	203446	92
6:45	49.81	203814	107	7384	4735	2396	18013	1802	166177	3821	2933	196683	207261	99
7:00	49.96	205653	108	7387	4871	4162	18382	1797	166066	3628	2943	196620	209236	53
7:15	49.89	207623	79	7386	4939	7816	17941	1796	166080	2107	3035	194868	211100	-58
7:30	50.00	208129	42	7399	4888	13189	15156	1782	164651	1223	3028	190052	211316	-32
7:45	50.03	207969	45	7401	4676	19933	12923	1736	161142	208	3065	183360	211084	-47
8:00	50.17	207290	835	7395	4439	27578	11395	1681	154597	27	3073	175273	210185	-41
8:15	50.00	211673	2063	7391	4193	36194	11334	1650	150700	2	3046	171286	214510	92
8:30	50.02	214705	2667	7392	3793	44344	10628	1653	146428	2	3042	166568	217282	195
8:45	50.05	217523	3242	7376	3389	51211	9302	1655	144066	1	3080	162923	220080	114
9:00	50.05	218210	3928	7385	3100	57783	8932	1664	138736	1	3004	157327	220605	90
9:15	49.98	221988	4255	7388	2926	63390	8592	1655	137368	2	3013	155672	224334	155
9:30	50.02	223771	4680	7374	2768	69120	8592	1650	133728	33	2941	151883	226206	92
9:45	50.03	225285	5116	7371	2702	73539	8425	1621	130795	50	3008	149044	227511	122
10:00	50.01	224326	5135	7368	2583	76854	8293	1614	127693	54	3018	144889	227477	59
10:15	50.05	224071	5639	7372	2456	80099	7975	1604	124735	57	2986	141516	227284	51
10:30	50.03	223757	5641	7367	2149	82768	7837	1579	122307	60	2978	138840	227045	104
10:45	49.98	222504	5868	7341	2244	84135	6742	1588	120041	62	2999	136125	225152	116
11:00	50.02	221661	6042	7351	2159	85669	6627	1592	118201	64	2938	133833	224601	182
11:15	49.99	220712	6237	7363	2163	87225	6557	1583	115925	65	3014	131324	223895	211
11:30	50.02	220161	6402	7367	2122	87500	6329	1582	114317	63	2994	130539	222274	140
11:45	49.95	220219	6724	7355	2207	87287	6440	1584	115061	26	2993	130725	222953	79
12:00	49.99	218784	6636	7353	2281	87045	6527	1591	113533	22	2923	129458	221275	75
12:15	49.93	217666	6502	7354	2444	86596	5856	1595	113220	18	2985	128626	220068	93
12:30	50.01	217538	6500	7349	2653	86909	5820	1607	112647	10	2967	127976	219962	101
12:45	49.95	216997	6342	7329	2721	86282	5837	1605	112574	4	2971	127994	219323	127
13:00	50.07	215379	6400	7330	3065	85432	6064	1603	111209	2	2961	126882	217666	54
13:15	50.10	211552	6362	7330	3239	83056	6028	1604	109789	2	2999	125257	214047	51
13:30	50.00	211998	6239	7318	3447	82609	6419	1604	110139	2	2989	125942	214527	40
13:45	49.96	213773	5894	7306	3608	81202	6758	1595	112685	3	3007	128963	216164	34
14:00	49.96	214410	5695	7307	3657	79228	6810	1598	115528	44	2809	131525	216981	47
14:15	49.91	215625	4871	7311	3784	76719	6994	1594	118927	43	2807	135122	218179	78
14:30	49.89	218780	4878	7298	3792	74622	7368	1609	123870	44	2827	140366	221430	114
14:45	49.93	220014	4022	7300	3891	71016	7512	1613	128640	43	2762	145107	222777	20
15:00	49.93	222064	3625	7294	3930	67594	7995	1621	133632	44	2779	150540	224889	134
15:15	49.96	220996	3125	7306	4042	63172	8165	1731	136949	44	2846	153782	224255	-2
15:30	49.97	222533	2652	7295	4199	58657	8385	1733	143274	44	2765	159677	226352	9
15:45	50.00	223749	2196	7290	4194	53611	9305	1807	148020	56	2852	165944	227135	159
16:00	49.93	223039	1245	7296	4410	47666	9605	1957	152449	222	2872	170963	226477	164
16:15	49.91	219736	416	7303	4786	40608	9368	2309	155805	225	2908	174342	223312	158
16:30	49.75	218975	126	7278	4924	33626	10714	2280	160540	391	2871	180425	222624	140
16:45	49.57	216999	119	7276	5043	25989	12937	2448	163458	1370	2905	185967	221426	84
17:00	49.44	215897	37	7267	5122	18184	16567	2734	165248	2504	2943	192591	220569	115
17:15	49.82	213958	23	7306	5182	11706	18281	2623	166044	4867	2922	197070	218931	91
17:30	49.44	213697	22	7274	4767	6382	21004	2957	166941	6163	2940	202548	218428	74
17:45	49.42	212103	24	7280	4889	2924	22653	2655	167447	6200	2926	204290	216974	12
18:00	49.71	213652	128	7233	4882	1358	24877	2836	168041	6286	2882	207412	218395	29
18:15	49.60	216940	134	7281	4979	856	27376	2838	168675	6944	2871	211105	221820	69
18:30	49.59	218181	97	7273	5007	801	28419	2838	169241	6999	2896	212373	223474	75
18:45	49.84	217975	82	7296	5088	810	27016	2765	169602	6284	2915	212077	221776	102
19:00	49.99	216037	91	7317	5310	833	25906	2686	168587	6084	2876	209894	219599	114
19:15	50.03	213891	105	7310	5647	728	24371	2576	167890	5443	2971	207516	216936	105
19:30	49.98	210879	114	7322	5881	0	23774	2254	166804	4708	2900	204998	213643	123
19:45	50.04	208429	114	7317	6206	0	23361	2089	164673	4875	2896	202223	211417	133
20:00	50.05	205274	111	7338	6573	0	22199	2054	162412	4364	2905	198701	207845	112
20:15	49.98	202308	75	7328	6851	0	21575	1936	160533	4106	2920	195457	205249	165
20:30	50.04	200304	74	7314	6863	0	20627	1815	159817	4056	2918	193441	203410	165
20:45	49.98	198775	22	7302	6916	0	19446	1792	159365	3871	2949	191859	201641	263
21:00	50.03	196809	22	7309	6869	0	19355	1773	157405	3835	2962	189940	199508	380
21:15	50.04	195736	22	7322	6913	0	18126	1768	157494	3681	3003	188823	198307	400
21:30	50.05	194971	22	7326	7010	0	15306	1755	159399	3555	2989	187961	197340	413
21:45	50.04	194285	22	7320	7030	0	14100	1764	160170	3676	2966	187255	197026	348
22:00	50.03	192211	22	7314	7034	0	13085	1776	159472	3268	2953	185177	194902	351
22:15	49.87	193333	22	7315	7040	0	12987	1703	161303	2923	2991	186293	196262	356
22:30	49.93	193051	23	7319	7045	0	12383	1647	161540	2869	3030	186006	195833	383
22:45	49.93	192397	25	7322	7032	0	12278	1631	161066	2987	2931	185365	195247	467
23:00	50.03	191093	25	7333	6837	0	12283	1644	159776	2937	2908	184256	193718	463
23:15	50.04	189178	26	7336	6883	0	11161	1647	159264	2627	2960	182295	191878	426
23:30	50.03	187052	26	7332	6857	0	10474	1646	158279	2488	2933	180195	190009	419
23:45	50.02	186159	31	7334	6841	0	10141	1634	158006	2150	2979	179318	189085	432

[1]Demand Met (Demand incidental on transmission system): Excluding demand met through captive and rooftop sources; includes storage load comprising pumping and BESS charging (i.e. (B) in the table above)
[2]Hydro generation is excluding pumped hydro(PSP) & Bhutan Hydro. Bhutan hydro is accounted for in net transnational exchange.
[3]Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha (manually punched).

Disclaimer:
1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.