

HOME INSPECTION REPORT

Prepared for: Jordan & Priya Shah

Property: 123 Maple Avenue, Rye, NY 10580

Inspection Date: July 14, 2026

Inspector: ProHome Inspections, License #NY-INSP-4471

SUMMARY OF FINDINGS

The home is generally in good and well-maintained condition. The following items are noted for the buyers' awareness:

- Water Heater: Approximately 11 years old and near the end of its service life. Budget for replacement within 1-2 years. (Recommend)
- Basement: Minor moisture staining observed on the north foundation wall. No active leak at time of inspection. Recommend monitoring. (Monitor)
- Roof: Asphalt shingle roof in serviceable condition, est. 8 years old.
- Electrical: 200-amp panel, updated, no deficiencies observed.
- HVAC: Forced-air gas furnace and central AC both operational.

This report should be reviewed prior to the expiration of the inspection contingency on July 18, 2026.