

Print Back Co

Noida  
Block A circuit · 50 metered lights of 900 represented

RECORDED VS THEORETICAL

+3%

As predicted

11 counted days averaged **12.41** kWh/day against a theoretical **12.00** kWh/day (count × W × hours ÷ 1000). The circuit behaves as its inventory predicts. This average is the baseline every post-installation savings figure will be measured against.

| THEORETICAL   | RECORDED AVERAGE | DAYS COUNTED      | EXCLUDED |
|---------------|------------------|-------------------|----------|
| 12.00 kWh/day | 12.41 kWh/day    | 11 of 12 recorded | 1 day    |

What is on this circuit

the survey's load inventory

| DEVICE                        | COUNT | W EACH | RUNS | KWH/DAY |
|-------------------------------|-------|--------|------|---------|
| Tube light 20W                | 25    | 20     | 24 h | 12.00   |
| Theoretical daily consumption |       |        |      | 12.00   |

Recorded consumption, day by day

Excluded days are shown, never hidden

| DATE   | KWH   | VS THEORY | DATE   | KWH   | VS THEORY |
|--------|-------|-----------|--------|-------|-----------|
| Thu 16 | 11.80 | -2%       | Wed 22 | 12.70 | +6%       |
| Fri 17 | 12.25 | +2%       | Thu 23 | 13.15 | +10%      |
| Sat 18 | 12.70 | +6%       | Fri 24 | 11.80 | -2%       |
| Sun 19 | 13.15 | +10%      | Sat 25 | 12.25 | +2%       |
| Mon 20 | 11.80 | -2%       | Sun 26 | 12.70 | +6%       |
| Tue 21 | 12.25 | +2%       | Mon 27 | 13.15 | +10%      |

☐ As predicted within ±5%    ☒ Worth a look ±5-10%    ☐ Excluded — not counted in the average

Mon 27 Jul — Partial day — 9 of 24 hours in the export

FirsThing · every figure traces to stored daily readings and the recorded inventory (INV-02).  
Print Back Co · Block A · pre-installation