

Project:	Oakridge Residential Estates	Inspection Date:	July 25, 2026
Unit/Area:	Building B - Unit 302	Inspector:	David Miller (Site Supt.)

ITEM #	LOCATION	DEFICIENCY / DESCRIPTION	ASSIGNED TO	TARGET DATE	STATUS
01	Kitchen	Cabinet door hinge loose on upper cabinet right of stove	Millwork Sub	Jul 28, 2026	Open
02	Master Bath	Caulking along base of shower wall tile has small gap	Tile Craft Inc.	Jul 27, 2026	Open
03	Living Room	Touch up paint on north wall near baseboard corner	Pro Painters	Jul 29, 2026	Open
04	Entryway	Front door latch plate needs adjustment (sticks when closing)	Carpentry Team	Jul 27, 2026	Resolved
05	Balcony	Remove masonry overspray from glass sliding door frame	Clean Co.	Jul 30, 2026	Open
06	Bedroom 2	HVAC return vent cover missing 1 mounting screw	Mechanical Trades	Jul 28, 2026	Open

* Note: All completed items must be inspected and initialed by the Site Superintendent before final project sign-off.

INSPECTOR / SITE SUPERINTENDENT SIGNATURE

LEAD SUBCONTRACTOR REPRESENTATIVE