electrocelos
GRUPO ANDRÉ

Declaration of Performance

(Regulation UE n.º 305/2011 and Regulation UE n.º 574/2014)

N.º: 1/2019

Product Type	**Fire Curtain - FLAMA**
Intended uses	Construction - Fire Compartmentation
Manufacturer	MOTORLINE ELECTROCELOS, S.A. Travessa do Sobreiro, nº 29, 4755–474 Rio Côvo Santa Eugénia – Barcelos.
Brand	***Motorline Professional.***
System of Assessment and Verification of Constancy of Performance (Annex V of Regulation 305/2011)	System 3

TECNALIA RESEARCH@ INNOVATION performed tests of performance and durability of the curtain and fire resistance rating according to EN 1363-1:2012, EN 13501-2:2016, EN 16005:2012+AC:2015 and UNE-EN 12101-1:2005+A1:2006 under system 3 and issued the report n.º 070319-001-1, 070319-001-2, 070319-002-1, 070319-002-2, 070319-003-1, 070319-003-2, 071430, 079850-001-1 and 079850-001-2.

Essential Characteristics	Performance	Harmonized Technical Specifications
Classification of fire resistance	E 120 EW 90 EI_2 60 (with irrigation) EI_1 60 (with irrigation)	EN 1363-1:2012 EN1634-1:2014 EN 13501-2:2016
Rise of the curtain	Satisfactory	EN 16005:2012+AC:2015 UNE-EN 12101-1:2005+A1:2006
Lowering of the curtain	Satisfactory	EN 16005:2012+AC:2015 UNE-EN 12101-1:2005+A1:2006
Alarm	Satisfactory	EN 16005:2012+AC:2015 UNE-EN 12101-1:2005+A1:2006
Cutting off the power supply	Satisfactory	EN 16005:2012+AC:2015 UNE-EN 12101-1:2005+A1:2006
Operation through auxiliary power supply	Satisfactory	EN 16005:2012+AC:2015 UNE-EN 12101-1:2005+A1:2006
1000 Cycles	Satisfactory	EN 16005:2012+AC:2015 UNE-EN 12101-1:2005+A1:2006

The performance of the product identified above is in conformity with the set of declared performance/s. This de-claration of performance is issued, in accordance with Regulation (EU) N.º 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by André Viana, Administrator.

Barcelos, September 4, 2019

electrocelos S.A.