electrocelos
GRUPO ANDRÉ

Declaration of Performance
N.º: 002/2019

Product Type	**Rapid Door - PILE**
Intended to use	Construction (according to EN 12444:2001 and EN 12424:2000).
Manufacturer	Electrocelos – Sistemas Automatizados e Comunicações de Barcelos, S.A. Travessa do Sobreiro, nº 29, 4755–474 Rio Côvo Santa Eugénia – Barcelos.
Brand	***Motorline Professional.***
System of Assessment and Verification of Constancy of Performance	System 3

Tecnalia Inspiring Business performed:

- Tests of resistance to wind loads according to EN 12444:2001 and EN 12424:2000 under System 3 and issued the report n.º 057831-001;
- Tests of safe opening and operation forces according to UNE EN 13241-1:2004 under System 3 and issued the report n.º 21361-3.

Essentials Characteristics	Performance			Harmonized Technical Specifications
Resistance to wind loads	**Model**	**Width/ mm**	**Height/ mm**	EN 12444:2001 EN 12424:2000
			8500	
	Standard	8050	No Class (150 Pa)	
	With anti-storm kit	8050	Class 2	
Safe opening	PASS			EN 13241-1:2004
Operation forces	PASS			EN 13241-1:2004
Water tightness	NPD			---
Thermal resistance	NPD			---
Air permeability	NPD			---

*NPD – Parameter Not Determined
*150 Pa ≈ 55 km/h; Class 2 ≈ 100 km/h

This declaration is issued under the responsibility of the manufacturer. This document will lose its validity if there is any change of the product not agreed with the manufacturer.

Barcelos, 28 of February of 2019

electrocelos S.A

(André Viana, Administrator)