

NOTES

Power and Cooling Requirement

The maximum requirement for L10 rack would be 14 Amps (commando socket required).

The L10 rack is currently around 5200 BTU.

LEGEND

		Total Plus 20%		
		2900	84 Kg	5200
Make / Item	Model / Type	Watts	Weight	BTU

FRONT VIEW		SIDE VIEW		
Smartcomm	Custom	27	Blank Rack Panel	
Middle Atlantic	FEB1	26	Blank Rack Panel	
NETGEAR	M4250-26G4XF-PoE+	25	614	5.5 2100
Middle Atlantic	FEB1	24	Blank Rack Panel	
Middle Atlantic	FEB1	23	Blank Rack Panel	
Middle Atlantic	FEB1	22	Blank Rack Panel	
Middle Atlantic	FEB1	21	Blank Rack Panel	
Crestron	DM-NVX-360	20	200	1.0 33
Middle Atlantic	FEB1	19	Blank Rack Panel	
SKY+HD	DRX890W	18	45	2.3 155
Middle Atlantic	FEB1	15	Blank Rack Panel	
CRESTRON	CP4	14	300	1.5 50
Middle Atlantic	FEB1	13	Blank Rack Panel	
Symetrix	Prism 8x8-D	12	210	4.1 200
Middle Atlantic	FEB1	11	Blank Rack Panel	
KALEIDOVISION	KL4-A 2U	10	350	11 945
Middle Atlantic	VT1	09	Rack Vent Panel	
FURMAN	M10-XE	08	-	2.3 0.5
Middle Atlantic	VT1	07	Rack Vent Panel	
Powersoft	1204 DSP	06	251	6.8 345
Middle Atlantic	VT1	05	Rack Vent Panel	
Powersoft	1204 DSP	04	251	6.8 345
Middle Atlantic	VT1	03	Rack Vent Panel	
APC	SMT1500RMI2U	02	144	28.7 90
		01		

Middle Atlantic ERK-2725
27 RU Equipment Rack

Middle Atlantic CBS-ERK-25
Caster Base for 25 Inch

FRONT		SIDE	
Smartcomm	Custom	08	Blank Rack Panel
Middle Atlantic	BR1	07	Brush Grommet Panel
Middle Atlantic	FEB1	06	Blank Rack Panel
EXCEL+Lace Bar	100-026+LBP-6A	05	Keystone PP + Lace Bar
Middle Atlantic	FEB1	04	Blank Rack Panel
Middle Atlantic	BR1	03	Brush Grommet Panel
Middle Atlantic	FEB1	02	Blank Rack Panel
TDI+Lace Bar	CP-1065+LBP-6A	01	Speakon PP + Lace Bar

Middle Atlantic HPM-8-915
8 RU Hinged Panel Mount Rack

Usable Depth 15 in (38.1 cm)
Weight Capacity 11.3 kg

For Construction

© Copyright. All rights to this drawing and its design are the property of SmartComm Ltd. Any use or duplication of this drawing is strictly prohibited without prior written permission of SmartComm Ltd.

Drawn By	SD	30/11/23	
Checked By	LJ	30/11/23	
Issued By	SD	30/11/23	

SCALE NOT TO SCALE

PAGE SIZE A1



Smartcomm Ltd
Hullfax Road
Cressens Business Park
High Wycombe
Buckinghamshire
HP12 3SN
Tel: +44 (0)1494 471 912
E-mail: info@smartcomm.co.uk
Web: www.smartcomm.co.uk

C01	For Construction	30/11/23	SD
Rev	Description	Date	Name

Royal Mail Parkside
Block B Level 10
Rack Elevation - Rack Details

Project	Section	Type	Number	Revision	Version
NEPS	BB-10	HE	01	C01	V01