Our Order 2497163-10-1 Your Order 26-510 Packing List 422222-1 (7/13/2026) Image 566997
Heat W10776
Desc Pipe SMLS Nipple ASTM A106-B,1" x 6" XXH

2

WESTBROOK

MATERIAL TEST REPORT

1111 LOCKWOOD DR.
HOUSTON, TX 77020

Voice 713 675 6438
Fax 713 675 9742

Sold To: DODSON VALCO Purchase Order: 424599 Printed: 5/16/2025
Order No.: 351603 Order Date: 5/13/2025

Line: Description:
71 1 X 6 XXH A106B BLK SMLS NPL TBE

****** Specifications - Heat Code W10776: ******
A106-19 GR.B, SA106 GR.B, A234-19 WPB, SA234 WPB, A530, A733, ASME B36.10, B1.20.1, MSS SP-25, SP-95
STARTING MATERIAL: A106B PIPE & TUBE

Chemical Composition %:

C:	Mn:	P:	S:	Si:	Cr:	Ni:	Mo:
0.178	0.750	0.006	0.007	0.200	0.060	0.110	0.020

Cu:	V:	C.E.:
0.170	0.022	.342

Mechanical Properties:

Tensile(PSI):	Yield(PSI):	Elong(%):	Hardness:	Bend:	Hydro(PSI):
71025	46859	48.00	HRB 81-82	OK	2500

Comments:
Normalized 905C, 14 min, still air cooled.
Hot finished pipe.
Meets Nace MR-01-75/2015, MR-01-03/2012, and ISO 15156/2015.

We hereby certify that the contents of this Material Test Report are correct and accurate to the best of our knowledge and belief, that all test results are in compliance with the material specifications and that all material meets the dimensional requirements of the order. The products described have not come into contact with mercury or any of its components. No weld repair performed. Westbrook's Quality System is registered to ISO 9001, Certificate #32813. This document is in accordance with EN10204:2004 3.1/DIN50049 3.1B and was electronically transmitted. This inspection certificate is issued under the authority of Westbrook's QA Manager.

Prop 65 Warning for California Residents - Products listed may contain chemicals including Nickle and/or Carbon known to the State of California to cause cancer, birth defects and other reproductive harm. http://www.p65warnings.ca.gov/