Monday Oct-12-2026

Flowserve Facility:

Flowserve Cookeville Operations
1978 Foreman Drive
Cookeville, TN 38501

cmtrs@flowserve.com

To:

Valve Summary

SERIAL #	HEAT #	PO #	Order #	Description	Valve Type	Class	End Connection
61-584759	D1866	1103380		2" 2345	3375	900	FLG

FORM QF-MT VER 4

MTR Certificate Managed By MetalTrace. Trace Applications Inc. www.TraceApps.com toll-free: 1.866.429.7007

VEEYES

Veeyes Steelcast Private Limited.

4/363-A,Kallipalayam,Chikarampalayam Village Post,
Karamadai
Coimbatore, Pincode :641104

ISO CERTIFICATE
No:MUM6037939

VSC/LAB/06 - R0

INSPECTION CERTIFICATE
AS PER EN 10204 3.1

Customer : FLOWSERVE INDIA CONTROLS PVT LTD
CHENNAI 603209

T.C. No : FS/D1866/16
T.C.Date : 24/09/2016

P.Order : 10073960 Dt. 02/08/2016

Heat No : D1866
Pour Date : 11/08/2016

Specification : **ASTM A216 Gr.WCC -2016**

CASTING PROCESSED BY INDUCTION MELTING

FOUNDRY IDENTIFICATION : VSC

CHEMICAL COMPOSITION %

Element	C	Mn	Si	P	S	Cr	Ni	Mo	Cu	V	CE	RES	N	Al
Minimum	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Maximum	0.230	1.200	0.600	0.025	0.020	0.500	0.500	0.200	0.300	0.030	0.430	1.000	0.015	0.080
Actual	0.206	0.937	0.419	0.022	0.012	0.114	0.045	0.004	0.001	0.003	0.389	0.167	0.005	0.046

HEAT TREATMENT : NORMALIZING - Heated to 920°C Soaked for 3 1/2 Hrs and Air Cooled Cycle No.A2230

MECHANICAL PROPERTIES

Requirments	Yield Strength		Tensile Strength		% Elongation	% Reduction	Hardness	Bend Test	Impact Test in ()			
	MPa	Ksi	MPa	Ksi	GL :50 mm	In Area	BHN		(10mm X 10mm X 55mm)			
	0.2 % Rp		-		-	-	-					
Minimum	275.0(	40	485.00	70	22.00	35.00	---	-				
Maximum	---	---	655.00	95	---	---	237	-	1	2	3	Avg
Actual	314.48	46	527.43	76	36.88	61.71	143	-	--	--	--	--

ITEM DESCRIPTION

SL.No.	Description	Drawing No.	Part No.	Quantity
1	BODY MCG 2" cl 900/1500	487609 REV M	N487609-60	4 Nos

MTC - REVIEWED & ACCEPTED
10139336 FICPL QC

Remarks : Visual inspection as per MSS SP-55 Type II-XII a Satisfactory
Radioactive level measured, delievered materials are free of radioactive contamination
This certificate confirms to RMC 90012-REV 13 .
MPI Carried out acceptable to ASME B16.34 APPENDIX II
This certificate confirms to NACE MR0175/0103

We Confirm that the above material was manufactured, sampled, tested and inspected in accordance with the drawings, customer order requirements , material specification ASTM A216 Gr.WCC -2016 and was found to meet the requirements.

A.Senathipathi
Lab Incharge
Prepared by

C.Kannan
Manager QA
Makers Representative.