Aalberts Integrated Piping Systems Americas, Inc.

DBA – Conbraco Industries, Inc.

125 Highway 501 E. Conway, SC 29526

apollovalves.com | 704-841-6800

MATERIAL TEST REPORT

We certify that the below listed components were manufactured, tested, and inspected in accordance with the requirements of the procurement documents as stated.

Model Number: **72A**
Size: **1**
Quantity: **4**
Material Specification: **ASTM A105 Low Carbon(A105)**

Customer Name: **ADAM RYAN**
Customer Order Number: **17854**
Valve Part Number: **72-105-27A**
User Tag Number:

Heat_code	C	Mn	P	S	Si	Cr	Ni	Mo	Cu	V	Tensile_psi	Yield_psi	Elo	Ra	Hardness
RHS	0.19	0.85	0.009	0.029	0.23	0.121	0.068	0.046	0.19	0.005	76500	50700	28	59	156 BHN
XBX	0.28	0.84	0.009	0.017	0.26	0.11	0.09	0.03	0.15	0.001	86200	48100	27	60	161 HBW

TESTING PROCEDURE: All Apollo Valves are 100% tested in accordance with their standard of construction. Valves designed to the requirements of ASME B16.34 are tested to meet or exceed the requirements of API 598, ASME B16.34, MSS SP-61 and MSS SP-72. Valves designed to the requirements of MSS SP-110, are tested to meet or exceed the requirements of MSS SP-110. Specification sheets are available at www.apollovalves.com.

We certify that the above listed components meet the requirements of the procurement documents as stated.
This material certificate complies with EN 10204-2004 Type 3.1 (formerly Type 3.1.B).

Date: **09/22/26**
Signed:

The above listed information is certified to be true and accurate to the best of my knowledge and belief.

Cammie Warren
Quality Assurance Manager